

BODEGA BAY BUOY 46013, CA, USAWMO: **992490**Lat: **38.253N**Lon: **123.303W**Elev: **0**StdP: **101.33**Time Zone: **-8.00 (W08)**Period: **94-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	7.4	8.0	N/A	N/A	N/A	N/A	N/A	N/A	17.1	9.6	16.3	9.9	6.2	330	0.734

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	1.9	16.7	N/A	15.9	N/A	15.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.5	14.6	13.8	6.3	18.5	1.1	1.2	5.5	19.4	4.9	20.1	4.3	20.8	3.5	21.6		
			DB													
			WB													
				N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.7	11.1	11.1	10.8	10.7	10.9	11.4	12.1	12.8	13.1	12.9	12.2	11.2
	DBStd	1.55	1.32	1.42	1.33	1.04	1.04	1.00	1.28	1.26	1.37	1.45	1.35	1.60
	HDD10.0	32	5	6	7	4	3	1	0	0	0	1	1	6
	HDD18.3	2424	224	204	233	228	232	207	193	173	158	167	185	221
	CDD10.0	649	39	35	32	26	29	44	65	86	93	92	66	43
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.5	6.1	6.5	6.9	7.3	8.3	8.2	6.2	6.2	5.3	5.5	5.6	6.1
Precipitation	PrecAvg	1232	236	223	142	78	50	12	1	3	2	53	125	277
	PrecMax	1911	719	685	436	266	178	64	4	33	13	145	321	625
	PrecMin	686	3	12	4	12	0	0	0	0	0	1	63	
	PrecStd	367	170	164	126	67	56	17	1	7	3	41	92	195
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.6	15.1	14.8	14.3	14.5	14.8	16.3	17.0	18.0	17.4	16.5	16.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	13.9	14.2	13.8	13.1	13.4	14.1	15.4	16.1	16.7	16.4	15.4	15.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	13.4	13.6	13.2	12.6	12.9	13.6	14.8	15.4	15.5	15.7	14.8	14.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	13.0	13.0	12.7	12.2	12.4	13.0	14.1	14.7	15.0	15.1	14.1	13.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.1	1.8	1.8	1.6	1.5	1.5	1.7	1.8	1.9	1.8	2.0	2.1
		MCDBR	2.4	2.3	2.2	2.0	2.0	1.9	2.0	2.3	2.2	2.5	2.8	2.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.321	0.330	0.336	0.359	0.363	0.353	0.360	0.339	0.340	0.334	0.317	0.322	
	taud	2.573	2.547	2.537	2.434	2.456	2.487	2.476	2.540	2.513	2.573	2.595	2.571	
	Ebn at Noon	865	902	928	919	916	922	913	928	911	885	863	837	
	Edh at Noon	74	86	95	112	111	108	108	99	96	82	72	70	
All-Sky Solar Radiation	RadAvg	2.27	3.20	4.53	5.96	6.85	7.42	6.59	5.78	5.11	3.83	2.68	1.95	
	RadStd	0.33	0.41	0.40	0.42	0.50	0.39	0.40	0.38	0.34	0.28	0.21	0.30	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (35 neighbors)	N/A	N/A	-1.18	N/A	N/A	N/A	N/A	N/A	+127	N/A	

Nomenclature: See separate page