

PT ARGUELLO BUOY 46023, USA

WMO: 992580

Lat: 34.714N

Lon: 120.967W

Elev: 0

StdP: 101.33

Time Zone: -8.00 (W08)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	8.9	9.7	0.4	3.9	10.6	2.5	4.5	10.8	17.4	10.8	16.5	11.1	7.2	340	0.722

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	1.7	18.8	16.6	18.0	16.2	17.4	15.8	17.3	18.2	16.8	17.6	16.3	17.1	6.0	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	12.0	17.7	16.3	11.6	17.2	15.8	11.2	16.7	48.5	18.2	47.0	17.8	45.5	17.1	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	14.3	13.3	DB	7.5	20.8	1.6	2.6	6.3	22.7	5.4	24.2	4.5	25.7	3.3	27.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.3	12.4	12.5	12.2	11.7	12.0	13.0	14.0	14.8	15.4	15.0	14.1	12.8	(6)	
	DBStd	1.74	1.39	1.24	1.27	1.13	0.95	1.16	0.93	1.22	1.28	1.38	1.45	1.34	(7)	
	HDD10.0	3	1	0	1	1	0	0	0	0	0	0	0	1	(8)	
	HDD18.3	1829	183	164	190	200	197	159	135	109	89	105	126	172	(9)	
	CDD10.0	1217	77	69	69	51	62	91	123	149	161	154	124	87	(10)	
	CDD18.3	2	0	0	0	0	0	0	0	0	1	1	1	0	(11)	
	CDH23.3	1	0	0	0	1	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.9	6.5	6.7	7.6	7.7	7.8	7.2	6.7	6.8	6.1	6.4	6.5	6.8	(14)	
(15) Precipitation	PrecAvg	422	91	93	68	29	11	2	1	0	2	20	33	71	(15)	
	PrecMax	828	415	398	320	109	62	17	7	2	11	101	114	236	(16)	
	PrecMin	158	5	3	1	3	1	0	0	0	0	1	4	6	(17)	
	PrecStd	167	90	84	72	28	14	5	2	1	3	24	28	55	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.6	17.6	16.3	16.5	15.1	16.8	16.9	18.9	19.4	20.2	20.4	16.8	(19)	
		MCWB	12.6	10.8	13.0	13.0	13.5	15.2	15.5	17.0	17.3	15.9	16.7	13.5	(20)	
	2%	DB	15.2	15.5	15.1	14.2	14.3	15.7	16.3	18.0	18.5	18.6	17.7	15.8	(21)	
		MCWB	13.3	13.1	12.8	12.5	13.0	14.7	15.1	16.6	17.0	15.9	15.3	13.1	(22)	
	5%	DB	14.7	14.8	14.5	13.6	13.9	15.1	15.8	17.5	17.9	17.7	16.7	15.1	(23)	
		MCWB	12.9	12.8	12.7	12.0	12.7	14.1	14.8	16.3	16.6	15.6	14.3	12.8	(24)	
	10%	DB	14.2	14.1	14.0	13.0	13.4	14.7	15.3	16.7	17.2	16.8	16.1	14.6	(25)	
		MCWB	12.4	12.1	12.4	11.6	12.2	13.7	14.6	15.6	16.0	15.1	14.0	12.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.7	14.6	14.4	14.1	14.3	16.3	16.3	17.6	18.4	17.1	17.5	14.8	(27)	
		MCDB	15.2	15.0	14.9	15.3	14.6	16.3	16.4	18.2	19.1	18.2	19.5	15.4	(28)	
	2%	WB	14.0	13.9	13.7	13.3	13.7	15.2	15.7	17.0	17.5	16.6	15.9	14.4	(29)	
		MCDB	14.8	14.6	14.3	14.0	14.1	15.5	15.9	17.7	18.3	17.6	17.3	15.0	(30)	
	5%	WB	13.4	13.3	13.0	12.6	13.2	14.7	15.2	16.5	16.9	16.0	15.2	13.9	(31)	
		MCDB	14.3	14.1	13.8	13.4	13.7	15.0	15.5	17.5	17.7	17.0	16.0	14.6	(32)	
	10%	WB	12.9	12.8	12.6	12.1	12.7	14.0	14.9	15.8	16.4	15.4	14.7	13.3	(33)	
		MCDB	13.9	13.7	13.5	12.9	13.3	14.5	15.2	16.6	17.2	16.4	15.6	14.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.0	2.0	1.8	1.7	1.5	1.6	1.6	1.5	1.7	1.9	1.9	2.1	(35)	
		MCDBR	2.6	2.9	2.5	2.6	2.1	2.0	1.9	2.1	2.2	3.0	2.5	2.6	(36)	
	5% WB	MCWBR	2.3	2.7	2.3	2.3	1.8	1.6	1.5	1.6	1.9	2.7	2.6	2.8	(37)	
		MCWBR	2.2	2.3	2.2	2.7	2.1	2.1	1.9	1.9	2.1	2.5	2.2	2.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.312	0.323	0.338	0.347	0.354	0.353	0.358	0.344	0.347	0.345	0.318	0.317	(40)	
		taud	2.594	2.573	2.527	2.492	2.493	2.488	2.532	2.547	2.535	2.543	2.588	2.590	(41)	
	Ebn at Noon		902	928	937	939	929	925	918	930	915	890	887	874	(42)	
		Edh at Noon	77	87	99	107	108	109	104	100	97	88	76	73	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.98	3.82	5.15	6.37	6.92	6.99	6.28	5.84	5.33	4.24	3.30	2.64	(44)	
	RadStd		0.22	0.38	0.34	0.43	0.54	0.41	0.36	0.42	0.39	0.35	0.20	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)			+0.54	N/A	-1.28	+0.75	N/A	N/A	-158	+215	+58

Nomenclature: See separate page