

BLUNTS REEF BUOY 46030, CA, USA

WMO: 992650

Lat: 40.423N

Lon: 124.525W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 86-02

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	41.7	43.9	N/A	N/A	N/A	N/A	N/A	N/A	40.5	51.9	38.2	52.1	12.2	10	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.1	61.0	N/A	59.2	N/A	58.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10.5	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.2	31.1	26.0	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.9	50.5	50.1	50.1	50.8	51.8	52.5	53.3	54.3	54.1	52.9	52.1	50.8
	DBStd	2.92	2.89	3.46	2.36	1.86	2.63	2.21	1.81	2.04	2.51	2.27	2.49	3.47
	HDD50	159	30	34	28	13	9	3	0	0	1	3	8	30
	HDD65	4763	448	416	462	426	410	375	362	331	327	376	388	442
	CDD50	869	46	38	30	37	64	78	103	134	124	92	70	53
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	14.2	16.6	15.6	16.1	13.0	14.9	14.2	13.7	13.3	11.6	12.6	14.0	15.0
(15) Precipitation	PrecAvg	60.5	10.8	8.4	8.1	4.7	2.0	0.7	0.2	0.3	0.6	3.5	8.3	12.8
	PrecMax	90.4	24.4	18.8	17.0	14.0	6.3	4.5	0.7	0.9	3.6	12.4	17.6	29.0
	PrecMin	33.1	0.6	1.9	2.6	1.0	0.0	0.0	0.0	0.0	0.0	0.7	2.1	3.9
	PrecStd	14.2	5.7	4.0	4.1	2.6	1.7	1.0	0.2	0.2	0.9	2.4	3.6	6.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.4	58.8	57.5	56.4	60.1	59.4	59.4	63.1	63.2	61.0	59.5	59.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	56.3	56.6	55.6	55.2	58.6	58.1	58.1	61.6	59.9	57.7	57.9	57.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	55.3	55.3	54.6	54.4	57.1	57.1	57.1	58.4	58.7	56.8	56.9	56.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	54.7	54.5	53.5	53.6	55.4	55.9	56.2	57.0	57.4	55.8	55.7	55.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	3.8	3.9	3.7	3.4	2.7	3.0	2.8	3.1	3.5	3.6	3.7	4.0
		MCDBR	4.3	5.0	4.9	4.5	3.9	4.2	3.7	4.2	4.9	5.0	4.7	4.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.325	0.333	0.338	0.361	0.363	0.352	0.364	0.349	0.343	0.337	0.322	0.326
	taud		2.560	2.535	2.540	2.435	2.469	2.503	2.477	2.530	2.520	2.570	2.588	2.554
	Ebn at Noon		267	281	292	290	290	292	287	290	285	276	266	256
	Edh at Noon		23	27	30	35	35	34	34	31	30	26	22	22
(44) All-Sky Solar Radiation	RadAvg		601	860	1254	1715	2038	2241	2115	1811	1544	1079	689	501
	RadStd		84	116	111	130	132	121	128	99	85	75	67	83

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	-1.62	N/A	N/A	N/A	N/A	N/A	+225	+7

Nomenclature: See separate page