

EDISTO BUOY 41004, USA

WMO: 992730

Lat: 32.501N

Lon: 79.099W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (W05)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.8	41.2	23.3	17.6	41.9	26.4	20.4	44.3	36.6	56.3	35.1	55.8	20.9	10	0.581

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.4	85.2	79.6	84.4	78.9	84.0	78.4	81.0	84.1	80.2	83.6	79.5	83.0	12.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.1	156.0	83.7	79.1	151.1	83.4	78.3	146.8	82.8	44.5	84.3	43.7	83.7	42.9	83.2	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max			
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
34.3	31.5	29.0	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.0	56.9	57.8	62.3	67.3	73.0	78.8	81.1	81.3	79.1	73.1	67.0	61.7
	DBStd	10.10	8.61	6.92	5.87	4.38	3.21	2.40	1.64	1.92	2.57	4.99	6.41	7.90
	HDD50	69	37	16	4	0	0	0	0	0	0	0	1	11
	HDD65	849	270	213	116	28	1	0	0	0	0	9	55	157
	CDD50	7372	252	233	384	520	712	864	966	971	872	715	511	372
	CDD65	2678	20	10	32	98	248	414	501	506	422	259	115	53
	CDH74	20880	2	0	0	20	633	3643	5517	5686	3878	1207	223	71
CDH80	3616	0	0	0	0	0	392	1233	1460	501	30	0	0	
Wind	WSAvg	14.9	17.4	17.0	15.9	14.7	13.8	12.7	13.0	12.3	13.8	15.0	16.3	16.9
Precipitation	PrecAvg	49.0	3.7	3.0	3.7	2.9	2.7	4.9	6.2	6.7	5.3	4.7	2.4	3.1
	PrecMax	70.7	8.0	9.2	7.3	6.9	5.2	12.2	11.1	12.8	9.1	14.6	6.0	8.4
	PrecMin	38.3	0.9	1.1	0.6	1.1	0.3	2.3	2.7	2.0	0.8	0.0	0.0	0.9
	PrecStd	8.1	2.2	1.6	1.8	1.5	1.4	2.4	2.4	2.9	2.0	3.5	1.7	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.1	72.3	73.1	75.9	79.4	84.5	85.9	86.3	84.1	82.2	79.4	77.3
		MCWB	69.8	68.7	68.8	71.2	73.7	79.5	79.4	80.6	77.6	76.6	74.3	72.4
	2%	DB	72.1	70.7	71.9	74.7	78.3	84.1	84.8	85.4	83.3	80.9	77.9	76.3
		MCWB	67.6	67.8	67.9	70.2	73.0	79.0	79.4	79.8	76.8	75.4	72.7	72.0
	5%	DB	70.5	69.1	70.9	73.6	77.6	83.3	84.2	84.9	82.8	79.9	76.6	74.3
		MCWB	65.9	65.7	66.8	69.3	72.5	78.1	78.9	79.3	76.4	74.4	70.8	69.3
	10%	DB	68.8	67.3	69.6	72.7	77.0	82.2	83.5	84.3	82.3	78.8	75.2	72.3
		MCWB	64.1	63.3	65.3	68.4	72.0	77.3	78.4	78.6	76.0	73.0	68.8	66.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.7	69.5	71.1	72.6	76.2	80.9	81.4	82.4	80.9	78.2	75.6	74.4
		MCDB	73.4	71.0	72.3	75.0	77.5	84.0	83.9	85.7	81.7	81.4	78.5	76.8
	2%	WB	67.8	68.1	69.2	71.7	75.1	79.8	80.7	81.3	79.2	77.1	74.3	73.0
		MCDB	70.8	70.1	71.2	74.2	77.1	83.1	83.5	85.0	81.7	80.3	77.6	76.1
	5%	WB	66.1	66.3	67.9	70.8	74.3	78.8	80.1	80.4	78.3	75.9	72.5	70.5
		MCDB	69.4	68.6	70.3	73.5	76.8	82.4	83.2	84.3	81.7	79.6	76.4	74.4
	10%	WB	63.8	64.0	66.4	69.4	73.5	78.1	79.4	79.5	77.5	74.6	70.1	66.9
		MCDB	67.8	66.7	69.3	72.3	76.6	81.8	82.8	83.7	81.6	78.8	74.8	71.6
Mean Daily Temperature Range	5% DB	MDBR	8.9	8.9	7.0	5.2	3.7	3.1	2.9	3.4	3.6	5.0	6.7	8.1
		MCDBR	7.8	8.2	6.7	4.4	3.1	2.9	3.1	3.4	3.5	4.6	7.4	7.1
		MCWBR	9.7	9.0	7.2	4.8	3.8	3.2	3.4	3.7	3.7	5.2	7.3	7.6
	5% WB	MCDBR	8.3	7.4	6.4	4.2	3.4	2.8	2.7	3.2	3.3	5.0	7.3	7.6
		MCWBR	10.2	8.0	7.0	5.0	4.3	3.3	3.3	3.9	4.0	5.6	7.5	8.8
Clear-Sky Solar Irradiance	taub	0.343	0.349	0.372	0.401	0.452	0.473	0.504	0.486	0.429	0.397	0.360	0.346	
	taud	2.521	2.511	2.457	2.358	2.271	2.261	2.185	2.240	2.390	2.451	2.506	2.537	
	Ebn at Noon	278	288	288	282	267	260	252	255	266	267	269	270	
	Edh at Noon	27	30	34	39	43	43	47	44	36	32	27	26	
All-Sky Solar Radiation	RadAvg	874	1099	1472	1904	2105	2125	1998	1794	1516	1305	981	784	
	RadStd	65	121	142	143	129	150	125	122	127	128	65	61	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (23 neighbors)	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+338	+229

Nomenclature: See separate page