

EDISTO BUOY 41004, USA

WMO: 992730

Lat: 32.501N

Lon: 79.099W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (W05)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.2	5.1	-4.8	2.5	5.5	-3.1	2.9	6.8	16.4	13.5	15.7	13.2	9.3	10	0.581

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.9	29.5	26.5	29.1	26.1	28.9	25.8	27.2	29.0	26.8	28.7	26.4	28.4	5.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.3	28.7	26.2	21.6	28.5	25.7	21.0	28.2	85.7	29.1	83.7	28.7	81.9	28.5	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.3	14.1	13.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.1	13.8	14.3	16.8	19.6	22.8	26.0	27.3	27.4	26.1	22.8	19.4	16.5
	DBStd	5.61	4.78	3.85	3.26	2.43	1.78	1.33	0.91	1.07	1.43	2.77	3.56	4.39
	HDD10.0	38	21	9	2	0	0	0	0	0	0	0	1	6
	HDD18.3	472	150	118	64	16	1	0	0	0	0	5	31	87
	CDD10.0	4096	140	129	213	289	396	480	537	539	484	397	284	207
	CDD18.3	1488	11	6	18	54	138	230	278	281	234	144	64	29
	CDH23.3	11600	1	0	0	11	352	2024	3065	3159	2154	671	124	39
(14) Wind	WSAvg	6.7	7.8	7.6	7.1	6.6	6.2	5.7	5.8	5.5	6.2	6.7	7.3	7.6
	PrecAvg	1245	94	75	93	73	68	124	157	169	134	119	60	79
	PrecMax	1796	202	234	186	175	132	309	283	324	231	371	152	214
	PrecMin	972	22	29	16	29	8	59	69	51	20	0	1	22
	PrecStd	207	57	41	45	37	36	61	61	74	52	89	42	44
	DB	23.4	22.4	22.8	24.4	26.3	29.2	30.0	30.2	29.0	27.9	26.3	25.2	
	MCWB	21.0	20.4	20.5	21.8	23.1	26.4	26.3	27.0	25.3	24.8	23.5	22.5	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	22.3	21.5	22.2	23.7	25.7	28.9	29.3	29.7	28.5	27.2	25.5	24.6	
	2% MCWB	19.8	19.9	19.9	21.2	22.8	26.1	26.3	26.6	24.9	24.1	22.6	22.2	
	5% DB	21.4	20.6	21.6	23.1	25.3	28.5	29.0	29.4	28.2	26.6	24.8	23.5	
	5% MCWB	18.8	18.7	19.3	20.7	22.5	25.6	26.1	26.3	24.6	23.6	21.6	20.7	
	10% DB	20.4	19.6	20.9	22.6	25.0	27.9	28.6	29.0	27.9	26.0	24.0	22.4	
	10% MCWB	17.8	17.4	18.5	20.2	22.2	25.2	25.8	25.9	24.4	22.8	20.5	19.1	
	WB	21.5	20.8	21.7	22.6	24.6	27.2	27.5	28.0	27.2	25.7	24.2	23.6	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	23.0	21.7	22.4	23.9	25.3	28.9	28.8	29.8	27.6	27.4	25.8	24.9	
	2% WB	19.9	20.1	20.7	22.0	24.0	26.6	27.0	27.4	26.2	25.1	23.5	22.8	
	2% MCDB	21.6	21.2	21.8	23.5	25.1	28.4	28.6	29.4	27.6	26.8	25.3	24.5	
	5% WB	18.9	19.0	19.9	21.5	23.5	26.0	26.7	26.9	25.7	24.4	22.5	21.4	
	5% MCDB	20.8	20.3	21.3	23.0	24.9	28.0	28.4	29.1	27.6	26.4	24.7	23.6	
	10% WB	17.7	17.8	19.1	20.8	23.0	25.6	26.3	26.4	25.3	23.7	21.2	19.4	
	10% MCDB	19.9	19.3	20.7	22.4	24.8	27.7	28.2	28.7	27.6	26.0	23.8	22.0	
(35) Mean Daily Temperature Range	MDBR	4.9	5.0	3.9	2.9	2.1	1.7	1.6	1.9	2.0	2.8	3.7	4.5	
	5% DB	4.4	4.5	3.7	2.4	1.7	1.6	1.7	1.9	2.0	2.6	4.1	3.9	
	5% MCWBR	5.4	5.0	4.0	2.7	2.1	1.8	1.9	2.0	2.0	2.9	4.0	4.2	
	5% MCDBR	4.6	4.1	3.5	2.4	1.9	1.5	1.5	1.8	1.8	2.8	4.1	4.2	
	5% MCWBR	5.7	4.5	3.9	2.8	2.4	1.8	1.9	2.1	2.2	3.1	4.2	4.9	
(40) Clear-Sky Solar Irradiance	taub	0.343	0.349	0.372	0.401	0.452	0.473	0.504	0.486	0.429	0.397	0.360	0.346	
	taud	2.521	2.511	2.457	2.358	2.271	2.261	2.185	2.240	2.390	2.451	2.506	2.537	
	Ebn at Noon	876	907	908	890	843	821	794	803	839	842	848	852	
	Edh at Noon	86	95	108	124	136	137	147	138	114	100	86	81	
(44) All-Sky Solar Radiation	RadAvg	2.75	3.46	4.64	6.00	6.64	6.70	6.30	5.66	4.78	4.11	3.09	2.47	
	RadStd	0.21	0.38	0.45	0.45	0.41	0.47	0.39	0.39	0.40	0.41	0.20	0.19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+188	+127

Nomenclature: See separate page