

EEL RIVER BUOY 46022, CA, USAWMO: **992740**Lat: **40.712N**Lon: **124.529W**Elev: **0**StdP: **101.33**Time Zone: **-8.00 (W08)**Period: **94-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.1	6.9	N/A	N/A	N/A	N/A	N/A	N/A	18.1	12.3	16.6	11.2	5.3	0	0.704

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	1.9	17.3	N/A	16.5	N/A	15.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.1	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.9	14.4	13.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	10.6	10.0	9.8	10.3	11.1	12.2	12.8	13.5	13.5	12.4	11.6	10.8
	DBStd	1.91	1.72	1.58	1.34	1.16	1.16	1.17	1.27	1.41	1.68	1.47	1.50	1.68
	HDD10.0	78	14	18	19	10	3	0	0	0	0	1	4	11
	HDD18.3	2477	241	234	263	242	224	184	172	151	146	183	201	235
	CDD10.0	644	31	17	14	19	36	66	86	107	104	76	53	34
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.0	6.9	6.9	7.0	6.4	6.0	5.7	5.2	4.5	4.6	5.2	6.1	7.3
Precipitation	PrecAvg	1536	275	214	205	120	52	19	4	7	15	90	211	324
	PrecMax	2295	619	477	433	355	160	114	19	22	91	314	448	737
	PrecMin	841	14	47	67	25	1	0	0	1	0	17	53	98
	PrecStd	360	146	101	105	67	43	25	6	5	22	61	91	167
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.9	14.4	14.1	13.7	15.5	15.7	16.8	18.3	18.8	16.9	15.6	15.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	14.1	13.6	13.1	12.9	14.2	15.1	15.9	16.9	17.6	15.9	14.9	14.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	13.5	12.9	12.3	12.4	13.3	14.5	15.3	16.2	16.8	15.3	14.4	13.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	13.0	12.2	11.8	11.9	12.8	14.0	14.7	15.5	16.1	14.6	13.9	13.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.3	2.2	2.0	1.8	1.5	1.6	1.6	1.9	1.9	2.0	2.3	2.4
		MCDBR	2.5	2.6	2.6	2.1	2.0	2.0	2.0	2.5	2.1	2.5	2.7	2.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.324	0.332	0.337	0.359	0.362	0.351	0.364	0.349	0.344	0.337	0.322	0.326	
	taud	2.562	2.542	2.545	2.444	2.477	2.514	2.483	2.535	2.521	2.573	2.592	2.557	
	Ebn at Noon	841	886	918	914	915	922	906	913	898	868	837	807	
	Edh at Noon	72	84	93	109	108	105	107	99	94	80	69	67	
All-Sky Solar Radiation	RadAvg	1.86	2.67	3.90	5.35	6.41	7.03	6.69	5.71	4.84	3.35	2.12	1.54	
	RadStd	0.26	0.36	0.36	0.42	0.39	0.38	0.40	0.32	0.26	0.24	0.21	0.26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	N/A	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	+101	+2

Nomenclature: See separate page