

GULF OF MAINE BUOY 44005, USA

WMO: 992760

Lat: 43.201N

Lon: 69.128W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (W05)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.0	18.5	N/A	N/A	N/A	N/A	N/A	N/A	40.2	28.5	38.0	28.0	24.3	320	0.727

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	72.3	N/A	71.1	N/A	69.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	11.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.7	33.7	30.9	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.4	33.0	32.7	36.3	42.2	48.7	56.5	64.9	66.1	61.0	53.0	45.8	39.2		
	DBStd	12.56	8.09	6.62	5.59	3.39	3.62	4.10	3.41	3.01	3.70	4.21	5.35	6.53		
	HDD50	2243	528	485	426	234	70	2	0	0	0	22	141	335		
	HDD65	6178	993	905	891	684	505	256	45	23	128	373	576	799		
	CDD50	1647	0	0	0	0	30	197	461	498	331	113	16	1		
	CDD65	108	0	0	0	0	0	2	41	56	9	0	0	0		
	CDH74	13	0	0	0	0	0	0	6	7	0	0	0	0		
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0		
(14) Wind	WSAvg	15.0	19.8	19.5	17.3	14.4	11.8	11.0	10.9	10.9	12.3	15.9	17.3	19.4		
(15) Precipitation	PrecAvg	48.1	3.5	3.3	4.3	4.0	3.8	4.3	3.4	3.2	4.3	5.0	4.5	4.6		
	PrecMax	72.3	5.5	6.9	7.9	9.8	7.9	9.2	7.5	9.6	9.1	16.1	7.7	7.6		
	PrecMin	34.3	0.4	1.5	1.1	0.4	1.0	1.0	0.8	0.4	0.4	1.3	1.5	1.8		
	PrecStd	7.6	1.3	1.1	1.9	1.9	1.8	2.3	1.7	1.9	2.3	3.0	1.5	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	47.0	49.2	52.5	59.7	68.8	74.3	75.0	71.4	62.9	57.1	53.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	48.4	44.6	46.3	49.4	57.3	66.1	72.2	72.8	69.4	61.1	55.4	51.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	46.3	43.1	44.7	48.0	55.5	64.1	70.9	71.5	67.8	59.5	54.2	50.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	44.0	41.3	43.2	46.5	53.9	62.0	69.4	70.4	66.1	58.5	52.9	48.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	8.6	6.7	4.7	4.5	4.5	4.4	4.5	4.5	4.8	6.0	7.8		
		MCDBR	11.0	9.6	6.9	6.4	6.6	6.2	5.7	5.4	5.5	5.0	6.5	8.8		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.320	0.325	0.340	0.362	0.392	0.433	0.457	0.424	0.374	0.351	0.328	0.312		
	taud		2.459	2.466	2.461	2.425	2.384	2.281	2.241	2.322	2.431	2.493	2.520	2.519		
	Ebn at Noon		258	277	286	287	279	267	259	264	271	264	253	251		
	Edh at Noon		23	27	31	35	37	42	43	38	32	27	22	21		
(44) All-Sky Solar Radiation	RadAvg		477	775	1163	1513	1720	1845	1935	1744	1401	920	562	399		
	RadStd		36	63	83	154	187	160	122	80	87	81	53	47		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page