

GULF OF MAINE BUOY 44005, USA

WMO: 992760

Lat: 43.201N

Lon: 69.128W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (W05)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.0	-7.5	N/A	N/A	N/A	N/A	N/A	N/A	18.0	-2.0	17.0	-2.2	10.9	320	0.727

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.5	22.4	N/A	21.7	N/A	21.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	15.1	13.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	0.5	0.4	2.4	5.7	9.3	13.6	18.3	18.9	16.1	11.6	7.7	4.0
	DBStd	6.98	4.49	3.68	3.10	1.89	2.01	2.28	1.90	1.67	2.05	2.34	2.97	3.63
	HDD10.0	1246	293	269	237	130	39	1	0	0	12	78	186	
	HDD18.3	3432	552	503	495	380	281	142	25	13	71	207	320	444
	CDD10.0	915	0	0	0	0	17	109	256	277	184	63	9	1
	CDD18.3	60	0	0	0	0	0	1	23	31	5	0	0	0
	CDH23.3	7	0	0	0	0	0	0	3	4	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
(14) Wind	WSAvg	6.7	8.9	8.7	7.8	6.4	5.3	4.9	4.9	4.9	5.5	7.1	7.7	8.7
(15) Precipitation	PrecAvg	1223	89	84	108	102	97	109	86	82	108	127	115	117
	PrecMax	1836	140	176	200	249	201	233	191	245	230	408	195	193
	PrecMin	872	11	38	27	10	26	26	20	10	33	37	46	
	PrecStd	194	33	29	47	48	46	58	42	49	58	76	37	38
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	8.3	9.6	11.4	15.4	20.4	23.5	23.9	21.9	17.1	13.9	11.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	9.1	7.0	8.0	9.7	14.0	18.9	22.3	22.6	20.8	16.1	13.0	10.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	7.9	6.1	7.0	8.9	13.1	17.8	21.6	21.9	19.9	15.3	12.3	10.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	6.7	5.2	6.2	8.0	12.2	16.7	20.8	21.3	19.0	14.7	11.6	9.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	4.8	3.7	2.6	2.5	2.5	2.4	2.5	2.5	2.7	3.3	4.4
		MCDBR	6.1	5.3	3.9	3.5	3.7	3.5	3.2	3.0	3.1	2.8	3.6	4.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.320	0.325	0.340	0.362	0.392	0.433	0.457	0.424	0.374	0.351	0.328	0.312
	taud		2.459	2.466	2.461	2.425	2.384	2.281	2.241	2.322	2.431	2.493	2.520	2.519
	Ebn at Noon		813	874	903	904	881	842	817	833	854	832	799	792
	Edh at Noon		74	86	98	110	118	131	135	121	100	84	70	65
(44) All-Sky Solar Radiation	RadAvg		1.50	2.44	3.67	4.77	5.42	5.82	6.10	5.50	4.42	2.90	1.77	1.26
	RadStd		0.11	0.20	0.26	0.49	0.59	0.50	0.39	0.25	0.27	0.26	0.17	0.15

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+76	N/A

Nomenclature: See separate page