

BERING SEA BUOY 46035, USA

WMO: 992820

Lat: 57.016N

Lon: 177.703W

Elev: 0

StdP: 14.70

Time Zone: -12.00 (W12)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 16.5	(c) 18.8	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 51.1	(k) 30.0	(l) 47.2	(m) 31.0	(n) 24.8	(o) 350	(p) 1.083

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 2.2	(c) 53.1	(d) N/A	(e) 52.2	(f) N/A	(g) 51.4	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 15.4	(p) 80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 43.0	(b) 39.7	(c) 36.5	(e) 14.8	(f) 52.9	(g) 3.7	(h) 2.0	(i) 12.1	(j) 54.4	(k) 10.0	(l) 55.6	(m) 7.9	(n) 56.7	(o) 5.2	(p) 58.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.7	29.6	29.9	29.9	32.1	36.4	41.7	46.2	49.1	47.5	41.2	36.0	32.1		
	DBStd	7.93	5.35	5.15	5.17	3.48	2.86	2.60	2.07	2.07	2.83	3.50	3.68	4.60		
	HDD50	4515	631	564	622	538	422	248	120	40	81	273	420	556		
	HDD65	9968	1096	984	1087	988	887	698	583	492	524	738	870	1021		
	CDD50	22	0	0	0	0	0	0	1	14	7	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	19.5	23.5	24.3	21.4	19.7	16.5	14.2	13.9	15.6	18.1	21.0	23.2	23.3		
	PrecAvg	38.7	3.4	3.4	3.2	2.0	2.0	2.6	3.4	3.7	3.7	3.3	4.1	3.8		
	PrecMax	47.7	5.5	6.4	7.2	4.4	3.7	4.0	5.0	6.5	5.7	5.0	7.4	6.5		
(15) Precipitation	PrecMin	31.7	1.2	0.8	1.2	0.8	0.9	0.7	1.5	1.8	1.6	1.6	2.0	1.2		
	PrecStd	4.4	1.1	1.4	1.3	0.8	0.7	0.8	0.9	1.0	1.0	0.9	1.4	1.3		
	0.4% DB	40.0	38.4	38.8	38.9	44.0	49.8	53.0	54.4	54.0	49.9	44.5	40.9			
	0.4% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	39.0	37.4	37.5	37.8	42.0	47.4	51.2	53.4	52.8	48.1	43.2	39.5			
	2% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	5% DB	37.9	36.8	36.8	37.2	41.2	46.2	50.1	52.6	51.9	46.4	42.1	38.9			
	5% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	10% DB	36.8	36.1	35.9	36.5	40.3	45.2	49.1	51.8	51.2	45.7	41.1	38.1			
	10% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	0.4% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	0.4% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	2% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	5% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	5% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	10% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	10% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	5% DB	4.1	4.1	4.1	3.7	2.7	2.5	2.2	2.2	2.4	3.4	4.2	4.1			
	5% WB	3.7	4.0	3.8	3.6	2.7	3.4	2.6	2.3	2.1	3.1	4.1	4.2			
(36) Mean Daily Temperature Range	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
(40) Clear-Sky Solar Irradiance	taub	0.303	0.324	0.335	0.402	0.409	0.397	0.408	0.399	0.374	0.337	0.336	0.267			
	taud	2.208	2.313	2.360	2.141	2.200	2.335	2.337	2.363	2.346	2.331	2.122	2.335			
	Ebn at Noon	177	229	261	255	262	268	262	255	243	220	154	169			
	Edh at Noon	17	23	29	41	42	37	36	33	29	23	18	11			
(44) All-Sky Solar Radiation	RadAvg	121	295	638	1037	1215	1286	1153	951	771	437	166	84			
	RadStd	14	23	61	98	121	101	81	99	80	33	19	9			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page