

K1 BUOY 62029, United Kingdom

WMO: 992880

Lat: 48.720N

Lon: 12.430W

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	44.3	45.7	31.9	26.4	46.5	34.2	28.8	47.3	67.8	49.0	62.8	49.8	26.7	300	0.952

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.6	66.2	64.3	65.5	63.5	64.8	62.8	64.9	65.6	64.2	65.1	63.5	64.5	21.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.6	91.2	65.5	63.7	88.4	64.9	63.0	86.0	64.3	29.9	65.8	29.4	65.3	28.9	64.6	67.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
64.3	56.4	49.1	DB	41.3	66.8	2.0	1.4	39.9	67.8	38.7	68.7	37.6	69.5	36.2	70.5	
			WB	37.9	65.6	1.8	1.3	36.6	66.5	35.6	67.2	34.6	68.0	33.3	68.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.8	51.4	51.0	51.0	51.9	54.5	57.9	61.0	62.3	61.4	58.7	54.9	52.8
	DBStd	4.72	2.51	2.33	2.26	2.21	2.01	2.08	2.00	1.75	2.06	2.39	2.62	2.65
	HDD50	65	15	16	16	8	0	0	0	0	0	0	1	9
	HDD65	3379	421	392	435	394	327	212	123	87	109	196	304	379
	CDD50	2163	59	44	46	64	138	238	342	380	341	269	148	94
	CDD65	3	0	0	0	0	0	0	1	2	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	22.8	26.1	25.1	22.1	20.9	21.5	19.1	18.8	19.1	21.4	24.1	26.7	28.3
(15) Precipitation	PrecAvg	38.9	4.6	3.7	3.2	2.3	2.3	2.2	2.1	2.5	2.9	4.3	4.0	4.7
	PrecMax	53.2	9.4	9.1	5.6	4.0	3.7	5.6	4.0	9.3	5.0	6.1	6.6	8.2
	PrecMin	29.8	2.0	1.3	1.4	0.8	0.4	0.8	0.7	0.5	0.9	1.7	1.5	1.6
	PrecStd	4.4	1.6	1.6	1.1	0.9	0.7	1.1	0.8	1.7	1.0	1.2	1.4	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.2	56.3	55.7	60.7	62.8	64.4	66.6	67.5	66.5	64.7	61.1	59.2
		MCWB	55.2	54.5	53.9	59.7	60.5	62.1	64.2	65.6	64.6	62.4	59.1	57.0
	2%	DB	56.3	55.3	55.0	55.9	59.1	63.0	65.6	66.5	65.7	63.4	60.2	57.9
		MCWB	54.4	53.5	53.1	53.9	57.0	60.9	63.5	64.6	63.7	61.2	58.2	55.8
	5%	DB	55.6	54.7	54.4	55.3	57.6	61.9	64.7	65.7	65.1	62.7	59.3	57.0
		MCWB	53.7	52.7	52.5	53.4	55.6	59.8	62.8	63.8	63.2	60.4	57.4	54.8
	10%	DB	54.9	54.0	53.8	54.7	57.0	60.9	64.0	65.1	64.4	62.0	58.5	56.3
		MCWB	52.9	52.0	51.8	52.6	55.1	58.7	62.0	63.1	62.5	59.7	56.3	54.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.8	55.2	54.7	59.5	60.7	62.8	64.8	66.4	65.6	63.0	60.2	57.7
		MCDB	56.4	55.6	55.0	60.6	62.7	63.7	65.5	67.0	66.0	63.7	60.6	58.5
	2%	WB	54.9	54.0	53.9	54.8	57.6	61.3	64.3	65.4	64.6	62.0	59.0	56.5
		MCDB	55.8	54.7	54.5	55.5	58.5	62.4	65.1	66.1	65.3	62.9	59.6	57.5
	5%	WB	54.4	53.5	53.1	54.0	56.4	60.2	63.5	64.5	63.8	61.2	58.0	55.6
		MCDB	55.4	54.3	54.0	55.0	57.3	61.4	64.4	65.4	64.7	62.2	58.9	56.6
	10%	WB	53.6	52.8	52.5	53.2	55.7	59.3	62.6	63.7	63.1	60.5	56.9	54.7
		MCDB	54.9	53.9	53.7	54.6	56.7	60.5	63.7	64.8	64.1	61.7	58.2	56.0
(35) Mean Daily Temperature Range	5% DB	MDBR	3.9	3.4	3.0	2.9	2.5	2.3	2.4	2.6	2.7	3.1	3.6	3.6
		MCDBR	4.5	3.9	3.5	3.3	3.3	3.0	2.8	2.9	2.9	3.2	3.7	4.1
		MCWBR	5.9	5.4	4.6	4.0	3.9	3.8	3.2	3.6	4.1	4.4	5.4	5.4
	5% WB	MCDBR	4.4	3.7	3.5	3.4	3.2	2.9	2.7	2.9	2.8	3.2	3.6	4.0
		MCWBR	6.0	5.5	4.8	4.5	4.0	3.9	3.4	3.9	4.0	4.4	5.3	5.5
(40) Clear-Sky Solar Irradiance	taub		0.357	0.363	0.386	0.384	0.393	0.377	0.384	0.370	0.368	0.365	0.354	0.354
	taud		2.300	2.358	2.323	2.376	2.387	2.469	2.461	2.515	2.511	2.444	2.332	2.265
	Ebn at Noon		215	247	261	275	276	280	277	276	266	244	214	196
	Edh at Noon		24	28	34	35	36	34	34	30	28	25	23	22
(44) All-Sky Solar Radiation	RadAvg		314	528	918	1408	1648	1814	1665	1493	1103	681	375	241
(45)	RadStd		30	33	63	84	113	115	143	108	66	47	35	20

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	-1.55	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page