

ANASURIA BUOY 62164, United Kingdom

WMO: 992900

Lat: 57.200N

Lon: 0.800E

Elev: 98

StdP: 14.64

Time Zone: 0.00 (EUW)

Period: 02-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	34.8	36.8	N/A	N/A	N/A	N/A	N/A	N/A	40.9	43.4	38.3	43.9	18.6	100	0.792

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.3	74.1	N/A	70.4	N/A	67.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	15.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.7	33.3	30.3	DB	34.3	78.2	3.1	8.8	32.1	84.5	30.3	89.7	28.5	94.6	26.3	101.0	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.9	45.6	45.1	45.6	48.8	53.2	57.7	62.5	62.7	59.7	54.7	51.0	47.4
	DBStd	7.44	3.63	3.87	4.26	3.90	4.09	3.84	4.37	3.76	4.11	3.61	3.58	4.14
	HDD50	641	143	142	145	68	13	0	0	0	0	4	27	99
	HDD65	4487	602	557	601	487	367	222	105	94	167	320	420	545
	CDD50	1689	6	6	9	31	111	231	387	393	290	149	57	19
	CDD65	59	0	0	0	0	0	3	27	22	7	0	0	0
	CDH74	143	0	0	0	0	1	13	70	43	14	2	0	0
	CDH80	27	0	0	0	0	0	0	16	9	2	0	0	0
(14) Wind	WSAvg	16.3	20.5	18.6	17.2	13.8	13.9	12.8	12.8	14.2	15.2	17.0	19.4	20.1
(15) Precipitation	PrecAvg	44.6	5.3	4.3	3.9	2.2	1.8	2.5	2.9	3.3	3.8	4.4	5.1	5.2
	PrecMax	56.1	8.9	7.7	6.8	3.6	3.0	4.3	4.3	6.2	5.9	7.4	7.5	11.6
	PrecMin	32.8	1.8	2.2	1.6	1.2	0.8	1.3	1.3	1.1	1.8	1.5	2.7	2.6
	PrecStd	5.6	1.9	1.5	1.2	0.7	0.5	0.7	0.8	1.0	1.1	1.4	1.2	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.3	59.2	61.6	65.6	70.4	75.9	81.9	79.4	75.5	70.2	66.3	61.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	52.7	53.0	53.9	59.2	63.4	67.3	74.1	72.1	70.3	63.0	58.0	54.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	50.6	50.2	51.1	55.4	59.6	63.5	69.9	68.7	65.7	59.4	55.7	53.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	49.3	48.6	49.4	52.7	57.1	61.3	66.7	66.1	63.0	57.8	54.6	51.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	6.8	7.8	9.3	10.6	9.9	11.1	9.3	8.7	7.3	6.3	7.2
		MCDBR	9.9	10.7	11.3	15.3	15.5	14.2	17.4	14.8	14.6	12.1	9.9	10.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.329	0.347	0.367	0.391	0.376	0.380	0.387	0.383	0.369	0.351	0.330	0.308
	taud		2.207	2.295	2.321	2.293	2.412	2.425	2.416	2.434	2.455	2.387	2.257	2.171
	Ebn at Noon		164	219	248	260	273	273	268	261	247	216	163	135
	Edh at Noon		17	24	30	36	34	34	33	31	26	22	16	13
(44) All-Sky Solar Radiation	RadAvg		125	324	730	1263	1748	1726	1620	1336	888	448	170	85
	RadStd		13	42	58	97	103	115	154	92	91	32	16	10

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page