

ANASURIA BUOY 62164, United KingdomWMO: **992900**Lat: **57.200N**Lon: **0.800E**Elev: **30**StdP: **100.97**Time Zone: **0.00 (EUW)**Period: **02-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.5	2.7	N/A	N/A	N/A	N/A	N/A	N/A	18.3	6.3	17.1	6.6	8.3	100	0.792

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	23.4	N/A	21.3	N/A	19.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.8	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	14.9	13.6	1.3	25.7	1.7	4.9	0.0	29.2	-1.0	32.0	-1.9	34.8	-3.2	38.3		
(5)			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	7.5	7.3	7.6	9.3	11.8	14.3	16.9	17.0	15.4	12.6	10.6	8.6
	DBStd	4.13	2.01	2.15	2.37	2.17	2.27	2.13	2.43	2.09	2.28	2.01	1.99	2.30
	HDD10.0	356	79	79	81	38	7	0	0	0	0	2	15	55
	HDD18.3	2493	334	309	334	271	204	123	58	52	93	178	233	303
	CDD10.0	938	3	3	5	17	62	128	215	218	161	83	32	11
	CDD18.3	33	0	0	0	0	0	2	15	12	4	0	0	0
	CDH23.3	79	0	0	0	0	1	7	39	24	8	1	0	0
	CDH26.7	15	0	0	0	0	0	0	9	5	1	0	0	0
Wind	WSAvg	7.3	9.2	8.3	7.7	6.2	6.2	5.7	5.7	6.3	6.8	7.6	8.7	9.0
Precipitation	PrecAvg	1132	134	110	98	55	46	64	73	85	97	111	129	131
	PrecMax	1426	226	196	173	91	75	108	108	157	151	187	190	295
	PrecMin	834	46	56	40	30	21	34	33	28	45	39	69	65
	PrecStd	142	49	39	30	17	13	18	21	25	27	36	31	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.6	15.1	16.4	18.7	21.3	24.4	27.7	26.3	24.2	21.2	19.0	16.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	11.5	11.7	12.2	15.1	17.4	19.6	23.4	22.3	21.3	17.2	14.4	12.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	10.3	10.1	10.6	13.0	15.3	17.5	21.1	20.4	18.7	15.2	13.2	11.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	9.6	9.2	9.7	11.5	13.9	16.3	19.3	18.9	17.2	14.4	12.6	10.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.6	3.8	4.3	5.2	5.9	5.5	6.2	5.2	4.8	4.1	3.5	4.0
		MCDBR	5.5	6.0	6.3	8.5	8.6	7.9	9.7	8.2	8.1	6.7	5.5	5.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.329	0.347	0.367	0.391	0.376	0.380	0.387	0.383	0.369	0.351	0.330	0.308	
	taud	2.207	2.295	2.321	2.293	2.412	2.425	2.416	2.434	2.455	2.387	2.257	2.171	
	Ebn at Noon	517	689	781	820	861	861	845	823	778	680	514	426	
	Edh at Noon	54	75	94	112	106	106	105	97	82	68	51	42	
All-Sky Solar Radiation	RadAvg	0.40	1.02	2.30	3.98	5.51	5.44	5.11	4.21	2.80	1.41	0.54	0.27	
	RadStd	0.04	0.13	0.18	0.31	0.31	0.32	0.36	0.48	0.29	0.29	0.10	0.05	0.03

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page