

SOUTH NOMAD BUOY 46036, Canada

WMO: 992930

Lat: 48.350N

Lon: 133.940W

Elev: 10

StdP: 14.69

Time Zone: -9.00 (W09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	37.6	38.9	N/A	N/A	N/A	N/A	N/A	N/A	41.9	43.2	37.8	44.8	18.5	280	0.766

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.3	63.3	N/A	62.5	N/A	61.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	15.0	220

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
36.6	32.8	30.1	35.2	63.7	2.8	2.1	33.3	65.1	31.6	66.4	30.1	67.5	28.1	69.0		
			DB	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.3	46.1	44.7	43.9	45.1	47.8	51.4	55.9	59.1	58.2	54.7	49.7	46.7
	DBStd	5.86	3.12	2.62	2.66	2.17	2.28	2.50	2.42	2.03	2.03	2.98	3.27	2.91
	HDD50	847	123	149	188	148	77	11	0	0	0	1	43	107
	HDD65	5357	585	569	653	598	534	407	281	183	203	319	458	567
	CDD50	963	3	0	0	0	7	54	184	282	247	147	34	5
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.4	18.0	17.8	16.9	15.2	13.0	12.1	11.9	12.4	13.5	16.6	18.6	18.8
Precipitation	PrecAvg	48.6	6.4	4.6	3.8	3.1	2.4	2.4	1.9	2.0	3.3	5.8	6.5	6.3
	PrecMax	56.1	9.5	7.1	7.5	5.1	4.1	4.4	4.1	4.8	6.3	10.7	9.2	10.7
	PrecMin	38.2	2.9	1.9	1.8	1.9	0.6	1.0	0.2	0.0	0.5	3.1	3.7	2.9
	PrecStd	4.1	1.7	1.3	1.2	0.8	0.9	0.9	0.9	1.2	1.1	2.1	1.6	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	49.9	50.2	50.9	54.7	59.9	62.7	64.3	64.1	64.4	59.1	55.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	52.6	49.1	49.0	49.4	53.4	58.4	60.9	63.5	62.8	61.6	56.8	53.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	51.1	48.5	48.3	48.6	52.3	56.3	60.0	62.9	61.9	60.3	55.3	51.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	50.1	48.0	47.5	48.1	51.1	54.8	59.2	62.1	61.2	59.0	54.1	50.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.2	3.1	3.4	2.6	2.2	2.2	2.2	2.3	2.6	3.1	3.7	3.8
		MCDBR	3.1	3.0	3.6	2.8	2.6	2.5	2.5	2.7	3.1	3.6	3.9	4.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.347	0.344	0.379	0.414	0.412	0.382	0.380	0.389	0.391	0.372	0.352	0.333	
	taud	2.345	2.427	2.315	2.211	2.272	2.433	2.485	2.466	2.408	2.376	2.336	2.354	
	Ebn at Noon	223	257	264	265	270	279	278	271	257	240	217	211	
	Edh at Noon	23	26	34	42	41	35	33	32	31	27	23	20	
All-Sky Solar Radiation	RadAvg	294	552	925	1346	1551	1597	1480	1353	1093	671	362	252	
	RadStd	30	54	85	96	115	116	113	79	73	52	28	23	

Historical Trends

	DBAvg	Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
(a)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(b)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page