

SOUTH NOMAD BUOY 46036, Canada

WMO: 992930

Lat: 48.350N

Lon: 133.940W

Elev: 3

StdP: 101.29

Time Zone: -9.00 (W09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	3.1	3.9	N/A	N/A	N/A	N/A	N/A	N/A	18.7	6.2	16.9	7.1	8.3	280	0.766

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.3	17.4	N/A	16.9	N/A	16.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
16.4	14.7	13.4	DB	1.8	17.6	1.5	1.1	0.7	18.4	-0.2	19.1	-1.1	19.7	-2.2	20.6	20.6
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	7.9	7.1	6.6	7.3	8.8	10.8	13.3	15.1	14.6	12.6	9.8	8.2
	DBStd	3.25	1.74	1.46	1.48	1.20	1.27	1.39	1.35	1.13	1.13	1.65	1.82	1.62
	HDD10.0	471	68	83	104	82	43	6	0	0	0	1	24	59
	HDD18.3	2976	325	316	363	332	297	226	156	102	113	177	254	315
	CDD10.0	535	2	0	0	0	4	30	102	157	137	82	19	3
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.9	8.1	8.0	7.6	6.8	5.8	5.4	5.3	5.5	6.0	7.4	8.3	8.4
Precipitation	PrecAvg	1234	162	118	97	80	61	61	49	50	83	148	166	159
	PrecMax	1426	242	181	190	129	103	112	105	123	161	273	233	272
	PrecMin	971	73	49	45	49	15	25	5	1	13	78	94	74
	PrecStd	105	42	32	31	21	22	22	23	31	29	53	40	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	10.0	10.1	10.5	12.6	15.5	17.0	18.0	17.8	18.0	15.0	13.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	11.4	9.5	9.4	9.7	11.9	14.6	16.1	17.5	17.1	16.4	13.8	11.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	10.6	9.2	9.0	9.2	11.3	13.5	15.6	17.1	16.6	15.7	13.0	10.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	10.0	8.9	8.6	8.9	10.6	12.7	15.1	16.7	16.2	15.0	12.3	10.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.8	1.7	1.9	1.5	1.2	1.2	1.2	1.3	1.4	1.7	2.0	2.1
		MCDBR	1.7	1.6	2.0	1.6	1.5	1.4	1.4	1.5	1.7	2.0	2.2	2.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.347	0.344	0.379	0.414	0.412	0.382	0.380	0.389	0.391	0.372	0.352	0.333	
	taud	2.345	2.427	2.315	2.211	2.272	2.433	2.485	2.466	2.408	2.376	2.336	2.354	
	Ebn at Noon	702	809	831	834	851	880	877	853	811	758	685	665	
	Edh at Noon	73	83	108	132	129	110	103	101	98	86	72	64	
All-Sky Solar Radiation	RadAvg	0.93	1.74	2.92	4.24	4.89	5.04	4.67	4.26	3.44	2.12	1.14	0.80	
	RadStd	0.09	0.17	0.27	0.30	0.36	0.36	0.36	0.25	0.23	0.17	0.09	0.07	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page