

BIG CARLOS PASS, FL, USA

WMO: 994006

Lat: 26.404N

Lon: 81.881W

Elev: 10

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	45.8	49.5	N/A	N/A	N/A	N/A	N/A	N/A	24.8	53.1	23.1	53.1	12.7	10	0.399

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	90.8	N/A	89.3	N/A	88.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.1	18.8	17.0	40.5	94.0	5.4	0.9	36.6	94.6	33.5	95.1	30.4	95.6	26.5	96.2		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.2	64.8	66.1	69.1	74.4	78.6	81.9	82.8	83.5	82.5	78.4	71.4	68.3
	DBStd	8.09	7.18	6.32	5.48	3.55	2.72	2.25	1.85	1.60	1.80	4.17	5.52	6.73
	HDD50	9	6	1	0	0	0	0	0	0	0	0	0	2
	HDD65	248	92	60	29	2	0	0	0	0	0	2	14	49
	CDD50	9203	464	450	591	732	888	956	1017	1038	974	882	641	570
	CDD65	3966	85	89	155	283	423	506	552	573	524	418	206	152
	CDH74	35990	163	154	496	1694	3727	5625	6386	6844	5622	3750	1031	498
	CDH80	11077	5	3	26	183	842	1942	2380	2658	1916	972	125	25
Wind	WSAvg	8.9	9.4	9.1	9.7	9.6	8.8	8.4	7.5	7.7	8.0	9.2	9.8	9.1
Precipitation	PrecAvg	49.4	1.8	1.7	1.7	2.2	3.1	8.3	8.1	8.1	8.1	3.6	1.4	1.4
	PrecMax	67.7	7.8	5.9	6.0	6.5	8.9	19.1	13.3	13.5	17.2	15.3	5.8	6.8
	PrecMin	33.4	0.1	0.0	0.0	0.4	0.6	3.7	3.0	5.1	5.0	0.4	0.0	0.0
	PrecStd	10.2	2.0	1.3	1.4	1.4	1.7	3.4	2.5	2.0	3.0	3.0	1.5	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.4	80.2	82.7	86.1	89.7	92.1	92.3	92.5	91.4	89.3	85.8	82.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	77.8	77.5	80.4	83.7	87.4	89.3	89.9	90.4	89.6	87.5	83.2	80.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	75.7	75.9	78.3	82.0	85.5	87.9	88.4	88.9	88.5	86.1	81.4	78.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	74.0	74.4	76.9	80.6	84.0	86.8	87.3	87.8	87.3	84.7	79.5	77.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	13.0	11.9	12.0	10.8	10.3	9.4	9.6	9.6	10.4	10.9	12.4	12.1
		MCDBR	13.3	11.7	13.5	12.9	12.7	11.5	11.2	11.1	11.8	11.8	12.2	12.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.351	0.367	0.379	0.393	0.420	0.443	0.459	0.448	0.421	0.400	0.364	0.354	
	taud	2.525	2.487	2.440	2.376	2.355	2.367	2.315	2.375	2.432	2.459	2.506	2.539	
	Ebn at Noon	286	289	291	287	278	269	265	268	274	274	279	279	
	Edh at Noon	29	33	36	39	40	39	41	39	36	33	30	28	
All-Sky Solar Radiation	RadAvg	1185	1455	1769	2050	2106	1899	1865	1798	1618	1510	1282	1098	
	RadStd	85	89	111	87	142	169	120	85	103	86	69	76	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	+0.76	+1.60	N/A	N/A	N/A	N/A	-2	-45	+277	+211

Nomenclature: See separate page