

CRESCENT CITY HARBOR, CA, USA

WMO: 994012

Lat: 41.7460N

Lon: 124.1840W

Elev: 16

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	35.0	37.0	N/A	N/A	N/A	N/A	N/A	N/A	36.3	52.5	32.6	51.3	5.0	50	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.2	67.5	N/A	65.1	N/A	63.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.1	24.8	20.7	DB	32.0	75.5	2.3	5.9	30.3	79.8	29.0	83.3	27.7	86.6	26.0	90.9	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	49.6	47.8	48.5	49.4	51.7	54.7	55.8	57.0	56.8	54.7	51.2	48.2	(6)	
	DBStd	5.09	4.28	5.09	3.82	3.54	2.89	2.47	2.66	2.76	3.63	4.16	4.35	5.36	(7)	
	HDD50	438	59	93	75	50	13	0	0	0	0	10	38	100	(8)	
	HDD65	4696	476	481	513	467	414	309	287	250	245	319	414	521	(9)	
	CDD50	1224	48	33	28	33	65	142	179	215	206	156	74	45	(10)	
	CDD65	1	0	0	0	0	1	0	0	0	0	0	0	0	(11)	
	CDH74	17	0	0	0	1	15	0	0	0	0	1	0	0	(12)	
(13)	CDH80	6	0	0	0	0	6	0	0	0	0	0	0	0	(13)	
(14)	Wind	WSAvg	7.8	7.7	8.9	9.8	8.5	8.0	8.1	6.4	5.8	6.3	7.0	7.8	9.8	(14)
(15) Precipitation	PrecAvg	74.4	11.8	9.3	9.2	6.9	3.8	1.7	0.3	0.6	1.1	4.6	10.1	15.0	(15)	
	PrecMax	112.2	23.1	21.1	19.1	15.6	8.2	5.9	1.5	2.0	5.4	10.2	25.0	34.4	(16)	
	PrecMin	44.5	4.0	2.6	3.6	1.8	0.0	0.1	0.0	0.0	0.0	0.3	3.1	4.5	(17)	
	PrecStd	17.6	5.6	5.0	4.3	3.8	2.2	1.5	0.4	0.6	1.3	2.8	5.2	7.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.6	62.5	60.5	67.8	67.8	67.3	67.3	67.6	69.4	69.6	66.0	63.5	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	60.0	59.5	57.6	58.9	60.2	62.0	63.7	65.1	66.3	64.9	61.3	60.4	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	57.4	57.0	55.4	56.1	57.4	60.1	61.4	63.1	64.0	62.6	59.2	58.2	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
(25) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	55.7	54.9	53.8	54.4	55.8	59.0	59.6	61.3	62.2	60.6	57.6	56.0	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
(31) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	9.6	9.4	9.2	7.8	7.7	5.8	6.2	8.7	9.7	10.2	9.7	(35)	
		MCDBR	12.7	11.7	10.7	12.3	10.7	10.0	9.4	10.3	12.6	13.1	12.3	10.0	(36)	
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)	
		MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.321	0.321	0.327	0.352	0.357	0.348	0.354	0.350	0.341	0.330	0.315	0.320	(40)	
		taud	2.559	2.568	2.573	2.463	2.491	2.524	2.513	2.536	2.532	2.587	2.603	2.568	(41)	
	Ebn at Noon	Ebn at Noon	265	284	294	292	291	293	290	289	285	276	266	255	(42)	
		Edh at Noon	22	25	28	34	34	33	33	31	29	25	21	21	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	557	815	1190	1648	2053	2279	2289	1952	1582	1049	630	458	(44)	
	RadStd	RadStd	87	116	125	151	126	136	110	113	92	97	74	84	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (16 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+4

Nomenclature: See separate page