

CRESCENT CITY HARBOR, CA, USA

WMO: 994012

Lat: 41.7460N

Lon: 124.1840W

Elev: 5

StdP: 101.27

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.7	2.8	N/A	N/A	N/A	N/A	N/A	N/A	16.2	11.4	14.6	10.7	2.3	50	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.4	19.7	N/A	18.4	N/A	17.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.0	11.1	9.3	DB	0.0	24.2	1.3	3.3	-0.9	26.5	-1.7	28.5	-2.4	30.3	-3.4	32.7	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	9.8	8.8	9.1	9.7	10.9	12.6	13.2	13.9	13.8	12.6	10.7	9.0
	DBStd	2.83	2.38	2.83	2.12	1.97	1.60	1.37	1.48	1.54	2.02	2.31	2.42	2.98
	HDD10.0	243	33	52	42	28	7	0	0	0	0	6	21	56
	HDD18.3	2609	264	267	285	259	230	172	159	139	136	177	230	289
	CDD10.0	680	27	18	16	18	36	79	99	119	114	87	41	25
	CDD18.3	1	0	0	0	0	1	0	0	0	0	0	0	0
	CDH23.3	9	0	0	0	1	8	0	0	0	0	1	0	0
CDH26.7	3	0	0	0	0	3	0	0	0	0	0	0	0	
Wind	WSAvg	3.5	3.4	4.0	4.4	3.8	3.6	3.6	2.9	2.6	2.8	3.1	3.5	4.4
Precipitation	PrecAvg	1889	300	237	234	174	97	44	8	14	27	116	257	380
	PrecMax	2849	588	536	486	396	209	150	39	52	136	258	634	873
	PrecMin	1130	101	66	92	45	0	3	0	0	0	7	78	114
	PrecStd	446	143	126	108	97	57	38	10	15	32	70	132	190
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.1	16.9	15.8	19.9	19.9	19.6	19.6	19.8	20.8	20.9	18.9	17.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	15.5	15.3	14.2	15.0	15.6	16.7	17.6	18.4	19.0	18.3	16.3	15.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	14.1	13.9	13.0	13.4	14.1	15.6	16.3	17.3	17.8	17.0	15.1	14.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	13.2	12.7	12.1	12.4	13.2	15.0	15.4	16.3	16.8	15.9	14.2	13.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.7	5.3	5.2	5.1	4.3	4.3	3.2	3.4	4.8	5.4	5.7	5.4
		MCDBR	7.0	6.5	6.0	6.9	5.9	5.5	5.2	5.7	7.0	7.3	6.8	5.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.321	0.321	0.327	0.352	0.357	0.348	0.354	0.350	0.341	0.330	0.315	0.320	
	taud	2.559	2.568	2.573	2.463	2.491	2.524	2.513	2.536	2.532	2.587	2.603	2.568	
	Ebn at Noon	835	894	926	919	917	923	914	910	897	870	837	804	
	Edh at Noon	70	80	89	107	106	103	103	98	92	78	67	65	
All-Sky Solar Radiation	RadAvg	1.75	2.57	3.75	5.19	6.47	7.19	7.21	6.16	4.99	3.31	1.99	1.44	
	RadStd	0.27	0.37	0.39	0.47	0.40	0.43	0.35	0.36	0.29	0.30	0.23	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+2

Nomenclature: See separate page