

PORT ORFORD, OR, USA

WMO: 994031

Lat: 42.7390N

Lon: 124.4980W

Elev: 26

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	36.1	38.2	N/A	N/A	N/A	N/A	N/A	N/A	40.3	51.3	36.2	52.4	6.0	0	0.653

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	70.6	N/A	68.3	N/A	66.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	13.8	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.8	30.9	25.9	DB	31.8	78.8	3.0	5.1	29.6	82.5	27.9	85.5	26.2	88.3	24.0	92.0	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.0	48.9	48.1	48.2	49.2	53.0	56.0	58.9	59.4	58.1	55.4	51.3	48.4
	DBStd	5.79	4.39	4.58	3.65	3.63	3.70	3.04	3.35	3.49	4.02	3.83	4.04	4.87
	HDD50	419	72	82	79	52	8	1	1	0	2	3	31	88
	HDD65	4406	498	474	522	473	374	269	191	174	207	300	411	513
	CDD50	1497	39	28	22	30	101	182	276	292	246	170	71	40
	CDD65	9	0	0	0	1	2	1	0	1	2	2	0	0
	CDH74	33	0	0	0	3	15	2	1	1	5	6	0	0
	CDH80	4	0	0	0	0	4	0	0	0	0	0	0	0
Wind	WSAvg	10.9	11.3	10.5	12.7	10.4	10.4	11.2	11.7	10.4	9.3	9.9	10.8	12.5
Precipitation	PrecAvg	81.9	13.8	9.8	9.5	7.6	4.3	2.2	0.4	0.7	1.3	5.3	11.5	15.0
	PrecMax	131.3	25.6	20.5	16.0	17.3	9.4	7.6	2.1	3.7	6.5	11.3	25.0	29.8
	PrecMin	60.2	5.4	3.8	3.0	2.9	0.0	0.2	0.0	0.0	0.0	0.2	3.1	5.4
	PrecStd	17.7	6.0	4.9	3.7	3.9	2.4	1.7	0.5	1.0	1.5	2.9	5.6	5.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.9	64.0	60.2	71.0	74.3	70.2	72.2	71.1	72.3	72.7	65.3	61.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	59.0	58.9	57.0	60.0	64.7	65.6	68.2	68.9	69.0	66.4	60.6	59.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	56.6	56.3	55.0	56.1	60.4	63.0	66.3	67.1	66.5	62.8	58.5	57.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	54.7	54.5	53.3	53.8	58.5	61.2	64.9	65.4	64.2	60.4	57.1	55.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	8.2	8.5	7.9	8.3	8.7	8.6	9.5	9.4	9.6	8.6	8.2	8.3
		MCDBR	11.2	11.3	10.8	13.0	13.4	12.4	12.1	12.1	13.7	13.1	10.5	9.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.320	0.322	0.329	0.356	0.361	0.351	0.345	0.348	0.339	0.333	0.320	0.322	
	taud	2.563	2.564	2.563	2.445	2.473	2.511	2.535	2.547	2.547	2.577	2.585	2.555	
	Ebn at Noon	262	281	292	290	289	292	292	289	284	273	260	250	
	Edh at Noon	22	25	28	34	34	33	32	30	29	24	21	20	
All-Sky Solar Radiation	RadAvg	509	764	1123	1591	2013	2214	2319	1950	1548	980	572	417	
	RadStd	77	99	123	130	115	135	93	117	89	92	71	75	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+4

Nomenclature: See separate page