

PORT CHICAGO, CA, USA

WMO: 994034

Lat: 38.056N

Lon: 122.039W

Elev: 7

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 37.2	(c) 39.1	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 23.2	(k) 47.8	(l) 20.2	(m) 50.6	(n) 5.4	(o) 190	(p) 0.571

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 9	(b) 19.6	(c) 89.2	(d) N/A	(e) 85.5	(f) N/A	(g) 82.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 9.5	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 27.6	(b) 24.2	(c) 21.4	(d) DB	(e) 33.1	(f) 96.5	(g) 2.8	(h) 3.3	(i) 31.1	(j) 98.9	(k) 29.4	(l) 100.9	(m) 27.9	(n) 102.7	(o) 25.8	(p) 105.2	(q) N/A
(4) 27.6	(5) 24.2	(6) 21.4	(7) WB	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A	(19) N/A	(20) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.7	49.4	51.9	54.9	58.1	61.6	66.5	68.4	68.6	68.4	63.6	55.7	49.2
	DBStd	8.62	4.22	4.61	4.70	5.41	5.10	5.19	4.50	4.00	4.86	4.85	5.04	4.83
	HDD50	186	62	30	9	1	0	0	0	0	0	0	11	73
	HDD65	2449	484	366	312	221	134	38	11	9	17	87	281	489
	CDD50	3740	43	84	163	243	359	496	571	576	553	421	182	49
	CDD65	527	0	0	1	13	28	84	118	120	119	43	1	0
	CDH74	3911	0	0	9	120	258	753	888	758	844	276	5	0
	CDH80	1179	0	0	0	21	70	245	288	212	287	56	0	0
(14) Wind	WSAvg	10.5	7.0	7.7	8.5	10.8	12.7	13.8	16.2	15.1	11.8	8.5	6.9	6.5
(15) Precipitation	PrecAvg	21.2	4.5	4.1	2.4	1.4	0.9	0.2	0.0	0.0	0.0	1.1	2.1	4.4
	PrecMax	34.4	11.5	12.6	9.6	4.6	3.1	1.2	0.0	0.6	0.2	4.5	6.5	11.0
	PrecMin	11.1	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4
	PrecStd	6.3	3.2	2.8	2.5	1.1	0.9	0.3	0.0	0.1	0.1	1.1	1.7	3.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.3	70.7	75.1	82.7	87.3	92.3	93.6	91.6	91.5	86.3	74.4	64.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	61.6	66.5	70.7	77.6	81.1	86.8	86.8	86.0	87.6	80.3	70.3	60.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	58.7	62.6	66.7	72.5	75.7	82.4	82.5	81.7	83.1	76.9	66.9	58.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	56.4	59.9	63.7	67.9	71.6	78.1	78.6	78.1	78.6	73.1	63.8	56.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	13.5	14.9	15.9	16.6	19.3	19.7	19.3	19.6	17.4	14.1	11.2
		MCDBR	16.7	18.4	20.3	24.0	24.1	26.6	26.0	24.6	27.1	23.5	18.7	13.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.323	0.325	0.339	0.359	0.364	0.361	0.365	0.349	0.348	0.332	0.324	0.326
	taud		2.534	2.529	2.475	2.395	2.407	2.420	2.406	2.443	2.446	2.526	2.528	2.525
	Ebn at Noon		273	288	293	292	291	290	288	291	286	281	270	263
	Edh at Noon		24	28	32	37	37	37	37	35	33	27	24	23
(44) All-Sky Solar Radiation	RadAvg		731	1042	1478	1943	2299	2542	2472	2208	1829	1318	881	646
	RadStd		115	131	143	161	140	104	73	75	63	85	59	100

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (47 neighbors)	+0.67	N/A	-2.07	N/A	N/A	N/A	N/A	N/A	-207	+239	N/A

Nomenclature: See separate page