

APPALACHICOLA HARBOR, FL, USA

WMO: 994045

Lat: 29.7245N

Lon: 84.9804W

Elev: 7

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.5	37.4	N/A	N/A	N/A	N/A	N/A	N/A	21.3	49.6	18.9	47.7	8.1	10	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	90.7	N/A	89.2	N/A	87.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.9	16.4	14.0	DB	28.4	93.4	4.0	2.2	25.6	95.0	23.2	96.2	21.0	97.4	18.1	99.0	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.2	53.2	56.5	61.6	68.4	75.2	81.0	82.0	82.3	79.2	71.5	61.0	57.2
	DBStd	11.83	8.33	7.50	6.62	4.96	4.00	2.75	2.36	2.45	3.19	5.89	6.94	7.34
	HDD50	125	67	26	4	0	0	0	0	0	0	0	7	21
	HDD65	1212	369	247	143	25	1	0	0	0	0	17	155	255
	CDD50	7117	165	208	363	552	782	930	992	1002	876	667	336	244
	CDD65	2730	2	9	37	128	318	480	527	537	426	219	34	13
	CDH74	25602	0	6	36	309	2277	5285	6032	6149	4108	1325	73	2
	CDH80	7718	0	0	1	14	365	1699	2152	2205	1095	187	0	0
Wind	WSAvg	6.4	6.5	6.5	6.8	6.9	7.0	6.1	5.4	5.7	6.2	6.8	7.1	6.3
Precipitation	PrecAvg	54.7	4.2	3.9	4.6	2.6	2.5	5.0	6.9	7.5	7.1	3.9	3.2	3.5
	PrecMax	88.3	20.8	9.9	13.0	12.1	12.1	16.4	18.1	18.9	18.8	20.5	7.5	9.7
	PrecMin	32.4	0.7	0.4	0.0	0.0	0.0	0.2	0.7	2.3	0.6	0.0	0.2	0.8
	PrecStd	13.2	3.3	2.3	3.0	2.8	2.3	3.9	4.3	3.9	4.7	3.9	2.0	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.2	74.4	77.6	82.1	87.8	93.5	92.3	92.2	90.1	88.3	79.1	73.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	68.5	70.4	74.8	78.8	85.6	90.2	90.4	90.1	87.5	83.8	76.9	71.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	66.6	68.8	73.0	77.2	83.7	88.3	89.0	88.7	86.2	81.9	73.7	69.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	64.7	66.7	71.2	75.6	82.0	86.9	87.4	87.2	85.0	80.1	71.5	67.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	13.3	12.3	12.4	11.5	11.3	10.2	10.2	9.6	10.2	13.0	14.6	12.7
		MCDBR	12.0	11.9	12.7	12.0	13.0	12.1	12.0	10.9	11.0	12.9	13.6	10.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.348	0.356	0.367	0.394	0.437	0.470	0.491	0.483	0.435	0.388	0.357	0.346	
	taud	2.506	2.495	2.465	2.381	2.296	2.266	2.220	2.252	2.362	2.474	2.495	2.533	
	Ebn at Noon	281	289	292	286	272	262	256	257	267	274	275	276	
	Edh at Noon	29	31	34	39	42	43	45	43	38	32	29	27	
All-Sky Solar Radiation	RadAvg	1010	1220	1630	1951	2163	1985	1860	1739	1606	1446	1135	904	
	RadStd	81	144	138	160	130	136	133	124	116	105	82	84	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	-175	+292	+180

Nomenclature: See separate page