

APPALACHICOLA HARBOR, FL, USA

WMO: 994045

Lat: 29.7245N

Lon: 84.9804W

Elev: 2

StdP: 101.30

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	3.0	N/A	N/A	N/A	N/A	N/A	N/A	9.5	9.8	8.5	8.7	3.6	10	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	32.6	N/A	31.8	N/A	31.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.3	6.2	-2.0	34.1	2.2	1.2	-3.6	35.0	-4.9	35.7	-6.1	36.4	-7.7	37.2		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.6	11.8	13.6	16.4	20.2	24.0	27.2	27.8	28.0	26.2	22.0	16.1	14.0
	DBStd	6.57	4.63	4.16	3.68	2.76	2.22	1.53	1.31	1.36	1.77	3.27	3.86	4.08
	HDD10.0	69	37	14	2	0	0	0	0	0	0	0	4	12
	HDD18.3	673	205	137	79	14	1	0	0	0	0	9	86	142
	CDD10.0	3954	92	116	202	307	434	517	551	557	487	371	187	136
	CDD18.3	1517	1	5	21	71	177	267	293	298	237	122	19	7
	CDH23.3	14223	0	3	20	172	1265	2936	3351	3416	2282	736	41	1
	CDH26.7	4288	0	0	1	8	203	944	1196	1225	608	104	0	0
Wind	WSAvg	2.9	2.9	2.9	3.0	3.1	3.1	2.7	2.4	2.6	2.8	3.1	3.2	2.8
Precipitation	PrecAvg	1389	106	98	117	66	64	128	176	191	180	98	82	88
	PrecMax	2242	528	251	329	308	308	416	459	479	477	521	191	246
	PrecMin	824	19	11	0	1	0	5	19	59	14	1	5	21
	PrecStd	335	83	59	77	70	59	100	110	100	120	99	50	50
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.8	23.6	25.3	27.8	31.0	34.2	33.5	33.5	32.3	31.3	26.2	22.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	20.3	21.3	23.8	26.0	29.8	32.3	32.4	32.3	30.8	28.8	24.9	21.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	19.2	20.5	22.8	25.1	28.7	31.3	31.7	31.5	30.1	27.7	23.2	20.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	18.2	19.3	21.8	24.2	27.8	30.5	30.8	30.7	29.4	26.7	22.0	19.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	7.4	6.8	6.9	6.4	6.3	5.7	5.7	5.3	5.6	7.2	8.1	7.1
		MCDBR	6.7	6.6	7.1	6.7	7.2	6.7	6.6	6.1	6.1	7.2	7.5	6.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.348	0.356	0.367	0.394	0.437	0.470	0.491	0.483	0.435	0.388	0.357	0.346	
	taud	2.506	2.495	2.465	2.381	2.296	2.266	2.220	2.252	2.362	2.474	2.495	2.533	
	Ebn at Noon	886	910	920	901	859	826	806	811	841	865	868	871	
	Edh at Noon	90	99	108	122	133	137	143	137	119	100	90	84	
All-Sky Solar Radiation	RadAvg	3.19	3.85	5.14	6.15	6.82	6.26	5.87	5.48	5.06	4.56	3.58	2.85	
	RadStd	0.25	0.46	0.44	0.51	0.41	0.43	0.42	0.39	0.36	0.33	0.26	0.26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	-97	+162	+100

Nomenclature: See separate page