

PENSACOLA HARBOR, FL, USA

WMO: 994047

Lat: 30.4035N

Lon: 87.2112W

Elev: 10

StdP: 14.69

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.1	35.3	N/A	N/A	N/A	N/A	N/A	N/A	18.7	58.8	16.7	54.1	7.0	0	0.346

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.3	92.7	N/A	91.1	N/A	89.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.4	13.9	12.2	DB	25.6	97.1	4.1	1.8	22.6	98.4	20.2	99.5	17.9	100.5	15.0	101.8	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.0	52.2	56.3	62.3	69.8	76.6	82.8	83.8	84.2	80.9	71.7	61.1	57.8
	DBStd	12.89	9.29	8.59	7.19	5.05	4.46	2.78	2.52	2.78	3.54	6.71	7.65	9.45
	HDD50	169	87	37	7	0	0	0	0	0	0	0	9	29
	HDD65	1259	400	259	134	19	2	0	0	0	0	23	160	262
	CDD50	7484	157	214	389	595	825	984	1048	1060	926	674	343	269
	CDD65	3098	5	15	51	163	362	534	583	595	476	232	44	38
	CDH74	31265	0	12	64	487	2812	6380	7183	7338	5001	1619	118	251
	CDH80	11494	0	0	4	18	541	2536	3023	3226	1756	306	9	75
(14) Wind	WSAvg	5.5	5.7	5.4	5.5	6.0	6.2	6.0	5.6	5.0	4.9	5.5	5.3	5.0
(15) Precipitation	PrecAvg	62.5	4.7	5.0	5.7	4.2	4.0	6.5	7.7	7.0	5.7	3.9	4.1	4.3
	PrecMax	87.3	18.8	11.7	13.0	24.4	10.3	21.1	20.4	14.1	19.7	14.8	13.3	9.6
	PrecMin	39.4	0.2	0.8	0.2	0.4	0.1	0.9	1.7	2.1	0.4	0.0	0.3	0.6
	PrecStd	13.1	3.3	2.5	3.1	4.1	2.7	4.5	4.1	3.0	4.1	3.6	2.9	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.1	75.9	79.2	82.3	89.5	93.8	94.5	94.9	93.2	88.7	81.7	87.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	68.8	72.1	75.5	79.9	86.7	91.5	91.9	92.6	90.4	85.4	78.0	81.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	67.1	69.7	73.4	78.3	84.7	89.6	90.2	91.0	88.8	83.4	74.9	74.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	65.3	67.7	71.5	76.9	83.0	88.2	88.8	89.5	87.2	81.4	72.4	69.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	14.2	13.6	13.2	11.4	10.8	10.9	10.5	11.3	12.7	14.7	15.9	14.3
		MCDBR	12.3	11.3	11.8	11.6	11.9	12.5	12.2	12.9	13.5	14.3	14.4	12.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.335	0.351	0.375	0.404	0.440	0.467	0.510	0.498	0.444	0.386	0.359	0.344
	taud		2.541	2.499	2.428	2.350	2.284	2.261	2.161	2.189	2.313	2.454	2.470	2.525
	Ebn at Noon		285	290	289	282	271	262	251	253	264	274	273	276
	Edh at Noon		27	31	36	40	43	43	48	46	39	32	29	27
(44) All-Sky Solar Radiation	RadAvg		980	1170	1584	1909	2123	2000	1880	1748	1643	1449	1113	862
	RadStd		75	156	125	153	111	157	128	132	97	139	98	81

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+279	+173

Nomenclature: See separate page