

PENSACOLA HARBOR, FL, USA

WMO: 994047

Lat: 30.4035N

Lon: 87.2112W

Elev: 3

StdP: 101.29

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.5	(c) 1.8	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 8.3	(k) 14.9	(l) 7.5	(m) 12.3	(n) 3.1	(o) 0	(p) 0.346

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 6.3	(c) 33.7	(d) N/A	(e) 32.9	(f) N/A	(g) 32.0	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 2.2	(p) 130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.3	(b) 6.2	(c) 5.4	(e) -3.6	(f) 36.2	(g) 2.3	(h) 1.0	(i) -5.2	(j) 36.9	(k) -6.5	(l) 37.5	(m) -7.8	(n) 38.0	(o) -9.5	(p) 38.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.1	11.2	13.5	16.8	21.0	24.8	28.2	28.8	29.0	27.1	22.1	16.2	14.3		
	DBStd	7.16	5.16	4.77	3.99	2.81	2.48	1.54	1.40	1.55	1.96	3.73	4.25	5.25		
	HDD10.0	94	48	21	4	0	0	0	0	0	0	0	5	16		
	HDD18.3	699	222	144	74	11	1	0	0	0	0	13	89	146		
	CDD10.0	4158	87	119	216	331	458	547	582	589	514	374	191	149		
	CDD18.3	1721	3	8	28	91	201	297	324	331	264	129	24	21		
	CDH23.3	17369	0	7	36	271	1562	3544	3991	4077	2778	899	66	139		
	CDH26.7	6386	0	0	2	10	301	1409	1679	1792	976	170	5	42		
(14) Wind	WSAvg	2.5	2.5	2.4	2.5	2.7	2.8	2.7	2.5	2.2	2.2	2.5	2.4	2.2		
(15) Precipitation	PrecAvg	1587	120	128	146	107	101	166	196	178	146	99	104	108		
	PrecMax	2218	477	296	329	621	262	537	517	359	501	377	337	243		
	PrecMin	1000	5	20	6	10	2	22	43	53	10	0	8	14		
	PrecStd	333	84	64	78	105	68	114	105	77	104	91	74	47		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.7	24.4	26.2	27.9	31.9	34.3	34.7	35.0	34.0	31.5	27.6	30.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	20.5	22.3	24.2	26.6	30.4	33.0	33.3	33.7	32.4	29.7	25.5	27.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	19.5	21.0	23.0	25.7	29.3	32.0	32.3	32.8	31.6	28.5	23.8	23.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	18.5	19.8	21.9	24.9	28.3	31.2	31.6	31.9	30.7	27.5	22.5	21.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		7.9	7.6	7.3	6.4	6.0	6.1	5.8	6.3	7.0	8.2	8.8	7.9		
	5% DB	MCDBR	6.8	6.3	6.6	6.5	6.6	6.9	6.8	7.2	7.5	7.9	8.0	7.0		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.335	0.351	0.375	0.404	0.440	0.467	0.510	0.498	0.444	0.386	0.359	0.344		
	taud		2.541	2.499	2.428	2.350	2.284	2.261	2.161	2.189	2.313	2.454	2.470	2.525		
	Ebn at Noon		899	913	910	890	855	827	791	797	831	863	861	869		
	Edh at Noon		86	98	112	125	135	137	151	146	124	101	92	84		
(44) All-Sky Solar Radiation	RadAvg		3.09	3.69	4.99	6.02	6.69	6.30	5.93	5.51	5.18	4.57	3.51	2.72		
	RadStd		0.24	0.49	0.39	0.48	0.35	0.49	0.40	0.41	0.31	0.44	0.31	0.26		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+155	+96

Nomenclature: See separate page