

LAKE WORTH PIER, FL, USA

WMO: 994050

Lat: 26.6130N

Lon: 80.0340W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 8.7	(c) 10.9	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 14.2	(k) 20.7	(l) 12.8	(m) 20.7	(n) 5.2	(o) 310	(p) 0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 3.7	(c) 30.6	(d) N/A	(e) 30.1	(f) N/A	(g) 29.7	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.8	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.2	(b) 11.7	(c) 10.4	(e) 5.3	(f) 32.8	(g) 2.4	(h) 0.8	(i) 3.6	(j) 33.4	(k) 2.2	(l) 33.8	(m) 0.9	(n) 34.3	(o) -0.8	(p) 34.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.2	19.4	20.8	21.7	23.6	25.4	26.8	27.6	27.9	27.5	26.0	22.7	21.1
	DBStd	3.78	3.83	3.46	2.78	1.96	1.19	1.10	1.00	0.96	1.02	1.83	3.04	3.90
	HDD10.0	3	1	1	0	0	0	0	0	0	0	0	0	1
	HDD18.3	94	36	18	9	1	0	0	0	0	0	1	6	23
	CDD10.0	5196	293	304	362	407	477	504	547	554	524	497	381	346
	CDD18.3	2246	70	88	113	159	219	254	288	296	274	239	137	110
	CDH23.3	19534	142	214	309	808	1728	2649	3342	3576	3147	2338	832	449
	CDH26.7	4303	1	7	14	19	108	558	1043	1229	919	366	36	2
(14) Wind	WSAvg	5.0	5.4	5.3	6.1	5.9	5.1	4.1	3.7	4.2	4.7	5.0	5.3	5.7
(15) Precipitation	PrecAvg	1531	73	60	90	93	115	216	154	204	224	151	70	80
	PrecMax	2106	232	168	237	234	341	479	262	487	604	345	279	245
	PrecMin	1108	7	3	15	17	27	59	55	82	99	34	7	27
	PrecStd	221	73	43	63	55	90	109	51	93	97	96	66	58
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	27.8	28.7	29.0	30.5	31.0	31.0	31.8	31.3	30.1	28.0	26.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	25.3	25.7	26.2	26.8	28.3	29.7	30.1	30.6	30.0	29.1	27.7	26.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	24.9	25.1	25.4	26.3	27.6	29.1	29.7	30.1	29.6	28.5	27.2	25.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	24.2	24.6	24.9	25.8	27.2	28.6	29.4	29.7	29.2	28.2	26.6	25.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	4.6	4.2	3.4	2.9	3.4	3.3	3.7	3.2	3.1	4.5	4.6
		MCDBR	4.1	4.2	4.9	4.1	4.3	4.2	3.7	4.4	3.6	3.4	3.4	3.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.360	0.370	0.386	0.402	0.431	0.460	0.473	0.463	0.432	0.413	0.380	0.369
	taud		2.520	2.509	2.447	2.389	2.345	2.327	2.285	2.337	2.428	2.439	2.484	2.517
	Ebn at Noon		889	908	909	898	865	835	824	832	853	850	860	864
	Edh at Noon		92	100	112	122	128	129	134	127	113	106	95	90
(44) All-Sky Solar Radiation	RadAvg		3.55	4.35	5.32	6.12	6.25	5.79	5.83	5.62	4.92	4.51	3.79	3.27
	RadStd		0.24	0.28	0.31	0.28	0.53	0.54	0.33	0.32	0.27	0.33	0.20	0.23

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (26 neighbors)	+0.39	+0.85	N/A	N/A	N/A	N/A	N/A	-21	+138	+112

Nomenclature: See separate page