

MT DESERT ROCK, ME, USA

WMO: 994060

Lat: 43.9690N

Lon: 68.1280W

Elev: 30

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.8	11.7	-2.7	4.8	12.8	0.6	5.7	15.1	50.7	37.6	47.4	31.4	23.4	320	0.885

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.3	67.3	64.1	65.7	63.3	64.4	62.5	65.4	65.9	64.1	64.5	62.9	63.3	12.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	93.3	65.7	63.9	89.0	64.3	62.6	85.0	63.0	30.3	65.9	29.2	64.2	28.4	63.6	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 48.6	41.7	36.5	DB	0.8	72.5	4.3	3.1	-2.3	74.8	-4.8	76.6	-7.2	78.3	-10.3	80.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.4	28.9	29.3	33.7	40.8	47.1	53.7	59.8	61.2	57.7	51.3	44.2	35.7	(6)	
	DBStd	12.50	9.77	8.12	6.17	3.82	3.37	3.43	2.86	2.49	2.91	4.29	6.36	7.99	(7)	
	HDD50	2796	654	581	505	275	103	8	0	0	0	37	188	445	(8)	
	HDD65	7171	1119	1001	970	725	554	340	164	121	218	424	625	910	(9)	
	CDD50	1103	0	0	0	0	14	118	302	346	232	78	13	0	(10)	
	CDD65	3	0	0	0	0	0	0	1	2	0	0	0	0	(11)	
	CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	17.2	20.2	20.8	19.0	18.1	16.0	13.5	13.2	14.1	14.6	18.5	19.3	19.5	(14)	
(15) Precipitation	PrecAvg	60.8	5.7	4.8	5.3	4.9	4.4	4.9	3.8	3.8	4.7	5.9	5.7	7.0	(15)	
	PrecMax	82.2	10.5	10.3	8.9	9.8	8.7	10.0	7.6	9.2	9.9	16.5	9.8	11.6	(16)	
	PrecMin	37.9	1.2	2.0	1.6	0.6	0.8	2.4	1.8	1.1	1.6	1.5	2.2	2.6	(17)	
	PrecStd	8.6	2.1	1.6	1.9	2.0	1.9	2.0	1.5	2.0	2.1	2.9	1.7	2.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.7	46.4	48.0	51.3	59.8	66.0	70.0	70.3	66.4	61.4	56.7	53.2	(19)	
		MCWB	49.6	45.8	46.5	47.7	53.6	59.2	64.9	66.0	63.2	55.9	55.8	52.3	(20)	
	2%	DB	47.9	43.6	44.8	48.5	55.6	61.6	66.9	67.7	64.4	59.3	54.9	50.6	(21)	
		MCWB	46.7	42.5	43.7	46.0	51.0	57.7	63.0	65.4	61.8	57.0	53.5	49.8	(22)	
	5%	DB	45.5	42.0	42.9	46.9	53.0	59.7	65.1	66.2	62.9	57.9	53.5	49.1	(23)	
		MCWB	44.0	40.7	41.5	45.0	49.5	56.7	63.1	64.3	61.0	56.2	52.0	47.8	(24)	
	10%	DB	42.6	40.2	41.2	45.4	51.3	58.1	63.8	65.0	61.6	56.6	52.5	47.5	(25)	
		MCWB	40.3	38.4	39.4	43.6	48.6	55.7	62.5	63.3	60.2	55.2	51.0	45.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	46.5	48.1	50.4	56.6	62.6	66.8	67.5	65.7	59.2	56.7	52.9	(27)	
		MCDB	50.1	46.6	48.1	50.9	58.6	63.0	68.1	68.1	66.8	59.8	56.8	53.2	(28)	
	2%	WB	47.2	43.8	45.2	47.6	52.5	59.3	64.8	65.9	63.4	57.5	54.0	50.6	(29)	
		MCDB	47.6	44.1	45.4	47.7	54.0	59.8	65.6	66.2	64.1	58.1	54.2	50.8	(30)	
	5%	WB	44.4	41.9	43.1	46.1	50.5	57.4	63.6	64.5	62.1	56.4	52.7	49.0	(31)	
		MCDB	45.0	42.4	43.6	46.4	51.7	58.1	63.9	64.8	62.6	56.9	53.0	49.2	(32)	
	10%	WB	40.9	39.7	41.0	44.6	49.1	55.9	62.2	63.4	60.9	55.2	51.5	46.5	(33)	
		MCDB	42.4	40.5	41.8	45.1	50.1	56.5	62.7	63.8	61.3	55.7	52.0	47.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	10.3	8.0	5.5	5.7	6.4	6.7	6.3	5.1	5.3	7.1	9.8	(35)	
		MCDBR	11.9	11.4	8.2	6.9	8.7	9.2	9.1	7.8	6.8	5.6	7.1	10.5	(36)	
		MCWBR	12.5	12.9	9.8	5.9	6.7	7.2	7.6	6.3	6.0	6.5	7.5	12.7	(37)	
	5% WB	MCDBR	10.4	11.0	9.2	6.2	8.8	8.3	8.6	7.0	6.0	5.6	5.6	11.5	(38)	
		MCWBR	12.9	12.9	10.6	5.7	6.9	7.3	7.5	6.4	5.6	7.0	7.4	13.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.306	0.313	0.332	0.359	0.382	0.419	0.436	0.411	0.367	0.340	0.323	0.306	(40)	
	taud		2.494	2.496	2.476	2.427	2.408	2.329	2.300	2.358	2.456	2.524	2.533	2.510	(41)	
	Ebn at Noon		262	281	288	287	282	271	265	267	272	267	253	250	(42)	
	Edh at Noon		22	26	30	35	36	40	40	37	31	25	22	20	(43)	
(44) All-Sky Solar Radiation	RadAvg		473	759	1156	1474	1675	1814	1886	1691	1373	889	531	383	(44)	
	RadStd		40	63	82	152	200	157	135	91	82	83	51	42	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+112	N/A

Nomenclature: See separate page