

FIVE FINGER LIGHT, AK, USA

WMO: 994080

Lat: 57.2704N

Lon: 133.6315W

Elev: 22

StdP: 14.68

Time Zone: -9.00 (NAK)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.5	21.3	N/A	N/A	N/A	N/A	N/A	N/A	56.5	31.0	48.0	33.3	28.3	340	0.781

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	65.3	N/A	62.5	N/A	60.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
43.9	37.1	32.8	14.9	70.6	3.7	2.8	12.2	72.6	10.0	74.2	7.9	75.8	5.2	77.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.7	35.2	35.4	37.4	42.8	48.6	53.1	55.6	55.3	51.3	45.4	39.2	36.1
	DBStd	8.81	6.63	5.84	5.12	3.34	3.69	3.31	2.85	2.98	2.61	3.41	5.13	5.51
	HDD50	2467	459	408	391	217	71	5	0	0	16	144	325	431
	HDD65	7420	924	828	856	666	509	356	292	300	412	606	775	896
	CDD50	524	0	0	0	1	28	99	173	166	54	3	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	13.6	18.3	17.0	17.3	12.9	10.3	8.0	7.9	8.6	11.7	15.1	17.8	18.2
	PrecAvg	104.8	11.5	8.6	8.4	6.4	4.6	3.8	4.8	6.7	10.7	13.4	12.9	13.0
Precipitation	PrecMax	142.7	21.4	17.8	15.8	9.8	11.5	7.0	8.9	14.6	19.3	20.9	23.1	28.2
	PrecMin	75.3	3.5	3.1	3.0	0.6	0.3	1.4	0.4	1.7	3.9	5.9	5.9	5.9
	PrecStd	17.0	3.6	3.9	3.3	2.3	2.6	1.4	2.0	3.0	3.7	3.4	4.1	5.4
	PrecStd	17.0	3.6	3.9	3.3	2.3	2.6	1.4	2.0	3.0	3.7	3.4	4.1	5.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	48.0	49.6	55.7	62.6	68.2	68.7	68.6	61.2	55.3	51.1	49.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	46.4	45.3	46.4	51.9	58.9	63.9	64.5	64.8	58.2	52.9	48.3	45.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	44.3	43.4	44.5	49.3	56.1	60.3	61.9	62.1	56.4	51.2	46.3	44.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	42.4	41.8	42.9	47.5	53.8	58.0	59.6	59.7	55.0	50.0	44.8	42.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.9	5.1	6.1	7.6	8.2	7.8	7.4	7.5	6.4	5.2	4.8	4.7
		MCDBR	7.1	7.1	8.0	10.2	11.7	12.2	11.5	11.8	8.6	7.0	6.3	6.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.289	0.327	0.327	0.389	0.382	0.388	0.385	0.371	0.358	0.327	0.295	0.273
	taud		2.234	2.223	2.325	2.164	2.310	2.354	2.410	2.475	2.466	2.443	2.264	2.172
	Ebn at Noon		183	223	262	259	271	270	269	265	251	227	178	151
	Edh at Noon		16	25	29	40	37	36	34	30	26	20	15	13
All-Sky Solar Radiation	RadAvg		157	422	839	1354	1674	1629	1409	1150	763	430	199	109
	RadStd		14	55	82	105	137	135	142	129	99	50	22	12

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page