

POINT ARENA, CA, USA

WMO: 994120

Lat: 38.9549N

Lon: 123.7410W

Elev: 57

StdP: 14.67

Time Zone: -8.00 (NAP)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	39.2	41.3	N/A	N/A	N/A	N/A	N/A	N/A	39.3	52.2	34.9	51.6	6.7	70	0.698

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	4.6	62.0	N/A	60.1	N/A	58.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.2	27.9	24.9	DB	35.5	69.6	2.2	5.1	33.9	73.2	32.6	76.2	31.4	79.1	29.7	82.7	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	49.9	49.5	49.6	49.8	50.9	52.2	53.1	53.9	54.1	53.5	51.5	49.6
	DBStd	3.37	3.40	3.44	2.94	2.41	2.28	1.91	2.15	2.24	2.48	3.03	3.52	3.93
	HDD50	267	44	45	43	32	15	2	1	0	1	4	24	56
	HDD65	4937	468	433	479	457	438	383	368	343	328	357	405	478
	CDD50	809	42	33	29	25	42	70	97	122	123	112	70	44
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	2	0	0	0	0	0	0	0	0	1	1	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.2	11.5	12.1	13.8	13.3	14.6	14.3	11.7	11.2	10.5	10.9	10.9	11.6
Precipitation	PrecAvg	48.5	9.3	8.8	5.6	3.1	2.0	0.5	0.0	0.1	0.1	2.1	4.9	10.9
	PrecMax	75.2	28.3	27.0	17.2	10.5	7.0	2.5	0.2	1.3	0.5	5.7	12.6	24.6
	PrecMin	27.0	0.1	0.5	0.2	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.5
	PrecStd	14.4	6.7	6.5	5.0	2.6	2.2	0.7	0.0	0.3	0.1	1.6	3.6	7.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.9	60.7	59.3	58.0	61.2	59.2	60.8	62.2	62.6	66.3	63.9	59.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	57.2	57.6	57.1	55.8	57.0	57.3	58.9	60.2	60.2	61.5	59.4	57.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	56.1	55.9	55.5	54.5	55.5	56.2	57.5	58.5	58.9	58.9	57.7	56.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	55.1	54.5	54.2	53.4	54.4	55.3	56.5	57.3	57.6	57.3	56.4	55.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	7.1	6.8	6.1	5.1	3.9	3.7	3.7	4.1	4.6	6.0	6.8	7.5
		MCDBR	8.3	7.9	8.1	7.0	5.8	5.4	4.9	5.7	6.6	8.8	8.0	6.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.325	0.332	0.334	0.359	0.357	0.353	0.354	0.344	0.338	0.334	0.317	0.326	
	taud	2.557	2.540	2.551	2.439	2.483	2.497	2.503	2.531	2.528	2.574	2.598	2.554	
	Ebn at Noon	271	284	295	291	292	292	291	292	289	279	272	261	
	Edh at Noon	23	27	30	35	34	34	33	32	30	26	23	22	
All-Sky Solar Radiation	RadAvg	685	971	1384	1845	2170	2389	2199	1911	1647	1199	805	583	
	RadStd	103	134	127	140	153	122	117	103	97	88	72	96	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (25 neighbors)	N/A	N/A	-2.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page