

FOLLY ISLAND, SC, USA

WMO: 994230

Lat: 32.6850N

Lon: 79.8880W

Elev: 10

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.9	34.4	12.2	10.2	35.2	17.2	13.1	39.4	34.8	49.9	29.0	50.1	10.3	310	0.513

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	87.4	78.2	86.2	78.2	85.1	78.0	81.0	85.1	80.1	84.4	79.2	83.6	11.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.7	154.2	84.4	78.6	148.4	83.5	77.8	144.4	82.8	44.5	85.3	43.5	84.4	42.6	83.7	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
33.5	26.4	23.1	DB	25.3	92.9	4.6	1.8	22.0	94.2	19.4	95.2	16.8	96.2	13.5	97.5
			WB	22.1	81.9	3.3	1.1	19.7	82.7	17.8	83.4	15.9	84.0	13.4	84.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.8	48.7	51.0	56.8	64.6	72.2	78.3	80.9	80.4	76.7	68.2	58.5	52.5
	DBStd	12.80	7.77	6.75	6.59	5.53	4.69	3.34	2.43	2.61	3.79	6.04	6.95	7.63
	HDD50	279	119	64	20	0	0	0	0	0	0	0	13	63
	HDD65	1878	505	393	259	72	7	0	0	0	0	39	212	391
	CDD50	6051	79	92	232	437	690	848	958	942	800	565	268	140
	CDD65	2173	0	0	6	59	232	398	493	477	350	139	17	2
	CDH74	18289	0	1	8	50	813	3528	5460	5154	2806	464	5	0
	CDH80	3916	0	0	1	7	58	584	1504	1371	378	13	0	0
Wind	WSAvg	11.3	10.0	10.7	11.7	12.1	12.9	11.8	11.6	11.0	12.0	10.9	10.3	10.1
Precipitation	PrecAvg	49.0	3.7	3.0	3.7	2.9	2.7	4.9	6.2	6.7	5.3	4.7	2.4	3.1
	PrecMax	70.7	8.0	9.2	7.3	6.9	5.2	12.2	11.1	12.8	9.1	14.6	6.0	8.4
	PrecMin	38.3	0.9	1.1	0.6	1.1	0.3	2.3	2.7	2.0	0.8	0.0	0.0	0.9
	PrecStd	8.1	2.2	1.6	1.8	1.5	1.4	2.4	2.4	2.9	2.0	3.5	1.7	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.7	68.1	73.4	78.9	85.8	89.1	90.6	89.6	86.3	81.8	74.6	69.4
		MCWB	59.6	61.8	60.7	67.2	74.6	76.4	77.6	78.8	74.8	74.5	71.2	67.8
	2%	DB	63.0	63.9	68.9	74.8	81.0	86.1	87.4	87.1	84.1	79.8	72.3	67.1
		MCWB	60.6	61.1	64.2	69.0	74.3	77.1	79.0	79.3	75.9	73.9	69.0	65.8
	5%	DB	61.1	61.6	66.9	73.0	79.0	84.3	86.1	86.0	83.0	78.3	70.4	65.1
		MCWB	59.2	59.2	63.2	68.5	73.3	77.0	78.8	78.8	75.9	72.9	67.1	63.2
	10%	DB	59.2	59.6	64.9	71.4	77.7	83.1	85.0	84.9	82.1	76.8	68.4	63.0
		MCWB	57.2	57.3	61.6	67.1	72.8	76.4	78.4	78.1	75.5	71.9	65.4	61.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.5	65.3	68.2	74.0	78.2	81.1	82.3	82.3	80.2	77.8	73.1	68.7
		MCDB	64.1	66.0	68.8	75.0	81.9	85.0	85.7	86.2	82.6	79.9	74.1	69.0
	2%	WB	61.7	62.3	66.2	71.7	76.2	79.9	81.0	81.0	78.5	75.8	70.4	67.0
		MCDB	62.4	63.1	67.3	73.0	79.1	84.1	85.0	85.5	81.6	78.1	71.4	67.4
	5%	WB	60.0	60.0	64.1	69.9	75.0	78.6	80.1	79.9	77.7	74.7	68.2	64.7
		MCDB	60.9	60.8	65.9	71.7	77.6	82.9	84.4	84.6	81.1	77.2	69.4	65.4
	10%	WB	58.0	58.1	62.3	68.3	73.9	77.8	79.2	78.9	77.0	73.3	66.2	62.2
		MCDB	59.1	59.0	64.3	70.4	76.9	82.2	83.8	83.8	80.7	76.1	67.8	63.4
Mean Daily Temperature Range	5% DB	MDBR	11.0	10.3	9.8	9.0	7.4	7.2	7.2	7.1	7.7	9.6	10.8	10.8
		MCDBR	11.4	10.9	11.6	10.0	8.9	9.7	9.0	8.2	8.4	9.4	10.7	10.4
		MCWBR	9.9	7.9	7.7	7.0	5.1	5.7	5.5	4.6	5.2	6.2	8.5	9.1
	5% WB	MCDBR	9.3	9.0	8.3	6.8	6.6	8.3	7.9	7.4	6.4	7.4	8.6	8.9
		MCWBR	9.4	8.2	7.0	5.7	4.8	5.6	5.5	5.1	5.0	6.2	7.9	8.9
Clear-Sky Solar Irradiance	taub	0.330	0.337	0.365	0.408	0.464	0.493	0.527	0.509	0.435	0.390	0.351	0.335	
	taud	2.541	2.519	2.457	2.320	2.214	2.180	2.098	2.148	2.348	2.454	2.516	2.553	
	Ebn at Noon	283	292	290	280	264	255	246	249	264	269	272	274	
	Edh at Noon	27	30	34	41	46	47	51	48	38	31	27	25	
All-Sky Solar Radiation	RadAvg	903	1117	1481	1902	2060	2083	1994	1800	1525	1317	1007	805	
	RadStd	54	116	138	130	133	143	119	116	128	138	69	64	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	+1.03	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+358	+248

Nomenclature: See separate page