

FOLLY ISLAND, SC, USA

WMO: 994230

Lat: 32.6850N

Lon: 79.8880W

Elev: 3

StdP: 101.29

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.6	1.3	-11.0	1.5	1.8	-8.2	1.9	4.1	15.5	10.0	13.0	10.0	4.6	310	0.513

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.0	30.8	25.7	30.1	25.7	29.5	25.5	27.2	29.5	26.7	29.1	26.2	28.7	4.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.5	22.0	29.1	25.9	21.2	28.6	25.4	20.6	28.2	85.5	29.6	83.3	29.1	81.1	28.7	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.0	11.8	10.3	-3.7	33.8	2.5	1.0	-5.5	34.5	-7.0	35.1	-8.4	35.7	-10.3	36.4		
			-5.5	27.7	1.9	0.6	-6.8	28.2	-7.9	28.5	-9.0	28.9	-10.3	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.8	9.3	10.6	13.8	18.1	22.4	25.7	27.2	26.9	24.8	20.1	14.7	11.4	(6)
(7)		DBStd	7.11	4.32	3.75	3.66	3.07	2.61	1.86	1.35	1.45	2.11	3.35	3.86	4.24	(7)
(8)		HDD10.0	155	66	36	11	0	0	0	0	0	0	7	35		(8)
(9)		HDD18.3	1043	281	218	144	40	4	0	0	0	22	118	217		(9)
(10)		CDD10.0	3362	44	51	129	243	383	471	532	523	444	314	149	78	(10)
(11)		CDD18.3	1207	0	0	3	33	129	221	274	265	194	77	9	1	(11)
(12)		CDH23.3	10161	0	1	4	28	452	1960	3033	2863	1559	258	3	0	(12)
(13)		CDH26.7	2176	0	0	1	4	32	324	836	762	210	7	0	0	(13)
(14)	Wind	WSAvg	5.0	4.5	4.8	5.2	5.4	5.8	5.3	5.2	4.9	5.4	4.9	4.6	4.5	(14)
(15)	Precipitation	PrecAvg	1245	94	75	93	73	68	124	157	169	134	119	60	79	(15)
(16)		PrecMax	1796	202	234	186	175	132	309	283	324	231	371	152	214	(16)
(17)		PrecMin	972	22	29	16	29	8	59	69	51	20	0	1	22	(17)
(18)		PrecStd	207	57	41	45	37	36	61	61	74	52	89	42	44	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.7	20.0	23.0	26.1	29.9	31.7	32.6	32.0	30.2	27.7	23.6	20.8	(19)
(20)		MCWB	15.4	16.5	16.0	19.5	23.7	24.7	25.3	26.0	23.8	23.6	21.8	19.9		(20)
(21)		2%	DB	17.2	17.7	20.5	23.8	27.2	30.0	30.8	30.6	28.9	26.5	22.4	19.5	(21)
(22)		MCWB	15.9	16.2	17.9	20.5	23.5	25.0	26.1	26.3	24.4	23.3	20.6	18.8		(22)
(23)		5%	DB	16.2	16.4	19.4	22.8	26.1	29.1	30.1	30.0	28.3	25.7	21.3	18.4	(23)
(24)		MCWB	15.1	15.1	17.3	20.3	22.9	25.0	26.0	26.0	24.4	22.7	19.5	17.3		(24)
(25)		10%	DB	15.1	15.4	18.3	21.9	25.4	28.4	29.5	29.4	27.8	24.9	20.2	17.2	(25)
(26)		MCWB	14.0	14.1	16.4	19.5	22.7	24.7	25.8	25.6	24.2	22.2	18.5	16.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.5	18.5	20.1	23.3	25.7	27.3	27.9	27.9	26.8	25.4	22.8	20.4	(27)
(28)		MADB	17.8	18.9	20.4	23.9	27.7	29.5	29.9	30.1	28.1	26.6	23.4	20.6		(28)
(29)		2%	WB	16.5	16.8	19.0	22.1	24.6	26.6	27.2	27.2	25.9	24.3	21.3	19.5	(29)
(30)		MADB	16.9	17.3	19.6	22.8	26.2	29.0	29.5	29.7	27.6	25.6	21.9	19.7		(30)
(31)		5%	WB	15.5	15.5	17.8	21.1	23.9	25.9	26.7	26.6	25.4	23.7	20.1	18.1	(31)
(32)		MADB	16.0	16.0	18.8	22.1	25.3	28.3	29.1	29.2	27.3	25.1	20.8	18.6		(32)
(33)		10%	WB	14.5	14.5	16.9	20.2	23.3	25.4	26.2	26.1	25.0	22.9	19.0	16.8	(33)
(34)		MADB	15.1	15.0	17.9	21.3	25.0	27.9	28.8	28.8	27.1	24.5	19.9	17.4		(34)
(35)	Mean Daily Temperature Range	MDBR	6.1	5.7	5.5	5.0	4.1	4.0	4.0	3.9	4.3	5.3	6.0	6.0	(35)	
(36)		5% DB	MCDBR	6.3	6.1	6.4	5.6	5.0	5.4	5.0	4.6	4.7	5.2	6.0	5.8	(36)
(37)		MCWBR	5.5	4.4	4.3	3.9	2.8	3.2	3.0	2.5	2.9	3.4	4.7	5.0	(37)	
(38)		5% WB	MADB	5.1	5.0	4.6	3.8	3.7	4.6	4.4	4.1	3.6	4.1	4.8	4.9	(38)
(39)		MCWBR	5.2	4.6	3.9	3.2	2.7	3.1	3.1	2.8	2.8	3.4	4.4	5.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.330	0.337	0.365	0.408	0.464	0.493	0.527	0.509	0.435	0.390	0.351	0.335	(40)	
(41)		taud	2.541	2.519	2.457	2.320	2.214	2.180	2.098	2.148	2.348	2.454	2.516	2.553	(41)	
(42)		Ebn at Noon	891	919	914	883	833	805	775	784	833	849	858	864	(42)	
(43)		Edh at Noon	84	94	107	128	144	149	161	151	119	99	85	79	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.85	3.52	4.67	6.00	6.50	6.57	6.29	5.67	4.81	4.15	3.17	2.54	(44)	
(45)		RadStd	0.17	0.37	0.43	0.41	0.42	0.45	0.37	0.37	0.40	0.43	0.22	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	+0.57	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+199	+138

Nomenclature: See separate page