

SABINE PASS, TX, USA

WMO: 994260

Lat: 29.6834N

Lon: 94.0333W

Elev: 1

StdP: 101.31

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.1	2.2	-7.7	2.0	3.7	-4.7	2.6	6.1	15.2	12.5	12.8	11.8	5.1	0	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	31.8	25.2	30.9	25.4	30.5	25.4	27.0	29.7	26.7	29.5	26.4	29.3	4.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.8	28.8	25.8	21.1	28.7	25.5	20.7	28.7	84.9	29.8	83.1	29.5	81.9	29.4	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	12.5	10.6	DB	-2.8	34.4	1.9	1.6	-4.2	35.5	-5.2	36.4	-6.3	37.2	-7.6	38.4	(4)
(5)			WB	-4.6	27.7	1.6	0.5	-5.8	28.0	-6.7	28.3	-7.6	28.6	-8.7	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.3	11.0	12.6	16.1	20.0	24.0	27.1	28.0	28.1	25.9	21.7	16.5	12.3	(6)	
	DBStd	6.98	4.39	4.32	3.88	3.05	2.26	1.50	1.24	1.45	2.27	3.58	4.29	4.51	(7)	
	HDD10.0	106	43	23	6	0	0	0	0	0	0	0	6	28	(8)	
	HDD18.3	782	229	161	86	18	1	0	0	0	0	13	83	191	(9)	
	CDD10.0	3873	73	97	196	301	435	513	557	560	478	364	199	101	(10)	
	CDD18.3	1506	0	2	17	69	178	263	298	302	228	118	27	4	(11)	
	CDH23.3	15012	1	1	8	117	1194	3010	3741	3791	2356	768	25	1	(12)	
(13)	CDH26.7	4771	0	0	1	4	66	908	1447	1572	693	78	1	0	(13)	
(14)	Wind	WSAvg	5.4	5.1	5.4	5.7	6.5	6.8	5.9	5.2	4.8	4.8	5.2	4.9	4.9	(14)
(15) Precipitation	PrecAvg	1468	126	91	96	98	120	149	149	129	154	131	103	121	(15)	
	PrecMax	2039	298	201	208	260	262	442	386	317	365	415	254	311	(16)	
	PrecMin	806	18	25	16	7	0	18	30	21	32	17	11	27	(17)	
	PrecStd	307	69	54	50	65	78	86	87	86	74	115	58	63	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.0	21.9	24.1	27.0	29.1	32.4	32.1	33.6	33.0	29.5	25.2	22.9	(19)	
		MCWB	16.3	19.1	18.5	19.4	22.9	25.4	24.9	24.5	23.7	24.3	21.5	21.6	(20)	
	2%	DB	18.5	20.3	22.7	25.4	27.9	30.7	30.8	32.0	30.7	28.3	24.1	20.9	(21)	
		MCWB	17.1	19.3	20.2	21.8	23.7	25.4	25.4	25.3	24.5	24.4	22.0	19.8	(22)	
	5%	DB	17.6	19.0	21.8	24.6	27.4	30.0	30.5	31.2	30.0	27.5	23.2	20.0	(23)	
		MCWB	16.6	18.2	20.1	21.9	23.9	25.1	25.4	25.5	24.7	24.4	21.2	19.1	(24)	
	10%	DB	16.7	18.0	20.9	23.9	26.9	29.4	30.1	30.6	29.4	26.8	22.3	18.9	(25)	
		MCWB	15.8	17.2	19.5	21.6	23.7	24.9	25.4	25.6	24.8	23.8	20.4	17.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.9	21.4	22.6	24.0	25.9	27.4	26.9	27.8	27.9	26.6	23.8	21.8	(27)	
		MCDB	19.1	21.5	22.9	24.9	27.2	30.1	29.7	30.3	28.9	27.9	24.5	22.7	(28)	
	2%	WB	17.9	20.0	21.6	23.4	25.2	26.7	26.7	27.1	26.7	26.0	22.6	20.5	(29)	
		MCDB	18.2	20.2	22.0	24.5	26.8	29.3	29.6	30.0	28.9	27.5	23.4	21.0	(30)	
	5%	WB	17.1	18.9	20.7	22.9	24.7	26.3	26.3	26.8	26.2	25.4	21.8	19.6	(31)	
		MCDB	17.4	19.0	21.2	24.0	26.5	28.8	29.4	29.9	28.7	27.1	22.7	20.0	(32)	
	10%	WB	16.2	17.9	20.0	22.4	24.3	25.9	26.1	26.5	25.7	24.6	20.9	18.4	(33)	
		MCDB	16.5	18.1	20.7	23.6	26.2	28.6	29.3	29.8	28.5	26.5	21.9	18.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	5.5	5.4	4.7	3.7	4.0	4.1	4.8	5.7	6.1	6.4	6.6	(35)	
		MCDBR	6.1	5.8	5.3	5.2	4.4	5.3	4.6	6.2	6.1	5.3	5.6	5.8	(36)	
	5% WB	MCWBR	5.5	4.3	4.1	3.3	2.6	2.6	2.3	2.6	3.1	3.3	4.4	5.4	(37)	
		MCWBR	5.0	3.8	3.8	3.2	3.1	3.7	4.2	4.7	4.1	4.2	5.3	4.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.346	0.361	0.378	0.435	0.479	0.481	0.496	0.478	0.455	0.387	0.374	0.354	(40)	
		taud	2.520	2.488	2.432	2.273	2.181	2.230	2.216	2.272	2.298	2.473	2.450	2.503	(41)	
	Edn at Noon	Edn at Noon	889	905	909	864	823	817	803	815	822	865	848	861	(42)	
		Edh at Noon	89	100	112	136	150	142	143	134	127	100	95	87	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.91	3.31	4.59	5.52	6.22	6.38	6.02	5.70	5.01	4.44	3.37	2.59	(44)	
	RadStd	RadStd	0.28	0.54	0.40	0.41	0.41	0.46	0.51	0.47	0.53	0.55	0.33	0.29	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (31 neighbors)	+0.34	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+108	+88

Nomenclature: See separate page