

NEWPORT SOUTH BEACH JETTY, OR, USA

WMO: 994280

Lat: 44.6130N

Lon: 124.0670W

Elev: 30

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	32.0	34.6	16.6	12.7	37.4	24.0	18.2	42.8	55.9	49.2	47.5	50.9	10.0	80	0.687

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	65.4	57.9	63.1	58.1	61.5	57.8	60.8	62.3	59.9	61.3	59.1	60.4	9.8	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.3	78.3	60.9	59.4	75.6	60.1	58.4	73.1	59.4	26.9	62.7	26.3	61.2	25.7	60.5	66.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.0	33.8	28.0	DB	28.3	80.0	3.6	7.3	25.7	85.2	23.6	89.5	21.6	93.7	19.0	99.0	(4)
(5)			WB	24.3	64.3	4.9	2.1	20.8	65.8	18.0	67.0	15.2	68.2	11.7	69.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	46.7	46.0	46.7	48.0	51.1	53.5	54.9	55.4	55.3	52.4	49.3	45.8	(6)
(7)		DBStd	5.39	4.50	4.83	4.01	3.58	3.62	2.68	3.08	3.09	3.90	3.96	4.59	5.14	(7)
(8)		HDD50	697	118	126	116	77	27	2	1	0	2	19	65	144	(8)
(9)		HDD65	5312	567	533	566	511	433	344	313	297	293	390	470	595	(9)
(10)		CDD50	866	16	13	15	17	60	109	153	169	161	94	45	14	(10)
(11)		CDD65	4	0	0	0	1	1	0	0	0	2	0	0	0	(11)
(12)		CDH74	31	0	0	0	5	6	5	0	1	13	1	0	0	(12)
(13)		CDH80	8	0	0	0	1	2	2	0	0	3	0	0	0	(13)
(14)	Wind	WSAvg	11.6	13.7	12.9	13.1	12.6	11.5	10.5	10.1	9.2	9.4	10.3	12.7	13.7	(14)
(15)	Precipitation	PrecAvg	68.2	10.7	7.8	7.3	4.8	3.3	2.6	0.9	1.1	2.2	5.2	10.4	11.7	(15)
(16)		PrecMax	102.9	21.3	16.8	13.1	9.6	7.2	6.2	3.2	7.0	6.3	10.6	20.3	22.4	(16)
(17)		PrecMin	46.3	0.7	1.6	1.2	1.1	0.4	0.4	0.0	0.0	0.0	0.1	1.9	2.8	(17)
(18)		PrecStd	13.1	4.7	3.9	3.1	2.0	1.6	1.6	0.7	1.3	1.7	2.7	4.6	5.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.5	60.8	62.2	66.0	66.5	64.4	64.4	65.8	74.8	68.4	62.7	59.3	(19)
(20)			MCWB	49.8	48.4	50.2	52.9	55.7	55.4	61.2	59.1	56.3	53.6	56.0	54.2	(20)
(21)		2%	DB	56.2	56.5	56.3	56.5	59.5	60.2	62.4	63.4	64.9	61.9	58.9	56.0	(21)
(22)			MCWB	50.8	49.1	50.8	50.7	56.0	56.9	59.9	59.3	58.7	57.3	55.1	52.2	(22)
(23)		5%	DB	54.2	54.2	54.2	54.3	57.3	59.0	61.1	61.8	62.5	59.7	56.9	54.0	(23)
(24)			MCWB	51.0	48.8	50.7	50.5	54.1	56.2	58.9	59.1	58.3	56.9	54.4	51.1	(24)
(25)		10%	DB	52.8	52.2	52.6	53.0	55.8	57.8	59.8	60.2	60.7	57.9	55.3	52.4	(25)
(26)			MCWB	50.3	48.1	49.7	49.9	52.7	55.3	58.3	58.3	58.0	55.6	53.2	49.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.2	54.9	54.4	54.6	60.2	59.8	62.8	61.5	61.8	61.8	58.8	56.4	(27)
(28)			MCD B	55.8	55.9	55.8	58.2	62.9	60.5	63.9	62.8	64.7	62.1	60.3	57.7	(28)
(29)		2%	WB	53.3	52.0	52.8	53.0	57.2	58.2	60.3	60.2	60.4	59.4	56.9	54.0	(29)
(30)			MCD B	54.1	53.8	54.4	54.7	59.5	59.2	61.2	61.4	62.8	60.2	57.7	55.2	(30)
(31)		5%	WB	52.2	50.5	51.4	51.8	55.4	57.1	59.2	59.2	59.5	58.1	55.6	52.4	(31)
(32)			MCD B	53.2	52.4	53.0	53.4	57.3	58.3	60.0	60.4	61.3	59.2	56.5	53.4	(32)
(33)		10%	WB	50.8	49.3	50.3	50.8	54.2	56.1	57.8	58.1	58.8	56.9	54.3	50.7	(33)
(34)			MCD B	51.9	51.2	51.9	52.5	56.0	57.4	58.8	59.3	60.6	58.1	55.4	51.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	9.1	8.8	8.3	6.5	5.8	5.4	6.0	7.4	8.9	8.9	8.4	(35)
(36)			MCDBR	10.0	11.7	11.3	10.6	9.1	8.2	6.7	7.9	11.0	11.4	9.9	9.0	(36)
(37)			MCWBR	6.8	8.0	7.4	7.4	5.8	5.3	5.7	5.9	6.7	6.4	6.8	7.1	(37)
(38)		5% WB	MCDBR	7.0	8.7	8.4	8.8	8.1	6.5	6.3	7.2	8.5	7.2	7.3	7.5	(38)
(39)			MCWBR	6.1	6.9	7.1	6.9	5.7	4.9	5.2	5.8	6.2	5.7	6.6	6.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.325	0.324	0.336	0.370	0.377	0.362	0.349	0.356	0.348	0.336	0.331	0.331	(40)	
(41)		taud	2.527	2.549	2.527	2.390	2.401	2.460	2.516	2.510	2.526	2.556	2.525	2.471	(41)	
(42)		Ebn at Noon	253	276	286	283	283	287	290	285	279	267	248	236	(42)	
(43)		Edh at Noon	22	25	29	36	36	35	32	31	29	24	21	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	419	681	1012	1450	1804	1960	2118	1792	1408	854	478	344	(44)	
(45)		RadStd	59	75	113	107	149	146	142	140	111	90	60	47	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+31

Nomenclature: See separate page