

GALLOO ISLAND, NY, USA

WMO: 994320

Lat: 43.8885N

Lon: 76.4443W

Elev: 105

StdP: 100.07

Time Zone: -5.00 (NAE)

Period: 86-02

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 2	(b) -18.8	(c) -15.9	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 26.8	(k) -1.0	(l) 24.2	(m) 1.4	(n) 5.7	(o) 50	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.2	(c) 25.8	(d) N/A	(e) 24.9	(f) N/A	(g) 24.0	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 4.4	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 18.5	(b) 15.8	(c) 14.1	(e) -22.0	(f) 28.1	(g) 3.0	(h) 1.7	(i) -24.1	(j) 29.3	(k) -25.9	(l) 30.3	(m) -27.6	(n) 31.2	(o) -29.7	(p) 32.4		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.0	-3.8	-4.8	-0.4	5.2	10.4	16.2	20.7	20.7	16.6	10.8	4.7	-0.9		
	DBStd	9.76	5.84	5.25	4.45	3.52	3.02	3.24	2.26	2.46	3.25	3.44	4.18	5.57		
	HDD10.0	1885	428	416	322	150	32	1	0	0	1	33	163	339		
	HDD18.3	3958	687	649	580	394	246	79	6	7	70	235	408	597		
	CDD10.0	1166	0	0	0	6	45	188	333	333	199	57	5	0		
	CDD18.3	196	0	0	0	0	0	16	81	82	17	0	0	0		
	CDH23.3	324	0	0	0	4	1	18	128	169	5	0	0	0		
	CDH26.7	17	0	0	0	1	0	1	6	9	0	0	0	0		
(14) Wind	WSAvg	6.6	8.0	7.3	6.5	6.4	5.9	5.0	5.0	5.4	6.2	7.2	8.5	7.9		
(15) Precipitation	PrecAvg	1213	109	94	87	94	95	98	92	88	96	124	109	126		
	PrecMax	1438	191	150	155	168	179	179	169	155	144	214	167	185		
	PrecMin	1014	59	56	43	28	32	33	37	30	51	31	59	69		
	PrecStd	116	34	20	29	38	40	37	35	36	28	46	31	30		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.7	5.9	10.7	19.0	20.2	25.5	27.3	27.9	24.1	19.7	14.7	9.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	5.6	4.6	7.8	14.2	17.8	23.4	25.6	26.1	22.9	17.8	13.7	8.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	4.1	3.2	6.5	11.8	16.1	22.2	24.8	25.2	22.0	16.7	12.3	6.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	3.1	2.1	4.9	9.9	14.8	20.8	24.0	24.2	21.1	15.6	10.8	5.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		6.5	6.7	5.5	4.9	5.1	4.6	3.9	4.2	4.7	4.6	5.1	5.7		
	5% DB	MCDBR	6.1	5.6	7.3	8.9	7.6	6.8	5.1	4.8	5.2	5.0	6.0	5.3		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.294	0.298	0.323	0.357	0.385	0.421	0.425	0.416	0.372	0.350	0.310	0.286		
	taud		2.425	2.410	2.430	2.397	2.374	2.303	2.296	2.314	2.418	2.461	2.521	2.508		
	Ebn at Noon		836	899	918	907	886	852	843	839	852	826	815	817		
	Edh at Noon		74	89	100	112	119	128	127	121	101	85	68	63		
(44) All-Sky Solar Radiation	RadAvg		1.25	2.07	3.38	4.47	5.47	5.80	5.91	5.22	4.14	2.45	1.51	0.98		
	RadStd		0.13	0.20	0.29	0.50	0.53	0.47	0.49	0.26	0.34	0.23	0.19	0.13		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (32 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page