

MATINICUS ROCK, ME, USA

WMO: 994370

Lat: 43.7836N

Lon: 68.8549W

Elev: 16

StdP: 101.13

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.6	-12.1	-20.3	0.6	-12.4	-18.6	0.7	-10.7	23.2	2.7	21.7	1.3	12.1	320	0.895

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.5	20.8	18.6	19.9	18.1	19.0	17.6	19.7	20.4	19.0	19.5	18.2	18.7	5.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.3	19.9	18.8	13.6	19.2	18.0	12.9	18.5	56.4	20.4	53.8	19.4	51.5	18.7	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.4	18.6	16.3		-17.0	24.2	3.0	1.4	-19.2	25.2	-20.9	26.0	-22.6	26.8	-24.8	27.9
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	-2.3	-1.7	0.9	5.0	8.7	12.8	16.5	16.8	14.6	11.0	6.5	2.2
	DBStd	7.35	5.80	4.45	3.38	2.27	2.23	2.30	1.98	1.55	1.71	2.60	3.76	4.52
	HDD10.0	1572	381	326	281	151	53	4	0	0	0	21	112	244
	HDD18.3	3912	639	559	539	400	297	168	62	51	113	228	354	501
	CDD10.0	713	0	0	1	0	14	87	202	212	137	51	8	1
	CDD18.3	11	0	0	0	0	0	0	6	5	0	0	0	0
	CDH23.3	4	0	0	0	0	0	0	3	1	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.2	10.4	9.8	9.5	8.5	7.7	6.7	6.3	6.2	5.9	8.2	9.4	10.0
Precipitation	PrecAvg	1544	144	122	134	124	111	124	96	97	120	150	145	177
	PrecMax	2087	266	262	227	249	222	254	192	234	251	420	248	295
	PrecMin	963	31	51	41	16	21	62	45	27	41	39	55	67
	PrecStd	219	53	41	49	51	47	52	39	51	53	73	43	56
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	7.4	9.1	12.2	17.5	21.1	23.0	21.9	19.7	17.6	14.4	13.7
		MCWB	10.0	6.9	7.5	7.9	14.3	17.7	19.2	19.1	16.6	14.5	12.9	12.9
	2%	DB	8.9	6.0	7.0	9.9	14.4	18.1	21.2	20.6	18.1	15.8	13.3	11.6
		MCWB	8.3	5.3	5.8	7.5	12.0	14.9	18.9	18.7	16.8	14.5	12.2	10.5
	5%	DB	7.4	5.2	5.8	8.7	12.7	16.7	20.1	19.8	17.4	14.8	12.4	10.1
		MCWB	6.2	4.4	4.6	6.7	11.0	14.5	18.3	18.3	16.4	13.8	11.4	9.3
	10%	DB	5.8	4.2	5.0	7.8	11.5	15.6	19.1	19.1	16.8	14.0	11.6	8.7
		MCWB	4.6	3.1	3.7	6.1	10.0	14.0	17.7	17.9	15.7	13.0	10.5	7.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.3	7.6	8.3	10.2	15.6	19.4	20.8	20.6	18.5	16.0	14.1	13.5
		MCDB	10.4	7.6	9.0	10.8	16.7	20.7	21.7	21.0	18.6	16.4	14.1	13.7
	2%	WB	8.9	5.8	6.5	8.5	12.9	16.3	19.9	19.7	17.7	15.1	12.7	11.3
		MCDB	9.0	5.9	7.1	9.2	13.8	17.1	20.8	20.0	17.8	15.7	13.1	11.7
	5%	WB	6.9	4.8	5.2	7.4	11.8	15.2	19.1	19.0	16.9	14.2	11.8	9.8
		MCDB	7.3	5.1	5.7	8.2	12.4	16.2	19.8	19.4	17.2	14.6	12.2	10.3
	10%	WB	5.2	3.5	4.2	6.6	10.5	14.4	18.3	18.3	16.3	13.5	10.9	8.1
		MCDB	6.0	4.2	4.7	7.4	11.5	15.3	18.9	18.7	16.7	13.9	11.5	8.7
Mean Daily Temperature Range	5% DB	MDBR	6.2	5.5	4.4	3.3	3.5	3.8	4.0	3.5	2.9	2.9	4.0	5.5
		MCDBR	6.4	5.6	4.6	4.4	5.7	5.8	5.4	4.5	3.7	3.3	4.1	5.8
		MCWBR	7.2	6.1	4.5	3.3	3.8	3.9	3.8	3.3	3.1	3.3	4.8	6.7
	5% WB	MCDBR	6.1	5.8	4.6	3.9	5.5	5.6	5.0	3.8	3.4	3.2	3.8	5.7
		MCWBR	7.4	6.7	4.8	3.5	4.5	4.3	4.0	3.4	3.3	3.4	4.8	6.9
Clear-Sky Solar Irradiance	taub	0.309	0.313	0.332	0.356	0.384	0.423	0.444	0.413	0.369	0.342	0.323	0.304	
	taud	2.476	2.483	2.472	2.434	2.400	2.304	2.266	2.343	2.443	2.514	2.532	2.522	
	Ebn at Noon	823	885	909	909	888	850	827	842	857	839	801	795	
	Edh at Noon	72	84	96	108	116	128	131	118	99	81	68	63	
All-Sky Solar Radiation	RadAvg	1.54	2.45	3.68	4.68	5.33	5.72	6.01	5.41	4.36	2.82	1.73	1.25	
	RadStd	0.12	0.20	0.25	0.49	0.62	0.49	0.42	0.27	0.26	0.26	0.16	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+59	N/A

Nomenclature: See separate page