

DAUPHIN ISLAND, AL, USA

WMO: 994420

Lat: 30.2504N

Lon: 88.0750W

Elev: 0

StdP: 14.70

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.5	37.4	16.1	12.4	38.8	21.3	16.0	42.5	43.9	40.6	36.0	48.9	20.2	0	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	88.3	78.5	87.2	78.1	86.4	77.7	80.7	85.0	79.9	84.6	79.2	84.2	8.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.5	153.0	83.6	78.4	147.4	83.4	77.6	143.6	83.2	44.3	85.5	43.3	84.8	42.6	84.2	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
37.3	30.9	26.0	DB	28.0	90.9	3.2	2.1	25.8	92.4	23.9	93.7	22.1	94.8	19.8	96.4	(4)
			WB	23.8	81.7	3.2	1.4	21.4	82.7	19.5	83.5	17.7	84.3	15.4	85.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	52.4	55.7	60.9	68.0	75.5	80.6	82.3	82.7	79.5	71.4	62.1	55.8
	DBStd	12.15	8.23	7.21	6.45	4.77	3.95	2.72	2.28	2.56	3.40	6.01	6.82	7.92
	HDD50	152	72	30	8	0	0	0	0	0	0	0	5	37
	HDD65	1276	390	265	151	26	1	0	0	0	0	19	129	295
	CDD50	7080	148	189	346	540	790	918	1002	1013	885	664	369	216
	CDD65	2731	1	4	24	116	326	468	537	548	435	219	44	9
	CDH74	25655	0	0	3	109	2026	5019	6407	6651	4289	1099	52	0
	CDH80	7088	0	0	0	0	158	1264	2152	2428	1005	81	0	0
Wind	WSAvg	12.6	13.9	14.0	14.0	14.1	12.5	10.5	9.5	9.6	12.3	13.5	13.5	13.7
Precipitation	PrecAvg	61.5	5.3	4.1	5.3	4.8	4.0	6.0	8.0	5.1	6.5	3.7	4.2	4.4
	PrecMax	82.8	15.4	8.8	10.4	19.1	14.9	13.9	21.3	11.5	18.3	10.6	11.0	6.2
	PrecMin	38.7	0.2	0.4	0.4	0.2	0.0	1.9	2.8	1.1	2.5	0.0	0.6	2.4
	PrecStd	12.9	4.1	2.6	2.9	4.3	3.5	3.0	4.4	2.5	4.3	3.1	2.9	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.2	71.2	74.1	78.4	85.3	88.4	89.6	90.8	88.3	83.8	77.8	72.8
		MCWB	67.2	69.5	68.0	73.5	76.0	77.4	78.9	78.8	76.0	76.1	73.0	69.1
	2%	DB	66.5	68.2	71.7	76.7	83.1	86.8	88.0	88.5	86.1	82.2	75.5	70.5
		MCWB	65.7	66.8	67.9	71.6	74.7	76.6	78.7	79.0	75.8	75.8	71.9	67.9
	5%	DB	65.3	66.4	70.2	75.3	81.7	85.7	86.9	87.3	85.0	80.7	73.4	68.5
		MCWB	64.4	65.1	67.0	70.6	74.6	76.3	78.3	78.4	76.1	74.9	69.6	66.8
	10%	DB	63.8	64.8	68.8	74.0	80.6	84.7	86.1	86.5	84.2	79.3	71.6	67.0
		MCWB	62.7	63.3	66.0	69.6	74.2	76.2	78.0	78.2	76.2	73.6	67.8	65.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.9	70.5	71.1	75.2	78.4	80.2	81.6	84.0	80.3	79.8	75.6	68.7
		MCDB	68.0	71.6	72.1	76.9	80.9	84.6	86.8	84.9	82.9	81.9	77.9	69.1
	2%	WB	66.4	68.3	69.6	73.7	77.6	79.3	80.4	81.6	79.2	77.7	72.7	67.9
		MCDB	66.6	69.2	70.8	75.3	80.5	83.3	85.8	84.6	82.9	80.3	75.3	68.4
	5%	WB	65.1	65.7	68.3	72.4	76.9	78.5	79.6	80.2	78.4	76.3	70.2	66.8
		MCDB	65.5	66.0	69.5	74.1	80.0	82.9	85.1	84.8	82.7	79.6	72.5	67.5
	10%	WB	63.8	63.2	67.0	71.3	75.7	78.0	78.8	79.4	77.9	74.9	68.5	65.3
		MCDB	64.3	63.9	68.4	73.2	79.3	82.6	84.5	84.9	82.7	78.9	70.9	66.2
Mean Daily Temperature Range	5% DB	MDBR	9.9	9.0	7.9	6.3	5.4	5.8	5.8	6.0	6.4	7.7	9.3	9.6
		MCDBR	8.5	7.4	6.9	6.0	5.8	6.4	6.5	6.4	6.5	6.4	8.0	9.0
		MCWBR	8.8	8.1	7.3	5.5	4.5	5.0	4.3	4.1	4.1	4.8	9.3	8.3
	5% WB	MCDBR	8.3	7.7	6.3	5.5	5.0	6.2	6.2	6.0	5.3	5.6	9.0	8.2
		MCWBR	9.1	8.5	7.4	6.5	4.5	5.3	4.9	4.6	4.1	5.3	10.0	9.3
Clear-Sky Solar Irradiance	taub	0.336	0.353	0.376	0.406	0.439	0.464	0.504	0.497	0.445	0.387	0.358	0.344	
	taud	2.549	2.508	2.437	2.351	2.297	2.277	2.188	2.203	2.313	2.464	2.483	2.536	
	Ebn at Noon	285	289	289	282	272	263	252	253	263	274	274	276	
	Edh at Noon	27	31	35	40	42	43	47	46	40	32	29	26	
All-Sky Solar Radiation	RadAvg	976	1164	1571	1905	2119	2014	1886	1765	1661	1452	1113	861	
	RadStd	78	160	125	158	109	152	129	132	101	141	98	76	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)		+0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+263	+167

Nomenclature: See separate page