

DAUPHIN ISLAND, AL, USA

WMO: 994420

Lat: 30.2504N

Lon: 88.0750W

Elev: 0

StdP: 101.33

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	3.0	-8.8	1.8	3.8	-5.9	2.3	5.8	19.6	4.8	16.1	9.4	9.0	0	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.3	31.3	25.9	30.7	25.6	30.2	25.4	27.1	29.5	26.6	29.2	26.2	29.0	3.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.4	21.9	28.7	25.8	21.1	28.6	25.3	20.5	28.5	85.1	29.7	82.8	29.3	81.2	29.0	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.7	13.8	11.6	-2.2	32.7	1.8	1.2	-3.5	33.6	-4.5	34.3	-5.5	34.9	-6.8	35.8		
			-4.6	27.6	1.8	0.8	-5.9	28.2	-6.9	28.6	-7.9	29.1	-9.2	29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	11.4	13.2	16.1	20.0	24.2	27.0	28.0	28.2	26.4	21.9	16.7	13.2
	DBStd	6.75	4.57	4.00	3.58	2.65	2.19	1.51	1.27	1.42	1.89	3.34	3.79	4.40
	HDD10.0	84	40	17	4	0	0	0	0	0	0	0	3	21
	HDD18.3	709	217	147	84	14	1	0	0	0	0	11	72	164
	CDD10.0	3933	82	105	192	300	439	510	557	563	492	369	205	120
	CDD18.3	1517	1	2	13	64	181	260	298	304	242	122	24	5
	CDH23.3	14253	0	0	2	61	1126	2788	3559	3695	2383	611	29	0
	CDH26.7	3938	0	0	0	0	88	702	1196	1349	558	45	0	0
Wind	WSAvg	5.6	6.2	6.3	6.3	6.3	5.6	4.7	4.2	4.3	5.5	6.0	6.0	6.1
Precipitation	PrecAvg	1562	135	103	135	123	101	153	204	129	165	95	107	111
	PrecMax	2103	390	224	263	484	378	353	542	291	464	269	279	158
	PrecMin	983	4	11	11	5	0	48	70	28	64	0	16	61
	PrecStd	328	104	66	74	110	90	75	111	63	110	78	74	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	21.8	23.4	25.8	29.6	31.3	32.0	32.6	31.3	28.8	25.5	22.7
		MCWB	19.6	20.8	20.0	23.1	24.5	25.2	26.1	26.0	24.5	24.5	22.8	20.6
	2%	DB	19.2	20.1	22.1	24.8	28.4	30.4	31.1	31.4	30.0	27.9	24.2	21.4
		MCWB	18.7	19.3	19.9	22.0	23.7	24.8	25.9	26.1	24.3	24.3	22.2	20.0
	5%	DB	18.5	19.1	21.2	24.0	27.6	29.9	30.5	30.7	29.4	27.1	23.0	20.3
		MCWB	18.0	18.4	19.4	21.5	23.7	24.6	25.7	25.8	24.5	23.8	20.9	19.3
	10%	DB	17.7	18.2	20.5	23.3	27.0	29.3	30.0	30.3	29.0	26.3	22.0	19.5
		MCWB	17.1	17.4	18.9	20.9	23.4	24.6	25.5	25.6	24.5	23.1	19.9	18.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.0	21.4	21.7	24.0	25.8	26.8	27.6	28.9	26.8	26.5	24.2	20.4
		MCDB	20.0	22.0	22.3	24.9	27.2	29.2	30.4	29.4	28.3	27.7	25.5	20.6
	2%	WB	19.1	20.2	20.9	23.2	25.4	26.3	26.9	27.6	26.2	25.4	22.6	20.0
		MCDB	19.2	20.7	21.6	24.0	26.9	28.5	29.9	29.2	28.3	26.8	24.0	20.2
	5%	WB	18.4	18.7	20.2	22.4	24.9	25.8	26.5	26.8	25.8	24.6	21.2	19.3
		MCDB	18.6	18.9	20.9	23.4	26.7	28.3	29.5	29.3	28.2	26.5	22.5	19.7
	10%	WB	17.7	17.4	19.5	21.8	24.3	25.5	26.0	26.3	25.5	23.9	20.3	18.5
		MCDB	18.0	17.7	20.2	22.9	26.3	28.1	29.2	29.4	28.1	26.0	21.6	19.0
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.0	4.4	3.5	3.0	3.2	3.2	3.3	3.6	4.3	5.2	5.3
		MCDBR	4.7	4.1	3.8	3.3	3.2	3.6	3.6	3.5	3.6	3.6	4.5	5.0
		MCWBR	4.9	4.5	4.1	3.1	2.5	2.8	2.4	2.3	2.3	2.7	5.1	4.6
	5% WB	MCDBR	4.6	4.3	3.5	3.1	2.8	3.4	3.4	3.3	3.0	3.1	5.0	4.6
		MCWBR	5.1	4.7	4.1	3.6	2.5	2.9	2.7	2.6	2.3	3.0	5.6	5.1
Clear-Sky Solar Irradiance	taub	0.336	0.353	0.376	0.406	0.439	0.464	0.504	0.497	0.445	0.387	0.358	0.344	
	taud	2.549	2.508	2.437	2.351	2.297	2.277	2.188	2.203	2.313	2.464	2.483	2.536	
	Ebn at Noon	899	912	910	889	856	830	796	798	830	863	863	869	
	Edh at Noon	86	97	111	125	133	135	147	144	125	100	91	83	
All-Sky Solar Radiation	RadAvg	3.08	3.67	4.95	6.00	6.68	6.35	5.95	5.56	5.24	4.58	3.51	2.71	
	RadStd	0.25	0.50	0.40	0.50	0.34	0.48	0.41	0.41	0.32	0.45	0.31	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+146	+93

Nomenclature: See separate page