

MOLASSES REEF, FL, USA

WMO: 994430

Lat: 25.0118N

Lon: 80.3765W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	13.4	N/A	N/A	N/A	N/A	N/A	N/A	19.1	20.5	16.7	20.1	9.9	0	0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.0	30.2	N/A	30.0	N/A	29.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.2	110

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
18.0	14.6	12.3	DB	8.3	31.1	2.5	0.5	6.5	31.4	5.1	31.7	3.7	32.0	1.9	32.4	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	20.8	21.7	22.4	24.1	25.9	27.5	28.2	28.5	27.9	26.5	24.0	22.3
	DBStd	3.38	3.42	2.92	2.53	1.71	1.18	0.99	0.90	0.86	0.90	1.49	2.31	3.17
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	45	19	10	5	0	0	0	0	0	0	0	1	9
	CDD10.0	5477	336	327	383	422	492	526	564	574	538	512	419	383
	CDD18.3	2479	97	103	129	172	234	276	306	316	288	254	171	133
	CDH23.3	22855	232	256	411	914	2033	3205	3846	4080	3551	2610	1092	627
CDH26.7	5768	0	0	1	8	139	877	1397	1624	1202	480	38	1	
Wind	WSAvg	6.3	7.3	6.6	7.0	7.0	6.1	5.1	4.7	4.8	5.2	7.0	7.6	7.4
Precipitation	PrecAvg	1475	48	52	54	72	135	239	175	212	215	155	63	54
	PrecMax	1838	152	147	147	139	318	472	275	313	334	371	202	314
	PrecMin	1222	10	1	7	8	14	78	93	83	95	38	10	8
	PrecStd	174	34	35	34	35	72	106	54	60	63	92	56	63
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.8	25.8	26.7	27.7	28.7	30.0	30.5	30.7	30.2	29.4	28.0	26.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	25.4	25.5	26.1	26.8	28.1	29.6	30.1	30.2	29.9	29.0	27.6	26.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	25.1	25.2	25.6	26.4	27.8	29.3	29.7	30.1	29.6	28.6	27.2	26.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	24.6	24.9	25.2	26.1	27.5	29.0	29.5	29.8	29.4	28.4	26.8	25.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.5	2.9	2.6	2.0	1.7	1.9	1.9	2.0	2.2	2.0	2.6	3.0
		MCDBR	2.5	2.0	2.1	2.0	1.9	2.0	1.9	2.2	2.2	2.0	2.0	2.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.364	0.380	0.387	0.401	0.429	0.453	0.463	0.445	0.428	0.416	0.382	0.374	
	taud	2.545	2.504	2.473	2.415	2.386	2.383	2.346	2.424	2.454	2.464	2.511	2.532	
	Ebn at Noon	894	903	912	900	868	841	833	849	860	854	866	867	
	Edh at Noon	92	102	110	119	123	122	127	117	111	105	94	90	
All-Sky Solar Radiation	RadAvg	3.83	4.66	5.72	6.46	6.47	5.99	6.16	5.92	5.24	4.70	4.05	3.58	
	RadStd	0.26	0.28	0.23	0.29	0.56	0.48	0.28	0.27	0.23	0.34	0.19	0.27	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)	+0.38	+0.87	N/A	N/A	N/A	N/A	N/A	-16	+119	+106

Nomenclature: See separate page