

SOMBRERO KEY LH, FL, USA

WMO: 994450

Lat: 24.6279N

Lon: 81.1108W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	54.0	57.3	37.2	32.6	56.1	42.3	39.8	59.0	36.4	65.2	33.9	67.1	18.9	10	0.563

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	88.3	79.6	87.3	79.1	86.6	78.7	82.4	85.0	81.6	84.7	80.7	84.6	6.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.8	165.5	84.1	80.6	158.9	83.8	79.7	154.0	83.7	46.1	84.7	45.1	84.7	44.2	84.5	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.8	33.1	28.6	DB	49.4	90.6	4.6	0.9	46.1	91.3	43.4	91.8	40.9	92.3	37.6	93.0	(4)
(5)			WB	41.9	83.1	4.5	1.9	38.6	84.5	36.0	85.5	33.5	86.6	30.2	87.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.6	69.9	70.9	73.0	76.4	79.7	82.4	83.7	84.3	83.0	80.2	74.8	72.4
	DBStd	6.33	5.92	5.56	4.49	3.13	2.14	2.05	2.02	1.86	1.82	3.12	4.29	5.55
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	67	27	18	6	0	0	0	0	0	0	0	2	14
	CDD50	10078	619	584	714	791	921	972	1046	1063	991	937	745	695
	CDD65	4668	180	183	255	341	456	522	581	598	541	472	296	243
	CDH74	43778	515	501	913	2051	4214	6109	7296	7774	6664	4868	1756	1117
	CDH80	12359	1	2	11	66	525	1918	2894	3354	2419	1079	80	10
Wind	WSAvg	14.5	15.0	14.4	17.1	16.1	14.2	12.6	11.9	12.0	12.9	15.1	16.9	15.5
Precipitation	PrecAvg	40.8	2.0	1.7	1.5	2.0	2.9	4.6	3.7	5.9	7.0	5.9	1.8	1.8
	PrecMax	55.4	8.2	6.1	3.5	6.1	9.1	14.7	8.3	19.3	15.2	17.2	6.7	5.4
	PrecMin	27.8	0.0	0.0	0.3	0.1	0.5	0.2	0.8	1.1	3.6	1.5	0.0	0.0
	PrecStd	7.4	2.0	1.6	1.0	1.5	2.4	3.3	1.9	3.3	2.4	4.1	1.8	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.8	80.2	81.6	83.4	85.7	88.6	89.4	89.7	88.6	86.8	83.1	81.3
		MCWB	74.9	75.8	76.1	76.7	78.1	79.6	80.2	80.4	80.0	78.9	76.3	76.3
	2%	DB	78.4	78.5	79.9	81.8	84.3	86.9	87.7	88.4	87.1	85.2	82.0	80.2
		MCWB	73.6	74.0	74.5	75.7	77.3	78.6	79.4	79.7	78.8	77.7	75.9	75.5
	5%	DB	77.7	77.9	78.7	80.5	83.4	86.0	86.9	87.4	86.3	84.3	81.0	79.3
		MCWB	72.9	73.5	73.4	74.8	76.7	78.3	79.0	79.1	78.4	77.5	75.3	74.8
	10%	DB	76.9	77.0	77.8	79.8	82.4	85.2	86.2	86.8	85.6	83.8	80.1	78.6
		MCWB	72.0	72.7	72.5	74.1	75.8	77.9	78.6	78.9	78.1	77.4	74.6	73.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.4	78.1	78.1	79.6	80.2	81.7	83.4	83.4	83.4	82.2	78.7	78.9
		MCDB	78.2	78.7	80.0	80.5	83.8	84.9	86.0	86.1	84.3	84.0	80.2	79.8
	2%	WB	75.7	76.4	76.3	77.8	78.4	80.5	82.0	82.3	82.2	80.7	77.5	77.4
		MCDB	77.3	77.6	78.6	80.1	82.5	84.5	85.3	85.6	84.1	83.0	79.9	78.9
	5%	WB	74.2	74.6	74.9	76.4	77.4	79.9	80.9	81.4	81.1	79.8	76.8	76.4
		MCDB	76.9	76.8	77.8	79.6	81.8	84.2	85.0	85.3	84.0	82.8	79.7	78.5
	10%	WB	72.9	73.2	73.5	75.1	76.7	79.2	80.1	80.5	80.1	78.7	75.5	75.2
		MCDB	76.5	76.4	77.2	79.0	81.3	83.9	84.9	85.3	84.1	82.6	79.5	78.1
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.0	5.0	4.2	4.1	4.9	4.8	5.2	5.1	4.6	5.2	5.5
		MCDBR	5.1	5.1	5.2	4.7	5.2	5.7	5.3	5.4	5.7	4.7	4.5	4.5
		MCWBR	5.3	4.9	4.9	4.7	4.6	4.7	4.8	4.6	4.6	3.9	4.3	4.7
	5% WB	MCDBR	5.1	5.3	5.6	5.2	5.0	5.3	5.3	5.5	5.6	4.6	4.8	4.5
		MCWBR	5.8	5.4	5.8	5.9	4.6	5.0	5.6	5.0	5.2	4.4	4.9	5.3
Clear-Sky Solar Irradiance	taub	0.363	0.378	0.384	0.402	0.425	0.444	0.452	0.434	0.422	0.409	0.379	0.371	
	taud	2.549	2.510	2.478	2.407	2.393	2.411	2.388	2.461	2.461	2.486	2.519	2.547	
	Ebn at Noon	285	287	290	285	277	269	267	272	275	273	277	277	
	Edh at Noon	29	32	35	38	39	38	38	36	35	33	30	28	
All-Sky Solar Radiation	RadAvg	1239	1533	1885	2126	2143	1992	2035	1936	1713	1534	1324	1169	
	RadStd	92	102	76	94	191	151	97	76	79	108	66	102	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	+0.65	+1.55	N/A	N/A	N/A	N/A	N/A	-23	+209	+187

Nomenclature: See separate page