

FOWEY ROCKS LH, FL, USA

WMO: 994560

Lat: 25.5906N

Lon: 80.0967W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 52.0	(c) 55.8	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 36.2	(k) 68.9	(l) 34.2	(m) 68.2	(n) 21.6	(o) 340	(p) 0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.3	(c) 88.0	(d) N/A	(e) 86.8	(f) N/A	(g) 86.1	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 11.0	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 36.8	(b) 32.1	(c) 28.1	(d) DB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A
(a) 36.8	(b) 32.1	(c) 28.1	(d) WB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.9	69.1	71.1	71.9	74.9	78.3	81.4	82.9	83.5	82.3	79.9	74.8	71.8
	DBStd	6.21	5.96	5.22	4.59	3.24	2.18	2.06	1.85	1.71	1.70	2.89	4.28	5.48
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	82	35	18	9	1	0	0	0	0	0	0	3	16
	CDD50	9802	591	592	679	746	876	943	1021	1038	969	927	743	677
	CDD65	4408	161	190	223	296	411	493	556	573	519	462	296	228
	CDH74	39437	289	432	623	1388	3296	5552	6855	7298	6245	4777	1799	883
	CDH80	10063	0	1	7	22	237	1467	2477	2895	2026	869	60	2
(14) Wind	WSAvg	15.4	16.9	15.9	17.9	17.3	16.4	13.4	11.5	12.1	13.5	15.5	16.8	17.5
(15) Precipitation	PrecAvg	59.5	1.9	2.2	2.3	3.1	5.1	9.1	6.7	8.1	9.3	6.7	2.8	2.2
	PrecMax	73.3	7.1	5.5	6.3	6.2	11.2	16.6	10.7	12.6	15.1	14.6	9.1	10.9
	PrecMin	49.8	0.3	0.1	0.2	0.4	0.2	3.1	3.6	3.0	5.3	1.6	0.4	0.4
	PrecStd	7.0	1.6	1.5	1.5	1.6	2.7	4.1	2.1	2.4	2.9	4.0	2.4	2.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.3	79.4	81.1	82.3	88.0	88.5	89.2	90.8	88.1	86.1	82.4	80.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	77.4	78.2	79.4	80.4	83.8	86.4	87.3	88.2	86.4	84.4	81.5	79.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	76.7	77.3	78.2	79.6	82.2	85.4	86.3	86.9	85.5	83.7	80.7	78.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	75.8	76.5	77.2	78.7	81.1	84.5	85.5	86.1	84.8	83.1	79.8	77.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	5.3	5.2	4.6	4.1	5.0	4.9	5.3	4.3	3.8	4.9	5.6
		MCDBR	4.8	5.1	5.6	5.9	6.5	6.7	6.2	6.7	5.3	4.4	4.4	4.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.366	0.378	0.389	0.400	0.427	0.457	0.463	0.452	0.430	0.417	0.383	0.375
	taud		2.532	2.506	2.463	2.418	2.387	2.364	2.337	2.398	2.452	2.456	2.504	2.521
	Ebn at Noon		282	286	288	286	276	266	264	267	272	270	274	274
	Edh at Noon		30	32	35	38	39	39	41	38	35	33	30	29
(44) All-Sky Solar Radiation	RadAvg		1186	1442	1769	2000	2010	1843	1902	1824	1604	1462	1255	1106
	RadStd		79	86	79	95	162	160	81	96	81	107	57	79

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)	+0.70	+1.60	N/A	N/A	N/A	N/A	N/A	N/A	-29	+234	+200

Nomenclature: See separate page