

FOWEY ROCKS LH, FL, USA

WMO: 994560

Lat: 25.5906N

Lon: 80.0967W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 11.1	(c) 13.2	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 16.2	(k) 20.5	(l) 15.3	(m) 20.1	(n) 9.7	(o) 340	(p) 0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 3.0	(c) 31.1	(d) N/A	(e) 30.5	(f) N/A	(g) 30.0	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 4.9	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 16.4	(b) 14.4	(c) 12.6	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.9	20.6	21.7	22.2	23.8	25.7	27.5	28.3	28.6	27.9	26.6	23.8	22.1		
	DBStd	3.45	3.31	2.90	2.55	1.80	1.21	1.14	1.03	0.95	0.94	1.61	2.38	3.04		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	46	19	10	5	1	0	0	0	0	0	0	2	9		
	CDD10.0	5446	328	329	377	414	487	524	567	577	538	515	413	376		
	CDD18.3	2449	89	106	124	164	228	274	309	318	288	257	164	127		
	CDH23.3	21909	161	240	346	771	1831	3084	3808	4054	3469	2654	999	491		
	CDH26.7	5591	0	1	4	12	132	815	1376	1608	1126	483	33	1		
(14) Wind	WSAvg	6.9	7.6	7.1	8.0	7.7	7.3	6.0	5.2	5.4	6.0	6.9	7.5	7.8		
(15) Precipitation	PrecAvg	1512	49	57	59	78	129	231	170	207	235	171	70	57		
	PrecMax	1861	180	139	159	157	285	421	271	321	384	370	232	276		
	PrecMin	1266	8	3	5	11	5	79	92	76	135	41	9	10		
	PrecStd	178	40	38	37	41	69	103	53	61	73	101	60	59		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.7	26.4	27.3	27.9	31.1	31.4	31.8	32.7	31.1	30.1	28.0	26.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	25.2	25.6	26.4	26.9	28.8	30.2	30.7	31.2	30.2	29.1	27.5	26.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	24.8	25.2	25.7	26.4	27.9	29.7	30.2	30.5	29.7	28.7	27.1	25.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	24.3	24.7	25.1	25.9	27.3	29.2	29.7	30.0	29.3	28.4	26.6	25.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		3.6	2.9	2.9	2.5	2.3	2.8	2.7	3.0	2.4	2.1	2.7	3.1		
	5% DB	MCDBR	2.7	2.9	3.1	3.3	3.6	3.7	3.5	3.7	3.0	2.5	2.4	2.4		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.366	0.378	0.389	0.400	0.427	0.457	0.463	0.452	0.430	0.417	0.383	0.375		
	taud		2.532	2.506	2.463	2.418	2.387	2.364	2.337	2.398	2.452	2.456	2.504	2.521		
	Ebn at Noon		889	903	908	901	870	838	832	843	857	851	863	863		
	Edh at Noon		93	102	111	119	122	124	128	120	111	105	94	91		
(44) All-Sky Solar Radiation	RadAvg		3.74	4.54	5.58	6.31	6.34	5.81	6.00	5.75	5.06	4.61	3.96	3.49		
	RadStd		0.25	0.27	0.25	0.30	0.51	0.50	0.25	0.30	0.26	0.34	0.18	0.25		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		+0.39	+0.89	N/A	N/A	N/A	N/A	N/A	-16	+130	+111

Nomenclature: See separate page