

LONG KEY, FL, USA

WMO: 994620

Lat: 24.844N

Lon: 80.864W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.9	12.9	4.4	5.2	13.3	6.9	6.2	15.4	13.7	15.6	12.6	15.5	7.8	0	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.7	30.9	25.9	30.6	25.9	30.3	25.7	27.4	29.5	27.0	29.4	26.8	29.3	2.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	22.4	28.7	26.3	21.8	28.9	25.9	21.2	28.8	86.1	29.6	84.9	29.5	83.6	29.3	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.2	11.0	9.9	DB	8.6	32.6	2.6	0.4	6.7	32.9	5.2	33.1	3.7	33.3	1.8	33.6	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	20.0	21.3	22.2	24.2	26.2	28.0	28.7	29.0	28.3	26.7	23.3	21.4
	DBStd	3.86	3.58	3.18	2.80	1.95	1.32	1.14	0.98	1.04	1.00	1.91	2.70	3.38
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	62	27	12	7	0	0	0	0	0	0	0	2	14
	CDD10.0	5462	309	318	379	426	503	541	580	588	548	517	401	354
	CDD18.3	2481	77	97	128	176	244	291	322	329	298	258	153	109
	CDH23.3	23687	150	269	448	1000	2214	3482	4149	4372	3683	2673	852	393
Wind	WSAvg	5.2	5.6	5.4	6.0	6.0	5.5	4.7	4.2	4.1	4.4	5.3	5.5	5.6
	PrecAvg	1112	53	40	61	47	77	157	103	143	193	133	63	49
	PrecMax	1400	195	194	179	137	159	337	204	226	336	350	192	138
	PrecMin	695	7	0	18	5	0	1	48	76	89	22	5	10
	PrecStd	194	42	48	39	32	53	99	42	44	65	90	57	34
	DB	25.8	26.3	27.7	28.9	29.6	31.1	31.4	31.7	31.2	30.1	28.6	26.9	
	MCWB	22.9	23.3	23.9	24.9	25.4	25.5	25.8	26.0	26.1	26.1	25.1	24.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	25.4	25.8	26.8	27.7	28.8	30.3	30.8	31.0	30.5	29.5	28.0	26.4	
	2% MCWB	22.8	22.9	23.5	24.2	24.9	25.2	25.7	26.0	25.9	25.7	24.8	23.8	
	5% DB	24.9	25.4	26.1	26.9	28.3	30.0	30.4	30.7	30.1	29.1	27.5	25.9	
	5% MCWB	22.4	22.6	23.1	23.6	24.6	25.1	25.7	25.9	25.8	25.6	24.6	23.4	
	10% DB	24.2	25.0	25.5	26.5	27.9	29.6	30.1	30.4	29.7	28.7	26.7	25.4	
	10% MCWB	21.9	22.3	22.7	23.3	24.2	25.0	25.6	25.8	25.6	25.5	24.1	23.0	
	WB	23.9	25.0	25.2	25.7	26.7	26.8	27.3	27.5	27.8	27.8	25.8	25.3	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	24.5	25.5	25.8	28.3	29.5	29.7	30.1	30.3	30.0	28.3	27.5	25.8	
	2% WB	23.4	23.8	24.6	25.1	25.6	26.4	26.9	27.3	27.3	27.3	25.5	24.5	
	2% MCDB	24.4	25.2	25.6	27.6	28.0	28.3	29.9	30.2	29.5	28.2	27.5	25.7	
	5% WB	23.0	23.3	24.0	24.7	24.9	26.1	26.7	26.9	26.8	26.8	25.0	24.0	
	5% MCDB	24.3	25.1	25.4	27.1	27.4	28.3	29.8	30.0	29.3	28.3	27.3	25.5	
	10% WB	22.6	22.9	23.3	24.0	24.4	25.8	26.4	26.6	26.4	26.4	24.3	23.6	
	10% MCDB	24.0	24.9	25.1	26.6	27.2	28.4	29.6	29.8	29.0	28.3	26.7	25.1	
Mean Daily Temperature Range	MDBR	3.4	3.1	2.9	2.3	2.0	2.4	2.5	2.7	2.5	2.3	2.9	3.2	
	5% DB	2.2	2.5	2.9	2.5	2.5	2.6	2.7	2.7	2.9	2.3	2.2	2.5	
	5% MCWB	1.9	2.1	2.4	2.4	2.0	2.1	1.8	1.9	2.0	1.7	1.5	1.8	
	5% WB	2.4	2.4	2.6	2.7	2.2	2.7	2.3	2.6	2.7	2.0	2.1	2.3	
	5% MCWB	3.0	2.5	2.7	2.9	2.1	2.4	1.8	2.1	2.1	1.8	2.1	2.2	
	taub	0.364	0.379	0.385	0.401	0.427	0.448	0.455	0.438	0.426	0.410	0.380	0.371	
	taud	2.545	2.504	2.475	2.407	2.389	2.397	2.375	2.447	2.452	2.481	2.513	2.543	
Clear-Sky Solar Irradiance	Ebn at Noon	895	904	914	900	870	845	840	856	862	860	869	872	
	Edh at Noon	92	102	110	120	122	120	123	114	111	103	94	89	
	RadAvg	3.87	4.76	5.84	6.59	6.63	6.14	6.28	5.99	5.32	4.78	4.12	3.63	
All-Sky Solar Radiation	RadStd	0.28	0.30	0.24	0.29	0.58	0.48	0.29	0.25	0.25	0.34	0.20	0.29	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (20 neighbors)		+0.38	+0.87	N/A	N/A	N/A	N/A	N/A	-13	+116	+104	

Nomenclature: See separate page