

CEDAR KEY, FL, USA

WMO: 994640

Lat: 29.1359N

Lon: 83.0293W

Elev: 2

StdP: 101.30

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.6	(c) 4.5	(d) -6.9	(e) 2.1	(f) 5.0	(g) -4.1	(h) 2.7	(i) 6.9	(j) 11.5	(k) 16.3	(l) 10.1	(m) 15.3	(n) 4.0	(o) 350	(p) 0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.3	(c) 31.3	(d) 25.5	(e) 30.8	(f) 25.5	(g) 30.3	(h) 25.4	(i) 27.6	(j) 29.2	(k) 26.9	(l) 29.1	(m) 26.5	(n) 29.0	(o) 3.9	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	22.9	28.6	26.3	21.7	28.4	25.7	20.9	28.3	87.4	29.1	84.3	29.1	82.2	29.0	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.4	(b) 9.5	(c) 8.4	(e) -1.1	(f) 32.5	(g) 1.9	(h) 0.7	(i) -2.5	(j) 33.0	(k) -3.6	(l) 33.4	(m) -4.7	(n) 33.8	(o) -6.0	(p) 34.3		
(4) 11.4	(5) 9.5	(6) 8.4	(7) -1.1	(8) 32.5	(9) 1.9	(10) 0.7	(11) -2.5	(12) 33.0	(13) -3.6	(14) 33.4	(15) -4.7	(16) 33.8	(17) -6.0	(18) 34.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	12.9	14.6	17.3	20.7	24.4	27.1	27.8	28.0	26.6	22.9	17.7	15.0
	DBStd	6.15	4.45	3.93	3.54	2.77	2.06	1.38	1.20	1.25	1.54	3.16	3.77	4.26
	HDD10.0	47	25	8	2	0	0	0	0	0	0	0	2	9
	HDD18.3	534	173	111	59	12	0	0	0	0	0	7	54	116
	CDD10.0	4162	114	138	229	321	447	513	551	557	497	399	232	165
	CDD18.3	1608	4	7	28	83	189	263	293	298	247	148	34	13
	CDH23.3	14635	1	7	12	187	1292	2848	3467	3503	2371	862	82	4
(14) Wind	WSAvg	4.1	3.7	3.8	4.5	4.7	4.5	4.4	3.9	4.0	4.5	3.9	3.9	3.7
	PrecAvg	1379	106	83	109	79	58	165	213	208	144	83	54	74
	PrecMax	1809	244	300	380	219	136	409	490	421	410	208	121	200
	PrecMin	911	30	14	13	10	2	55	106	107	49	10	2	15
	PrecStd	240	55	60	78	53	39	62	82	81	91	52	32	50
	DB	22.4	24.4	24.7	27.1	29.9	31.4	31.9	32.0	31.5	29.6	26.9	24.0	21.8
	MCWB	18.9	20.8	20.1	21.9	23.5	25.2	25.3	26.1	24.4	24.8	23.3	20.1	18.8
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	20.7	22.5	23.6	25.9	28.8	30.7	31.1	31.3	30.6	28.6	25.5	22.6	20.9
	2% MCWB	18.7	20.4	19.8	21.7	23.4	25.5	25.5	25.9	24.6	24.2	22.8	19.9	18.8
	5% DB	19.8	20.7	22.8	25.2	28.0	30.2	30.6	30.8	30.0	27.7	24.2	21.6	20.5
	5% MCWB	18.5	18.9	19.4	21.4	23.1	25.3	25.5	25.7	24.7	23.8	21.4	19.4	18.8
	10% DB	18.6	19.4	21.9	24.5	27.4	29.6	30.1	30.3	29.3	26.9	22.8	20.5	18.8
	10% MCWB	17.2	17.9	19.0	21.0	22.9	25.1	25.4	25.6	24.6	23.4	20.1	18.8	18.8
	WB	20.3	21.8	22.5	24.0	25.8	28.9	27.7	28.0	28.0	28.0	24.4	21.8	20.9
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	21.1	23.3	22.9	25.8	27.7	29.7	29.3	29.6	28.8	28.0	25.9	22.9	20.9
	2% WB	19.5	20.9	21.3	23.0	25.0	27.2	26.9	27.3	27.1	25.5	23.6	20.9	20.9
	2% MCDB	20.3	22.4	22.4	24.9	27.1	29.2	29.3	29.6	28.2	26.7	25.2	21.9	20.9
	5% WB	18.8	19.8	20.5	22.5	24.3	26.3	26.5	26.8	26.2	24.8	22.4	20.2	20.2
	5% MCDB	19.7	20.7	21.9	24.4	26.7	28.8	29.3	29.5	28.0	26.6	24.1	21.1	21.1
	10% WB	17.8	18.8	19.9	21.8	23.8	25.7	26.1	26.4	25.5	24.1	20.9	19.2	19.2
	10% MCDB	18.7	19.5	21.4	23.8	26.4	28.5	29.1	29.4	27.9	26.4	22.2	20.3	20.3
(35) Mean Daily Temperature Range	MDBR	6.4	5.7	5.6	5.2	4.6	4.0	4.2	4.3	5.0	5.8	6.9	6.5	6.5
	5% DB	6.0	5.4	5.8	5.5	5.2	4.4	4.5	4.6	5.7	5.5	6.5	6.0	6.0
	5% MCWBR	4.1	3.5	3.6	3.2	2.7	2.5	2.3	2.2	2.5	2.8	4.1	3.8	3.8
	5% WB	5.0	4.1	4.2	4.2	3.7	3.9	4.1	4.2	4.5	4.2	4.9	4.4	4.4
	5% MCWBR	4.3	3.2	3.7	3.7	2.8	2.6	2.6	2.4	2.9	3.0	4.1	3.8	3.8
(40) Clear-Sky Solar Irradiance	taub	0.342	0.351	0.367	0.388	0.425	0.456	0.493	0.471	0.427	0.387	0.355	0.341	0.341
	taud	2.525	2.504	2.457	2.371	2.323	2.309	2.211	2.284	2.384	2.474	2.503	2.551	2.551
	Ebn at Noon	897	919	921	907	869	837	806	822	850	867	874	882	882
	Edh at Noon	89	98	110	123	130	131	144	133	117	100	90	83	83
(44) All-Sky Solar Radiation	RadAvg	3.37	4.03	5.26	6.33	6.83	6.19	5.83	5.55	5.05	4.62	3.72	3.06	3.06
	RadStd	0.23	0.37	0.48	0.41	0.39	0.42	0.39	0.38	0.41	0.33	0.23	0.26	0.26

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	-7	-55	+157	+112

Nomenclature: See separate page