

POTATO POINT, AK, USA

WMO: 994660

Lat: 61.0564N

Lon: 146.6982W

Elev: 7

StdP: 101.24

Time Zone: -9.00 (NAK)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.9	-9.3	N/A	N/A	N/A	N/A	N/A	N/A	21.7	-6.1	20.6	-6.0	17.1	30	0.848

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.6	18.4	N/A	16.8	N/A	15.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	2.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.3	17.7	15.8	-12.2	21.7	1.9	3.7	-13.5	24.3	-14.6	26.4	-15.7	28.5	-17.0	31.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	-2.1	-1.2	-0.2	3.5	8.0	11.1	12.6	11.9	9.1	5.3	0.4	-0.7
	DBStd	5.98	4.01	3.12	3.07	2.50	2.51	2.09	1.87	1.92	1.74	2.12	3.55	3.10
	HDD10.0	2087	377	313	317	194	72	11	2	2	36	144	287	333
	HDD18.3	4923	635	547	575	444	319	217	179	200	276	403	537	591
	CDD10.0	206	0	0	0	1	11	43	81	61	9	0	0	0
	CDD18.3	1	0	0	0	0	0	1	0	1	0	0	0	0
	CDH23.3	4	0	0	0	0	0	2	1	2	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	6.9	11.5	10.1	9.5	5.4	3.5	2.4	2.7	3.9	5.3	7.7	10.7	10.6
Precipitation	PrecAvg	1125	101	94	68	57	51	57	84	118	153	126	99	113
	PrecMax	1401	263	235	148	111	112	100	132	281	260	320	239	254
	PrecMin	771	11	0	15	13	12	18	42	16	69	55	2	25
	PrecStd	163	58	53	43	27	27	21	26	64	53	68	65	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	4.7	7.4	13.0	17.0	20.0	20.2	20.8	15.8	11.3	8.0	5.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	4.4	3.7	5.5	10.1	15.0	17.0	18.2	18.1	13.7	9.7	6.3	4.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	3.4	3.0	4.5	8.2	13.2	15.5	16.8	16.4	12.6	8.8	5.3	3.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	2.4	2.4	3.5	6.8	11.7	14.3	15.7	15.0	11.6	8.0	4.5	2.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.9	2.7	3.1	3.7	4.3	4.4	4.6	4.5	3.8	2.9	2.7	2.7
		MCDBR	3.4	3.1	4.1	5.7	6.7	6.5	6.7	6.7	5.3	4.0	3.1	3.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.267	0.327	0.333	0.386	0.410	0.398	0.409	0.403	0.348	0.326	0.282	0.263
	taud		2.006	2.020	2.058	1.965	2.029	2.196	2.221	2.226	2.343	2.188	1.989	1.904
	Ebn at Noon		423	607	763	788	804	826	805	773	760	616	381	239
	Edh at Noon		44	82	110	147	150	129	123	113	84	68	43	30
All-Sky Solar Radiation	RadAvg		0.28	0.96	2.50	4.27	5.40	5.63	5.01	3.81	2.46	1.13	0.40	0.15
	RadStd		0.03	0.14	0.26	0.35	0.42	0.32	0.33	0.38	0.33	0.13	0.07	0.02

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (22 neighbors)	N/A	+1.60	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page