

CAPE ELIZABETH BUOY 46041, USA

WMO: 994980

Lat: 47.353N

Lon: 124.742W

Elev: 0

StdP: 14.70

Time Zone: -8.00 (W08)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	35.4	38.1	N/A	N/A	N/A	N/A	N/A	N/A	35.7	46.6	33.5	45.9	12.4	110	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.5	62.4	N/A	61.5	N/A	60.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.6	30.7	25.9	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.1	45.9	45.4	46.4	48.3	51.5	54.3	56.8	57.4	56.7	54.1	49.7	46.1
	DBStd	5.29	3.63	3.29	2.70	2.69	2.77	2.29	2.23	2.05	2.22	2.59	3.23	3.74
	HDD50	625	132	130	115	64	14	0	0	0	0	2	41	127
	HDD65	5082	593	549	577	500	419	321	254	236	248	339	460	586
	CDD50	1019	4	1	3	14	60	130	211	229	202	128	31	6
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.5	15.9	13.5	13.7	13.5	11.0	10.4	9.7	8.6	9.4	12.4	14.6	17.1
Precipitation	PrecAvg	107.6	16.9	10.7	12.4	7.7	4.5	3.4	1.7	2.7	4.3	11.1	16.2	16.0
	PrecMax	136.7	30.3	27.8	22.2	14.4	8.4	7.5	5.0	12.0	12.5	20.3	30.4	26.3
	PrecMin	78.5	10.4	0.7	1.9	1.9	1.0	0.9	0.3	0.2	0.3	1.1	5.2	8.0
	PrecStd	14.8	4.3	5.5	4.8	3.2	2.0	1.6	1.1	2.6	2.8	4.9	6.5	4.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.3	53.0	54.6	57.4	62.3	62.2	62.4	64.2	63.8	60.3	57.3	54.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	52.7	51.7	52.2	55.3	59.1	59.7	61.4	62.7	61.9	59.3	55.7	53.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	51.5	50.7	51.1	53.3	57.5	58.5	60.7	61.7	60.9	58.6	54.7	52.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	50.5	50.0	50.3	52.1	55.2	57.5	60.0	60.4	60.0	57.8	53.6	51.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.2	4.3	3.6	3.1	2.9	3.0	3.5	3.9	3.7	4.2	4.2
		MCDBR	4.1	4.7	4.9	4.3	5.1	4.0	3.6	4.9	4.5	3.9	4.6	4.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.321	0.323	0.337	0.367	0.394	0.356	0.348	0.350	0.344	0.341	0.326	0.316
	taud		2.528	2.548	2.526	2.410	2.350	2.497	2.552	2.549	2.551	2.543	2.522	2.512
	Ebn at Noon		244	270	282	281	276	288	289	284	276	259	239	231
	Edh at Noon		20	24	28	35	38	33	31	30	27	23	20	18
All-Sky Solar Radiation	RadAvg		325	612	949	1392	1669	1823	1823	1570	1251	742	396	276
	RadStd		42	71	94	118	137	139	141	125	99	78	49	34

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page