

NORTH SEA STATION 62118, United Kingdom

WMO: 995190

Lat: 57.700N

Lon: 0.900E

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	34.1	35.2	19.3	14.5	36.5	21.6	16.2	37.3	49.9	39.7	47.1	41.4	20.8	80	0.873

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.6	65.6	63.5	63.7	61.3	62.3	59.9	64.1	65.3	62.0	63.3	60.4	61.9	13.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.6	87.9	65.2	61.3	80.9	63.1	59.7	76.4	61.7	29.3	65.5	27.8	63.3	26.7	62.0	69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
43.0	38.5	34.3	DB	32.1	67.2	2.5	3.1	30.2	69.4	28.8	71.2	27.3	73.0	25.5	75.3	
			WB	27.7	63.7	2.1	3.4	26.2	66.2	25.0	68.2	23.8	70.2	22.3	72.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	42.8	41.8	43.2	44.4	47.7	52.2	57.2	58.8	56.3	51.2	48.7	44.2
	DBStd	6.71	3.83	3.99	3.25	3.42	3.61	2.93	3.04	3.43	2.92	3.20	3.40	3.92
	HDD50	1199	223	230	211	171	88	10	0	0	1	26	59	180
	HDD65	5808	687	649	675	618	535	385	240	195	261	429	490	644
	CDD50	869	1	1	1	3	17	75	225	272	190	62	20	2
	CDD65	3	0	0	0	0	0	0	0	3	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	17.7	22.0	21.7	19.6	16.5	14.9	14.2	13.0	13.6	16.4	20.4	20.8	20.1
Precipitation	PrecAvg	49.4	5.9	5.0	4.6	2.5	1.9	2.5	3.0	3.6	4.4	5.0	5.3	5.7
	PrecMax	61.4	8.5	10.4	8.2	4.1	3.6	4.1	5.3	9.1	6.5	8.8	7.2	11.4
	PrecMin	38.0	2.4	2.4	2.2	1.7	0.8	1.1	1.3	1.5	1.6	1.9	2.5	2.9
	PrecStd	6.0	1.9	1.9	1.5	0.7	0.6	0.7	0.9	1.3	1.3	1.6	1.3	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	51.7	53.0	53.6	58.5	62.5	65.5	69.1	63.2	58.9	55.7	53.0
		MCWB	50.3	49.6	47.5	48.6	53.7	58.3	62.3	66.8	60.1	56.5	51.8	50.0
	2%	DB	50.2	50.7	50.0	50.4	55.5	59.3	64.0	67.1	62.3	57.0	54.6	51.8
		MCWB	47.3	48.7	46.5	46.8	51.8	56.3	61.4	65.4	59.8	54.6	51.5	49.2
	5%	DB	48.8	49.1	48.5	49.2	53.3	57.6	62.8	65.3	61.4	56.1	53.7	50.4
		MCWB	46.1	46.9	45.5	46.3	50.3	55.1	60.4	63.5	58.9	53.6	51.2	47.7
	10%	DB	47.9	47.5	47.4	48.2	52.0	56.3	61.4	63.4	60.3	55.3	52.9	49.3
		MCWB	45.1	45.1	44.8	45.8	49.5	54.1	59.1	61.2	57.7	52.7	50.4	46.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.5	49.7	48.5	49.0	54.6	59.1	63.8	67.4	61.7	56.6	53.1	51.2
		MCDB	52.9	51.4	50.7	52.0	57.6	61.7	64.5	68.8	62.7	58.0	53.9	52.5
	2%	WB	47.9	48.8	47.2	47.6	52.1	56.9	62.1	65.6	60.6	55.3	52.2	49.4
		MCDB	49.6	50.6	49.1	49.5	54.0	58.3	63.3	66.8	61.9	56.5	53.6	51.1
	5%	WB	46.6	47.1	46.2	46.9	51.0	55.8	60.9	63.9	59.6	54.3	51.7	48.3
		MCDB	48.4	48.8	48.0	48.7	52.7	57.4	62.2	65.2	61.0	55.6	53.3	49.9
	10%	WB	45.5	45.4	45.3	46.2	50.1	54.5	59.7	61.7	58.2	53.2	50.9	47.2
		MCDB	47.5	47.2	47.2	48.0	51.7	56.0	61.2	63.1	59.8	54.8	52.6	49.1
Mean Daily Temperature Range	5% DB	MDBR	4.3	4.3	4.2	4.2	3.9	3.4	3.6	3.6	3.5	4.0	3.8	4.5
		MCDBR	5.1	5.0	5.1	6.3	5.6	5.0	5.1	4.9	4.6	4.3	4.6	5.2
		MCWBR	5.4	5.6	4.4	4.8	4.7	4.2	4.2	4.5	4.1	4.8	5.1	5.9
	5% WB	MCDBR	5.1	4.6	4.9	5.5	5.0	4.6	4.2	4.6	3.9	4.2	4.1	4.7
MCWBR		5.7	5.3	4.9	4.5	4.5	4.2	4.0	4.5	3.9	4.8	4.9	5.6	
Clear-Sky Solar Irradiance	taub		0.333	0.352	0.370	0.392	0.377	0.380	0.389	0.383	0.370	0.353	0.333	0.311
	taud		2.181	2.269	2.306	2.288	2.409	2.427	2.415	2.433	2.449	2.366	2.235	2.148
	Ebn at Noon		156	213	245	259	272	273	267	260	245	212	156	126
	Edh at Noon		17	24	30	36	34	34	33	30	26	22	16	13
All-Sky Solar Radiation	RadAvg		116	311	713	1238	1730	1708	1596	1312	863	430	159	77
	RadStd		12	41	52	101	105	123	153	94	83	32	16	9

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page