

NORTH SEA STATION 62129, United Kingdom

WMO: 995210

Lat: 53.050N

Lon: 2.117E

Elev: 0

StdP: 14.70

Time Zone: 0.00 (E00)

Period: 90-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.3	34.7	19.3	14.5	35.3	22.4	16.8	36.9	53.0	42.2	49.3	41.1	24.7	90	0.913

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.3	66.4	63.5	65.0	62.5	64.0	61.6	64.3	65.7	63.3	64.7	62.2	63.7	16.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	88.0	65.2	62.5	84.7	64.4	61.4	81.4	63.5	29.4	65.8	28.7	64.9	28.0	63.8	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 45.8	41.0	36.3	DB	31.0	71.0	3.8	4.0	28.2	73.9	26.0	76.2	23.8	78.4	21.0	81.3	(4)
(5)			WB	27.2	66.0	4.2	4.2	24.2	69.0	21.8	71.4	19.4	73.8	16.4	76.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.0	42.8	41.3	43.0	45.4	49.3	54.3	58.7	60.7	57.6	53.1	48.5	44.4	(6)
(7)		DBStd	7.34	3.40	3.86	3.47	3.05	3.69	3.20	3.29	3.34	3.26	3.55	3.72	3.39	(7)
(8)		HDD50	1140	222	244	218	140	57	4	0	0	0	12	69	174	(8)
(9)		HDD65	5486	687	664	683	588	486	320	196	138	222	370	495	637	(9)
(10)		CDD50	1134	0	0	1	3	36	134	270	331	228	106	24	1	(10)
(11)		CDD65	5	0	0	0	0	0	0	1	4	0	0	0	0	(11)
(12)		CDH74	1	0	0	0	0	0	1	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	19.4	24.1	22.3	21.4	18.5	16.9	15.3	15.0	16.0	17.2	20.9	21.3	23.8	(14)
(15)	Precipitation	PrecAvg	29.8	2.9	2.2	2.0	1.8	2.0	2.3	2.4	2.6	2.4	2.8	3.2	3.1	(15)
(16)		PrecMax	35.5	4.9	3.7	3.8	5.0	4.8	5.6	3.9	5.4	4.8	4.5	4.9	5.0	(16)
(17)		PrecMin	20.7	0.6	0.7	0.3	0.2	0.6	0.5	1.1	0.4	0.7	0.7	1.4	1.5	(17)
(18)		PrecStd	4.1	1.2	0.8	0.9	1.2	0.9	1.4	0.9	1.1	1.1	0.9	0.9	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.8	50.7	52.0	54.5	60.8	63.4	67.3	69.7	65.6	62.4	58.2	53.6	(19)
(20)			MCWB	48.3	47.5	48.3	49.9	55.6	59.9	63.9	65.3	61.9	60.1	56.4	51.4	(20)
(21)		2%	DB	49.3	48.8	49.7	52.1	57.7	61.1	65.3	67.1	64.4	60.7	56.5	51.8	(21)
(22)			MCWB	47.0	46.7	47.1	49.2	54.4	58.6	62.7	64.0	61.0	58.4	54.7	49.8	(22)
(23)		5%	DB	48.3	47.2	48.4	50.6	56.1	59.5	64.0	65.9	63.1	59.3	54.6	50.5	(23)
(24)			MCWB	46.2	45.0	46.1	48.2	53.6	56.8	61.8	63.4	60.1	56.9	52.7	48.4	(24)
(25)		10%	DB	47.3	45.8	47.2	49.3	54.2	58.0	63.0	64.7	62.0	58.0	53.3	49.2	(25)
(26)			MCWB	45.1	43.4	45.0	47.2	51.9	55.6	61.1	62.4	59.1	55.5	51.5	46.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	48.6	49.3	51.6	57.4	61.6	65.3	66.6	63.0	60.6	57.0	51.9	(27)
(28)			MCD B	50.2	49.6	51.0	53.1	59.0	62.5	66.1	68.2	64.6	62.0	57.9	53.0	(28)
(29)		2%	WB	47.7	47.1	47.7	50.0	55.5	59.4	63.6	64.9	61.8	58.9	55.3	50.0	(29)
(30)			MCD B	48.9	48.5	49.1	51.6	57.0	60.7	64.5	66.4	63.6	60.2	56.6	51.3	(30)
(31)		5%	WB	46.6	45.4	46.6	48.6	53.9	57.5	62.5	63.9	60.9	57.6	53.3	48.4	(31)
(32)			MCD B	48.1	46.9	48.0	50.0	55.9	58.7	63.6	65.5	62.8	59.1	54.3	49.8	(32)
(33)		10%	WB	45.5	44.0	45.4	47.6	52.0	56.3	61.3	63.1	59.8	56.3	52.0	46.8	(33)
(34)			MCD B	47.1	45.5	46.9	49.0	53.7	57.7	62.8	64.6	61.9	57.9	53.4	48.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	4.3	4.4	4.4	4.4	4.3	4.2	4.3	3.8	4.0	4.1	4.6	(35)
(36)			MCDBR	5.3	5.5	5.6	6.1	7.9	6.6	5.9	6.0	4.6	4.8	4.4	5.9	(36)
(37)			MCWBR	5.7	5.3	5.1	4.9	5.8	5.1	4.6	4.5	5.0	5.1	4.8	6.5	(37)
(38)		5% WB	MCD BR	5.1	5.3	5.4	5.7	7.1	5.8	5.1	4.9	4.3	4.6	3.9	5.6	(38)
(39)			MCWBR	5.7	5.4	5.2	5.0	5.8	5.3	4.4	4.3	5.0	5.1	4.7	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.349	0.380	0.404	0.403	0.408	0.411	0.400	0.384	0.362	0.336	0.321	(40)	
(41)		taud	2.338	2.371	2.305	2.272	2.348	2.347	2.350	2.392	2.426	2.433	2.385	2.326	(41)	
(42)		Ebn at Noon	202	238	253	262	269	268	265	261	251	230	200	182	(42)	
(43)		Edh at Noon	19	25	32	38	37	37	36	33	29	23	18	16	(43)	
(44)	All-Sky Solar Radiation	RadAvg	210	435	840	1366	1694	1773	1707	1440	1019	559	258	161	(44)	
(45)		RadStd	19	70	76	130	115	106	169	99	78	45	24	17	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (54 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page