

NORTH SEA STATION 62129, United Kingdom

WMO: 995210

Lat: 53.050N

Lon: 2.117E

Elev: 0

StdP: 101.33

Time Zone: 0.00 (E00)

Period: 90-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.2	1.5	-7.1	2.1	1.8	-5.3	2.4	2.7	23.7	5.7	22.1	5.1	11.0	90	0.913

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	19.1	17.5	18.4	16.9	17.8	16.4	18.0	18.7	17.4	18.1	16.8	17.6	7.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.6	12.6	18.5	17.0	12.1	18.0	16.4	11.6	17.5	50.6	18.8	48.9	18.3	47.2	17.7	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	18.3	16.2	-0.5	21.7	2.1	2.2	-2.1	23.3	-3.3	24.5	-4.5	25.8	-6.1	27.4		
(5)			-2.7	18.9	2.3	2.3	-4.3	20.5	-5.7	21.9	-7.0	23.2	-8.7	24.9	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	6.0	5.2	6.1	7.5	9.6	12.4	14.8	15.9	14.2	11.7	9.2	6.9	(6)	
	DBStd	4.08	1.89	2.15	1.93	1.69	2.05	1.78	1.83	1.86	1.81	1.97	2.07	1.88	(7)	
	HDD10.0	633	123	136	121	78	32	2	0	0	0	7	38	97	(8)	
	HDD18.3	3048	382	369	379	327	270	178	109	77	123	206	275	354	(9)	
	CDD10.0	630	0	0	1	2	20	74	150	184	127	59	13	1	(10)	
	CDD18.3	3	0	0	0	0	0	0	1	2	0	0	0	0	(11)	
	CDH23.3	1	0	0	0	0	0	1	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	8.7	10.8	10.0	9.6	8.3	7.6	6.8	6.7	7.1	7.7	9.3	9.5	10.6	(14)	
(15) Precipitation	PrecAvg	758	73	56	52	46	51	58	61	67	60	71	82	79	(15)	
	PrecMax	902	124	95	96	126	123	143	99	138	122	115	125	128	(16)	
	PrecMin	527	16	18	8	4	14	13	28	10	17	19	36	37	(17)	
	PrecStd	105	30	20	24	31	24	35	23	29	27	24	24	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.4	10.4	11.1	12.5	16.0	17.4	19.6	21.0	18.7	16.9	14.6	12.0	(19)	
		MCWB	9.0	8.6	9.1	9.9	13.1	15.5	17.7	18.5	16.6	15.6	13.6	10.8	(20)	
	2%	DB	9.6	9.3	9.8	11.2	14.3	16.2	18.5	19.5	18.0	15.9	13.6	11.0	(21)	
		MCWB	8.4	8.2	8.4	9.5	12.4	14.8	17.1	17.8	16.1	14.6	12.6	9.9	(22)	
	5%	DB	9.0	8.4	9.1	10.4	13.4	15.3	17.8	18.9	17.3	15.1	12.5	10.3	(23)	
		MCWB	7.9	7.2	7.9	9.0	12.0	13.8	16.6	17.5	15.6	13.9	11.5	9.1	(24)	
	10%	DB	8.5	7.6	8.4	9.6	12.4	14.5	17.2	18.2	16.6	14.5	11.9	9.6	(25)	
		MCWB	7.3	6.3	7.2	8.5	11.1	13.1	16.1	16.9	15.1	13.1	10.8	8.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	9.2	9.6	10.9	14.1	16.4	18.5	19.2	17.2	15.9	13.9	11.1	(27)	
		MCDB	10.1	9.8	10.6	11.7	15.0	17.0	18.9	20.1	18.1	16.7	14.4	11.7	(28)	
	2%	WB	8.7	8.4	8.7	10.0	13.0	15.2	17.5	18.3	16.6	15.0	13.0	10.0	(29)	
		MCDB	9.4	9.2	9.5	10.9	13.9	15.9	18.0	19.1	17.6	15.7	13.7	10.7	(30)	
	5%	WB	8.1	7.4	8.1	9.2	12.2	14.2	16.9	17.7	16.0	14.2	11.8	9.1	(31)	
		MCDB	8.9	8.3	8.9	10.0	13.3	14.8	17.5	18.6	17.1	15.1	12.4	9.9	(32)	
	10%	WB	7.5	6.6	7.5	8.7	11.1	13.5	16.3	17.3	15.4	13.5	11.1	8.2	(33)	
		MCDB	8.4	7.5	8.3	9.5	12.1	14.3	17.1	18.1	16.6	14.4	11.9	9.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.4	2.4	2.4	2.5	2.4	2.4	2.3	2.4	2.1	2.2	2.3	2.6	(35)	
		MCDBR	2.9	3.1	3.1	3.4	4.4	3.7	3.3	3.3	2.6	2.7	2.4	3.3	(36)	
	5% WB	MCWBR	3.2	2.9	2.8	2.7	3.2	2.9	2.6	2.5	2.8	2.8	2.7	3.6	(37)	
		MCWBR	2.9	2.9	3.0	3.2	3.9	3.2	2.8	2.7	2.4	2.5	2.2	3.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.332	0.349	0.380	0.404	0.403	0.408	0.411	0.400	0.384	0.362	0.336	0.321	(40)	
		taud	2.338	2.371	2.305	2.272	2.348	2.347	2.350	2.392	2.426	2.433	2.385	2.326	(41)	
	Ebn at Noon		637	751	798	826	847	845	835	823	790	726	629	574	(42)	
		Edh at Noon	61	79	102	119	116	118	115	105	90	74	58	52	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.66	1.37	2.65	4.31	5.34	5.59	5.38	4.54	3.21	1.76	0.81	0.51	(44)	
	RadStd		0.06	0.22	0.24	0.41	0.36	0.33	0.53	0.31	0.25	0.14	0.07	0.05	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (54 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page