

NORTH SEA STATION 62120, United Kingdom

WMO: 995220

Lat: 56.400N

Lon: 2.100E

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 98-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.0	33.9	19.9	14.9	36.3	22.6	17.0	37.6	47.4	41.5	44.0	43.6	21.2	100	0.854

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	67.9	62.9	66.1	61.5	64.6	60.5	63.7	66.9	62.4	65.3	61.2	64.0	11.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.1	83.5	65.4	61.0	80.1	64.4	59.7	76.4	63.3	29.0	67.2	28.1	65.4	27.2	64.2	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 42.8	38.3	34.0	DB	30.4	73.7	2.8	3.5	28.4	76.2	26.8	78.2	25.2	80.2	23.2	82.7	(4)
(5)			WB	28.7	65.2	2.9	2.7	26.6	67.1	24.9	68.7	23.3	70.2	21.2	72.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.8	42.8	41.5	42.3	45.1	49.5	54.4	58.9	60.3	57.8	52.0	48.3	44.4
	DBStd	7.50	3.68	4.01	3.98	3.37	3.97	3.67	3.78	3.75	3.46	3.53	3.12	3.94
	HDD50	1177	224	239	238	151	58	6	0	0	0	19	67	175
	HDD65	5553	689	659	702	598	481	319	191	153	218	402	502	639
	CDD50	1106	0	0	0	3	41	137	277	318	233	81	15	1
	CDD65	10	0	0	0	0	0	0	4	6	0	0	0	0
	CDH74	4	0	0	0	0	1	0	0	3	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	17.8	22.6	20.5	19.1	16.0	15.3	14.0	13.3	14.8	16.4	19.4	20.8	21.8
Precipitation	PrecAvg	44.6	5.3	4.3	3.9	2.2	1.8	2.5	2.9	3.3	3.8	4.4	5.1	5.2
	PrecMax	56.1	8.9	7.7	6.8	3.6	3.0	4.3	4.3	6.2	5.9	7.4	7.5	11.6
	PrecMin	32.8	1.8	2.2	1.6	1.2	0.8	1.3	1.3	1.1	1.8	1.5	2.7	2.6
	PrecStd	5.6	1.9	1.5	1.2	0.7	0.5	0.7	0.8	1.0	1.1	1.4	1.2	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.9	50.3	51.7	54.7	62.2	64.6	70.8	71.1	67.3	62.1	55.8	52.9
		MCWB	47.8	47.9	47.1	48.2	55.4	58.9	64.0	64.7	61.3	57.7	53.1	49.8
	2%	DB	49.2	48.7	48.9	52.1	58.6	62.2	67.7	68.3	65.0	59.8	54.6	51.4
		MCWB	46.6	46.2	45.6	47.4	52.9	57.5	62.6	63.4	60.3	56.5	52.2	48.7
	5%	DB	48.3	47.6	47.8	50.7	56.2	60.8	65.8	66.6	63.8	58.1	53.4	50.4
		MCWB	45.9	45.2	44.9	46.9	52.4	56.8	61.3	62.1	59.6	54.8	51.1	47.9
	10%	DB	47.4	46.6	46.9	49.5	54.6	59.4	64.1	65.1	62.5	56.5	52.4	49.5
		MCWB	44.8	44.3	44.3	46.4	51.1	55.8	60.1	61.0	58.8	53.3	50.0	47.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.0	48.5	47.7	49.9	57.5	60.9	65.4	66.0	62.6	58.6	54.0	50.4
		MCDB	50.1	49.5	49.4	52.7	57.9	62.6	68.9	69.1	65.7	61.2	55.4	51.6
	2%	WB	47.5	47.0	46.4	48.5	54.6	58.5	63.3	64.1	61.3	57.1	52.9	49.5
		MCDB	48.7	48.2	48.2	50.8	57.0	61.1	66.7	67.3	64.0	59.3	54.3	50.8
	5%	WB	46.3	45.8	45.5	47.7	53.0	57.3	62.1	62.9	60.3	55.6	51.7	48.6
		MCDB	48.0	47.1	47.4	49.9	55.6	60.1	65.1	65.8	62.8	57.7	53.1	50.1
	10%	WB	45.2	44.7	44.7	46.8	51.5	56.2	60.7	61.7	59.3	53.9	50.5	47.6
		MCDB	47.0	46.2	46.7	49.1	54.2	59.0	63.7	64.6	61.9	56.0	52.1	49.4
Mean Daily Temperature Range	5% DB	MDBR	4.4	4.6	4.3	4.5	4.9	4.7	5.1	5.0	4.6	4.3	4.5	4.9
		MCDBR	5.0	5.1	5.3	6.0	7.4	6.9	7.1	7.7	6.4	5.8	5.1	5.2
		MCWBR	6.1	5.0	4.4	3.9	5.2	4.6	4.6	5.0	4.8	5.4	5.2	5.7
	5% WB	MCDBR	5.1	5.0	5.1	5.6	6.7	6.2	6.4	6.8	5.9	5.3	4.5	5.1
		MCWBR	6.3	5.5	4.6	4.0	5.5	4.5	4.7	4.9	5.0	5.7	5.2	6.0
Clear-Sky Solar Irradiance	taub		0.334	0.350	0.370	0.397	0.381	0.386	0.392	0.389	0.377	0.353	0.335	0.313
	taud		2.218	2.298	2.309	2.274	2.402	2.412	2.406	2.419	2.432	2.394	2.271	2.201
	Ebn at Noon		170	221	249	259	272	272	267	260	246	219	169	145
	Edh at Noon		18	24	30	36	34	34	34	31	27	22	17	14
All-Sky Solar Radiation	RadAvg		137	341	756	1309	1773	1766	1660	1364	910	466	187	99
	RadStd		15	48	68	97	120	108	169	92	105	32	20	12

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page