

NORTH SEA STATION 62120, United Kingdom

WMO: 995220

Lat: 56.400N

Lon: 2.100E

Elev: 0

StdP: 101.33

Time Zone: 0.00 (EUW)

Period: 98-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.0	1.1	-6.7	2.1	2.4	-5.2	2.4	3.1	21.2	5.3	19.7	6.4	9.5	100	0.854

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.8	20.0	17.2	19.0	16.4	18.1	15.8	17.6	19.4	16.9	18.5	16.2	17.8	5.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	11.9	18.5	16.1	11.4	18.0	15.4	10.9	17.4	49.6	19.6	47.4	18.5	45.5	17.9	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.1	17.1	15.2	DB	-0.9	23.2	1.5	1.9	-2.0	24.5	-2.9	25.7	-3.8	26.8	-4.9	28.1	(4)
(5)			WB	-1.8	18.5	1.6	1.5	-3.0	19.5	-3.9	20.4	-4.8	21.2	-6.0	22.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	6.0	5.3	5.7	7.3	9.7	12.4	15.0	15.7	14.3	11.1	9.0	6.9		
	DBStd	4.17	2.05	2.23	2.21	1.87	2.21	2.04	2.10	2.09	1.92	1.96	1.74	2.19		
	HDD10.0	654	124	133	132	84	32	3	0	0	0	11	37	97		
	HDD18.3	3085	383	366	390	332	267	177	106	85	121	223	279	355		
	CDD10.0	614	0	0	0	2	23	76	154	177	129	45	8	1		
	CDD18.3	6	0	0	0	0	0	0	2	3	0	0	0	0		
	CDH23.3	2	0	0	0	0	1	0	0	2	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	8.0	10.1	9.2	8.5	7.2	6.8	6.2	6.0	6.6	7.3	8.7	9.3	9.8		
(15) Precipitation	PrecAvg	1132	134	110	98	55	46	64	73	85	97	111	129	131		
	PrecMax	1426	226	196	173	91	75	108	108	157	151	187	190	295		
	PrecMin	834	46	56	40	30	21	34	33	28	45	39	69	65		
	PrecStd	142	49	39	30	17	13	18	21	25	27	36	31	48		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	10.2	11.0	12.6	16.8	18.1	21.5	21.7	19.6	16.7	13.2	11.6		
		MCWB	8.8	8.8	8.4	9.0	13.0	14.9	17.8	18.2	16.3	14.3	11.7	9.9		
	2%	DB	9.6	9.3	9.4	11.2	14.8	16.8	19.8	20.2	18.3	15.4	12.6	10.8		
		MCWB	8.1	7.9	7.6	8.6	11.6	14.2	17.0	17.4	15.7	13.6	11.2	9.3		
	5%	DB	9.1	8.7	8.8	10.4	13.4	16.0	18.8	19.2	17.6	14.5	11.9	10.2		
		MCWB	7.7	7.3	7.2	8.3	11.3	13.8	16.3	16.7	15.3	12.7	10.6	8.8		
	10%	DB	8.5	8.1	8.3	9.7	12.6	15.2	17.8	18.4	16.9	13.6	11.3	9.7		
		MCWB	7.1	6.8	6.8	8.0	10.6	13.2	15.6	16.1	14.9	11.8	10.0	8.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	9.1	8.7	9.9	14.2	16.0	18.6	18.9	17.0	14.8	12.2	10.2		
		MCDB	10.0	9.7	9.7	11.5	14.4	17.0	20.5	20.6	18.7	16.2	13.0	10.9		
	2%	WB	8.6	8.3	8.0	9.2	12.6	14.7	17.4	17.8	16.3	13.9	11.6	9.7		
		MCDB	9.3	9.0	9.0	10.5	13.9	16.2	19.3	19.6	17.8	15.2	12.4	10.4		
	5%	WB	8.0	7.6	7.5	8.7	11.7	14.1	16.7	17.2	15.7	13.1	11.0	9.2		
		MCDB	8.9	8.4	8.6	9.9	13.1	15.6	18.4	18.8	17.1	14.3	11.7	10.1		
	10%	WB	7.3	7.1	7.1	8.2	10.8	13.4	15.9	16.5	15.2	12.2	10.3	8.7		
		MCDB	8.4	7.9	8.1	9.5	12.3	15.0	17.6	18.1	16.6	13.3	11.2	9.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.4	2.5	2.4	2.5	2.7	2.6	2.8	2.8	2.6	2.4	2.5	2.7		
		MCDBR	2.8	2.8	2.9	3.3	4.1	3.8	3.9	4.3	3.6	3.2	2.8	2.9		
	5% WB	MCWBR	3.4	2.8	2.4	2.2	2.9	2.5	2.6	2.8	2.6	3.0	2.9	3.2		
		MCWBR	2.8	2.8	2.9	3.1	3.7	3.5	3.6	3.8	3.3	2.9	2.5	2.9		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.350	0.370	0.397	0.381	0.386	0.392	0.389	0.377	0.353	0.335	0.313		
		taud	2.218	2.298	2.309	2.274	2.402	2.412	2.406	2.419	2.432	2.394	2.271	2.201		
	Ebn at Noon		535	698	784	818	859	858	843	820	774	689	532	456		
		Edh at Noon	57	77	96	115	108	108	107	99	86	69	53	45		
(44) All-Sky Solar Radiation	RadAvg		0.43	1.07	2.38	4.13	5.59	5.57	5.23	4.30	2.87	1.47	0.59	0.31		
	RadStd		0.05	0.15	0.21	0.30	0.38	0.34	0.53	0.29	0.33	0.10	0.06	0.04		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page