

NORTH SEA STATION 63108, United Kingdom

WMO: 995250

Lat: 60.133N

Lon: 1.700E

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	30.2	32.1	N/A	N/A	N/A	N/A	N/A	N/A	52.3	38.5	48.6	39.0	16.5	350	0.927

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.2	64.7	N/A	61.8	N/A	60.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 46.3	41.2	36.3	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.8	40.9	40.3	41.0	42.5	46.3	50.0	55.0	56.7	53.5	48.0	44.7	42.0
	DBStd	6.63	3.28	4.13	3.51	3.34	3.43	2.90	3.63	3.15	3.58	3.47	3.94	3.93
	HDD50	1712	283	273	280	226	123	33	1	0	10	75	161	247
	HDD65	6654	748	693	745	674	579	450	312	259	346	526	610	712
	CDD50	533	0	0	0	2	9	33	155	206	113	14	1	0
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	18.6	22.3	20.3	21.5	17.4	15.3	14.7	15.0	14.3	18.2	21.9	20.8	21.6
Precipitation	PrecAvg	52.8	6.3	5.2	5.0	2.8	1.9	2.6	3.2	3.9	4.6	5.6	5.5	6.1
	PrecMax	65.0	9.9	10.1	9.3	4.8	3.3	5.2	6.0	6.4	7.5	8.5	8.7	9.4
	PrecMin	37.6	3.0	2.3	1.8	1.0	0.9	1.0	1.6	2.6	1.9	2.3	1.7	2.6
	PrecStd	6.5	1.9	2.1	1.8	0.9	0.6	0.9	0.9	1.0	1.3	1.6	1.5	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.3	49.3	48.9	53.7	56.8	61.6	71.5	68.0	64.3	55.8	52.5	50.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	47.7	48.1	47.5	48.9	54.1	57.4	66.2	64.4	61.2	54.1	51.1	49.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	46.7	47.0	46.7	47.2	52.2	54.8	61.5	61.9	59.6	53.1	50.1	48.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	45.8	45.9	46.0	46.2	50.7	53.7	59.3	60.5	57.9	52.2	49.2	47.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.2	5.7	5.0	4.4	4.2	3.7	4.1	4.2	4.0	4.7	4.9	5.2
		MCDBR	6.3	6.2	5.7	5.7	6.2	5.9	8.1	6.9	5.9	5.2	6.0	5.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.338	0.355	0.369	0.383	0.372	0.367	0.383	0.376	0.368	0.351	0.329	0.418
	taud		2.087	2.210	2.277	2.305	2.405	2.459	2.429	2.450	2.430	2.315	2.155	2.441
	Ebn at Noon		121	196	237	258	271	274	266	259	239	197	126	85
	Edh at Noon		15	23	30	34	33	32	32	29	25	21	14	10
All-Sky Solar Radiation	RadAvg		74	245	623	1180	1626	1629	1487	1188	734	353	113	47
	RadStd		10	34	56	100	110	161	134	97	52	34	12	3

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	+1.10	N/A	N/A	N/A	N/A	N/A	-173	-236	N/A	N/A

Nomenclature: See separate page