

NORTH SEA STATION 63101, United Kingdom

WMO: 995280

Lat: 61.117N

Lon: 0.900E

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 98-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.5	34.0	N/A	N/A	N/A	N/A	N/A	N/A	50.7	38.1	48.0	38.5	23.6	350	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	64.2	N/A	61.7	N/A	60.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 44.5	40.0	34.9	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.2	42.9	41.8	43.2	44.7	48.1	51.2	55.6	56.7	54.0	49.3	46.7	43.1		
	DBStd	6.14	3.50	4.37	3.71	3.66	3.21	3.29	3.00	2.58	2.93	3.05	3.40	4.70		
	HDD50	1288	222	230	211	161	74	21	0	0	4	46	105	214		
	HDD65	6150	687	649	676	609	523	413	291	259	329	486	550	678		
	CDD50	612	0	0	0	2	16	58	174	206	126	25	4	1		
	CDD65	2	0	0	0	0	0	0	1	1	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	18.2	22.1	21.3	19.2	17.1	14.6	14.9	14.7	14.1	17.9	20.5	21.0	21.2		
	PrecAvg	52.8	6.3	5.2	5.0	2.8	1.9	2.6	3.2	3.9	4.6	5.6	5.5	6.1		
	PrecMax	65.0	9.9	10.1	9.3	4.8	3.3	5.2	6.0	6.4	7.5	8.5	8.7	9.4		
	PrecMin	37.6	3.0	2.3	1.8	1.0	0.9	1.0	1.6	2.6	1.9	2.3	1.7	2.6		
	PrecStd	6.5	1.9	2.1	1.8	0.9	0.6	0.9	0.9	1.0	1.3	1.6	1.5	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	52.5	52.6	55.3	59.7	65.8	67.5	68.4	63.1	56.7	54.7	53.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	50.4	50.8	50.9	52.2	56.0	60.2	64.6	63.3	60.5	55.2	53.0	52.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	49.1	49.5	49.6	50.5	54.1	57.1	61.8	61.3	59.1	54.1	51.9	50.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	47.7	48.0	48.4	49.2	52.3	55.2	59.6	60.0	57.7	53.0	50.8	49.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	6.0	5.8	5.4	5.7	5.0	4.6	4.8	4.5	4.6	5.4	5.6		
		MCDBR	6.5	7.1	7.0	7.4	8.3	7.8	7.7	6.8	5.9	5.3	6.4	6.4		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.338	0.357	0.370	0.382	0.372	0.365	0.382	0.371	0.366	0.348	0.324	0.382		
	taud		2.062	2.181	2.260	2.302	2.401	2.463	2.431	2.462	2.422	2.302	2.123	2.280		
	Ebn at Noon		108	188	233	256	270	274	265	259	236	192	113	68		
	Edh at Noon		14	23	29	34	33	31	32	29	25	20	13	9		
(44) All-Sky Solar Radiation	RadAvg		61	215	572	1113	1552	1583	1436	1152	699	328	95	38		
	RadStd		8	26	60	87	111	171	131	108	56	40	12	2		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	+1.17	+1.12	N/A	N/A	N/A	-184	-241	N/A	N/A	N/A

Nomenclature: See separate page